

Physikalisch-Technische Bundesanstalt

Braunschweig und Berlin

Member State of OIML
Germany



OIML Certificate No.
R60/2000-DE1-12.01

OIML CERTIFICATE OF CONFORMITY

Issuing Authority

Name: Physikalisch-Technische Bundesanstalt
Address: Bundesallee 100, 38116 Braunschweig
Person responsible: Dr. Oliver Mack

Applicant

Name: Sartorius Mechatronics T&H GmbH
Address: Meiendorfer Str. 205, 22145 Hamburg

Manufacturer of the certified type is the applicant.

Identification of the certified type

Digital strain gauge compression load cell
Type: PR 6204

Further characteristics see pages 2 and 3

This Certificate attests the conformity of the above identified type (represented by the sample or samples identified in the associated Test Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

R60, edition 2000
for accuracy classes D1, C3, C6

This Certificate relates only to the metrological and technical characteristics of the type of instrument covered by the relevant OIML Recommendation identified above.

This Certificate does not bestow any form of legal international approval.

Physikalisch-Technische Bundesanstalt

OIML Certificate No.
R60/2000-DE1-12.01

The conformity was established by the results of tests and examinations provided in the associated Test Reports.

- No. 1.12-4051023-3 including 20 pages (SN: 396395 / 2t / C3 / Y10000)
- No. 1.12-4051023-4 including 32 pages (SN: 383982 / 3t / C3 / Y14000 / digital tests)
- No. 1.12-4051023-5 including 33 pages (SN: 285218 / 12.5t / C6 / Y20000 / digital tests / $p_{LC} = 0.8$)
- No. 1.12-4051023-6 including 20 pages (SN: 396396 / 0.5t / D1 / Y2500 / Temp. -25°C to 55°C)
- No. 1.12-4051023-7 including 19 pages (SN: 396404 / 1t / D1 / Y5000 / Temp. -25°C to 55°C)
- No. 1.12-4051023-8 including 18 pages (SN: 396395 / 2t / D1 / Y5000 / Temp. -25°C to 55°C)
- No. 1.12-4051023-9 including 18 pages (SN: 285218 / 12.5t / D1 / Y5000 / Temp. -25°C to 55°C)

An OIML Basic Certificate has been issued, because the Test Reports mentioned above are based on measurements performed at the laboratories of the applicant.

The Issuing Authority

The OIML Member

Dr. O. Mack
Head of Working Group

Dr. R. Schwartz
Head of Division

18.10.2012

18.10.2012

The load cells of the series PR 6204 are compact compression load cells for self-centering pendulum applications. The strain gauge application is hermetically sealed; the deep-drawn and micro plasma welded housing is made of stainless steel and filled with inert gas. The analog signal of the strain gauge bridge is amplified, scaled and filtered by the integrated module. The load cell is equipped with an interface RS485.

To use the load cell it has to be connected to the junction box of the type PR6024/64S or to the junction box of the type PR6024/68S. The junction box has to be connected to the digital data processing device of the type TN-PRO.

The metrological characteristics for application in approved weighing instruments are listed in table 1.

Physikalisch-Technische Bundesanstalt

OIML Certificate No.
R60/2000-DE1-12.01

Table 1: Essential data

Accuracy class		D1 ¹⁾	C3	C6
Maximum number of load cell intervals n_{LC}		1000	3000	6000
Maximum capacity E_{max}	t	0.5 / 1 / 2 / 3 / 5 / 10 / 12.5 / 20 / 25 / 30 / 50 / 60	2 / 3 / 5 / 10 / 12.5 / 20 / 25 / 30 / 50 / 60	12.5 / 20 / 25 / 30 / 50 / 60
Minimum load cell verification interval $v_{min} = (E_{max} / Y)$		$E_{max} / 5000$ ²⁾	$E_{max} / 14000$ ³⁾	$E_{max} / 20000$
Minimum dead load output return $DR = (\frac{1}{2} \cdot E_{max} / Z)$		$\frac{1}{2} \cdot E_{max} / 1000$	$\frac{1}{2} \cdot E_{max} / 3000$	$\frac{1}{2} \cdot E_{max} / 8000$

Dead load: $0\% \cdot E_{max}$

Safe overload: $200\% \cdot E_{max}$ for $E_{max} < 25$ t; $150\% \cdot E_{max}$ for $E_{max} \geq 25$ t

Fraction: $p_{LC} = 0.7$ for D1 and C3; $p_{LC} = 0.8$ for C6

¹⁾ Extended temperature range: -25°C to 55°C

²⁾ For $E_{max} = 0.5$ t: $v_{min} = E_{max} / 2500$

³⁾ For $E_{max} = 2$ t: $v_{min} = E_{max} / 10000$

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate is issued, partial quotation of the Certificate and of the associated Test Report(s) is not permitted, although either may be reproduced in full.