



Member State of OIML
Japan

OIML Certificate No.
R60/2000-JP1-11.02

OIML CERTIFICATE OF CONFORMITY

Issuing authority

Name: National Metrology Institute of Japan / National Institute of
Advanced Industrial Science and Technology (NMIJ / AIST)
Address: AIST Tsukuba Central 3-9, Tsukuba Ibaraki 305-8563, Japan
Person responsible: Dr. Tamotsu Nomakuchi, President of AIST

Applicant

Name: KUBOTA Corporation
Address: 1-2-47, Shikitsu-higashi, Naniwa-ku, Osaka, 556-8601, Japan

Manufacturer of the certified pattern

Name: KUBOTA Corporation
Address: 1-2-47, Shikitsu-higashi, Naniwa-ku, Osaka, 556-8601, Japan

Identification of the certified pattern:

Beam (shear) load cell
Type: LB-XD-300L-HC, LB-XD-600L-HC, LB-XD-1.5T-HC
Fraction: $P_i=0.8$
Temperature range: $-10\text{ }^{\circ}\text{C} / 40\text{ }^{\circ}\text{C}$



Member State of OIML
Japan



OIML Certificate No.
R60/2000-JP1-11.02

Characteristics:

Model designation			LB-XD-300L-HC	LB-XD-600L-HC	LB-XD-1.5T-HC
Accuracy class	Class	-	C		
Maximum number of load cell verification intervals	n_{max}	-	4000 3000		
Humidity symbol			CH		
Minimum dead load	E_{min}	kg	0		
Maximum capacity	E_{max}	kg	300	600	1500
Safe load limit	E_{lim}	kg	450	900	2250
Minimum verification interval	v_{min}	kg	0.03 0.0375	0.06 0.075	0.15 0.1875
Apportionment factor	p_{LC}		0.8		
Ratio of minimum LC Verification interval $Y = E_{max} / v_{min}$	Y	-	10000 8000		
Ratio of minimum dead load output return $Z = E_{max} / (2 * DR)$	Z	-	4000 in the case of $n_{max}=4000$		
Excitation voltage		V DC	6 ~ 8		
Cable length (maximum)		m	15		

This certificate attests the conformity of the above-mentioned pattern (represented by the samples identified in the associated test report(s) with the requirements of the following Recommendation of the International Organization of Legal Metrology - OIML):

R60, edition 2000 (E)
For accuracy class C

This certificate relates only to the metrological and technical characteristics of the pattern of the instrument concerned, as covered by the relevant OIML International Recommendation.

This certificate does not bestow any form of legal international approval.

The conformity was established by tests described in the associated test report no. 10-28/R60:2000, that includes 33 pages.



Member State of OIML
Japan

OIML Certificate No.
R60/2000-JP1-11.02

The Issuing Authority
NMIJ/AIST

The OIML member



Dr. T. Nomakuchi
President of AIST
2011-01-07

Dr. Y. Miki
2011-01-07

Important note: Apart from the mention of certificate's reference number and the name of the OIML Member State in which the certificate was issued, partial quotation of the certificate or the associated test report is not permitted, though they may be reproduced in full.