



OIML Member state
The Netherlands

OIML CERTIFICATE OF CONFORMITY

Issuing authority

Name: NMI Certin B.V.
Address: Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
Person responsible: Ing. C. Oosterman

Applicant

Name: Keli Electric Manufacturing (Ningbo) Co., Ltd.
Address: No. 199 Changxing Road,
Jiangbei District, Ningbo,
P.R. China

Manufacturer of the certified type

Name: Keli Electric Manufacturing (Ningbo) Co., Ltd.
Address: No. 199 Changxing Road,
Jiangbei District, Ningbo,
P.R. China

Identification of certified type

A shear beam load cell
Type : SB-S....
Fraction : $P_i = 0.7$
Temperature range -10 °C / +40 °C

Maximum capacity (E_{max})	1 t up to and including 5 t
Accuracy Class	C
Maximum number of load cell intervals (n)	3000
Ratio of minimum LC Verification interval $Y = E_{max} / V_{min}$	8000
Ratio of minimum dead load output return $Z = E_{max} / (2 * DR)$	6000



OIML Member state

The Netherlands

This Certificate attests the conformity of the above identified type (represented by the sample or samples identified in the associated Test Report, the test certificate and the description with number TC7349 and the appertaining documentation folder) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

R60

Edition 2000 (E)

for accuracy class C

This Certificate relates only to the metrological and technical characteristics of the type of instrument covered by the relevant OIML Recommendation identified above.

This Certificate does not bestow any form of legal international approval.

The conformity was established by the results of tests and examinations provided in the associated Test Report:

N° R60/2000-NL1-08.02 that includes 40 pages.

The Issuing Authority

Ing. C. Oosterman

Manager Product Certification



28 January 2008

*

**

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate is issued, partial quotation of the Certificate and of the associated Test Report is not permitted, although either may be reproduced in full.