

INTERNATIONAL  
RECOMMENDATION

**OIML R 75-3**

Edition 2006 (E)

---

Heat meters

Part 3: Test Report Format

Compteurs d'énergie thermique

Partie 3: Format du rapport d'essai

---



## Contents

Introduction .....	4
<i>Explanatory notes to the Test Report Format</i> .....	4
<i>Note concerning the numbering of the following pages</i> .....	4
<b>I. TYPE EVALUATION REPORT</b> .....	5
1 Information concerning the type .....	5
2 Summary of the tests .....	13
3 Performance tests .....	14
4 Dry heat .....	24
5 Cold .....	25
6 Variations in supply voltage and frequency .....	26
7 Durability test .....	34
8 Damp heat cyclic .....	38
9 Short time mains voltage reduction .....	39
10 Electrical transients .....	41
11 Electromagnetic field .....	44
12 Electrostatic discharge .....	47
13 Static magnetic field .....	48
14 Electromagnetic field at mains frequency .....	50
15 Internal pressure .....	51
16 Pressure loss .....	52
<b>II. INITIAL VERIFICATION REPORT</b> .....	53
1 Information concerning the EUT verified .....	53
2 Initial verification tests .....	60

## Foreword

The International Organization of Legal Metrology (OIML) is a worldwide, intergovernmental organization whose primary aim is to harmonize the regulations and metrological controls applied by the national metrological services, or related organizations, of its Member States. The main categories of OIML publications are:

- **International Recommendations (OIML R)**, which are model regulations that establish the metrological characteristics required of certain measuring instruments and which specify methods and equipment for checking their conformity. OIML Member States shall implement these Recommendations to the greatest possible extent;
- **International Documents (OIML D)**, which are informative in nature and which are intended to harmonize and improve work in the field of legal metrology;
- **International Guides (OIML G)**, which are also informative in nature and which are intended to give guidelines for the application of certain requirements to legal metrology; and
- **International Basic Publications (OIML B)**, which define the operating rules of the various OIML structures and systems.

OIML Draft Recommendations, Documents and Guides are developed by Technical Committees or Subcommittees which comprise representatives from the Member States. Certain international and regional institutions also participate on a consultation basis. Cooperative agreements have been established between the OIML and certain institutions, such as ISO and the IEC, with the objective of avoiding contradictory requirements. Consequently, manufacturers and users of measuring instruments, test laboratories, etc. may simultaneously apply OIML publications and those of other institutions.

International Recommendations, Documents, Guides and Basic Publications are published in English (E) and translated into French (F) and are subject to periodic revision.

Additionally, the OIML publishes or participates in the publication of **Vocabularies (OIML V)** and periodically commissions legal metrology experts to write **Expert Reports (OIML E)**. Expert Reports are intended to provide information and advice, and are written solely from the viewpoint of their author, without the involvement of a Technical Committee or Subcommittee, nor that of the CIML. Thus, they do not necessarily represent the views of the OIML.

This publication - reference OIML R 75-3, Edition 2006 - was developed by Technical Committee TC 11 *Instruments for measuring temperature and associated quantities*.

It was approved for final publication by the International Committee of Legal Metrology in 2006.

OIML Publications may be downloaded from the OIML web site in the form of PDF files. Additional information on OIML Publications may be obtained from the Organization's headquarters:

Bureau International de Métrologie Légale  
11, rue Turgot - 75009 Paris - France  
Telephone: 33 (0)1 48 78 12 82  
Fax: 33 (0)1 42 82 17 27  
E-mail: [biml@oiml.org](mailto:biml@oiml.org)  
Internet: [www.oiml.org](http://www.oiml.org)

# OIML R 75: Heat meters

## Part 3: Test Report Format

### Introduction

Heat meters and sub-assemblies which comply with the general requirements of OIML R 75-1 and which are submitted for type approval and for initial verification shall comply with the relevant tests specified in R 75-2.

Implementation of this Test Report Format is informative with regard to the implementation of R 75-1 and R 75-2 in national regulations; however, **its implementation for the Type Evaluation Report is mandatory within the framework of the OIML Certificate System for Measuring Instruments.**

*Note:* For terms and definitions, refer to R 75-1.

### *Explanatory notes to the Test Report Format*

Section I includes the required format of a Type Evaluation Report and Section II includes a recommended format of an Initial Verification Report for a complete heat meter, a calculator, a flow sensor, a temperature sensor pair or a combined sub-assembly.

The symbols used in the tables are:

- MPE ..... Maximum Permissible Error
- EUT ..... Equipment Under Test
- RVM ..... Reference Values for the Meurand (5.3 in R 75-2)
- n/a ..... not applicable

The summary tables of tests and the tables for each test shall be completed according to this example:

Pass ×	Fail ___	When the EUT passes the test
Pass ___	Fail ×	When the EUT fails the test
Pass <b>n/a</b>	Pass <b>n/a</b>	Not applicable

### *Note concerning the numbering of the following pages*

In addition to the sequential numbering at the bottom of the pages of this Publication, a special place is left at the top of each page (starting with the following page) for numbering the pages of reports established following this model. For a given report, it is advisable to complete the sequential numbering of each page by the indication of the total number of pages of the report.

## I. TYPE EVALUATION REPORT

### 1 Information concerning the type

#### 1.1 General information

##### Testing Authority

Name: .....

Address: .....

Accredited laboratory:    Yes     No     Accreditation No.: .....    By company: .....

Test No.: .....    Declaration of expanded uncertainty of test equipment No.: .....

Contact information: .....

Date of beginning and end of tests: .....

Name(s) of test engineer(s): .....

##### Applicant/matrix information

Application No.: .....

Application date: .....

Model designation: .....

Applicant: .....

Address: .....

Manufacturer: .....

Address: .....

Representative: .....

(Name, telephone).....

#### 1.2 Information concerning the type

Instrument category:

Complete instrument     Documentation No.: .....    Serial No.: .....    Year of manufacture: .....

Calculator     Documentation No.: .....    Serial No.: .....    Year of manufacture: .....

Flow sensor     Documentation No.: .....    Serial No.: .....    Year of manufacture: .....

Temperature sensor pair     Documentation No.: .....    Serial No.: .....    Year of manufacture: .....

Combined sub-assemblies     Documentation No.: .....    Serial No.: .....    Year of manufacture: .....

Short description of the principle of measurement (measuring method): .....

List of documents provided by the manufacturer: .....

All values in this table are taken from documentation pages: .....

Additional qualifying information supplied: Yes  No  Remarks: .....

Completeness and correctness of instruction manual, marking, assembly instructions, installation instructions, security sealing plan, initial functionality check and operation instruction submitted for type evaluation (requirements of sections 11 and 12 in R 75-1 and 8.1 in R 75-2):

Pass  Fail  Remarks: .....

### 1.2.1 Complete instrument specifications

Accuracy class: Class 1  Class 2  Class 3

Heat conveying liquid: Water  Water-glycol solution  Mixing: \_\_\_/\_\_\_

Environmental class: A  B  C

Type of temperature sensors: Pt 100  Pt 500  Pt 1000  Pt 10000  other

Indication if shielding: Yes  No

Flow sensor to be operated: In the flow  In the return

Limits of temperature:  $\theta_{\min} = \text{_____ } ^\circ\text{C}$   $\theta_{\max} = \text{_____ } ^\circ\text{C}$

Limits of temperature difference:  $\Delta\theta_{\min} = \text{_____ K}$   $\Delta\theta_{\max} = \text{_____ K}$

Display unit options: GJ  MJ  kWh

Maximum value of thermal power ( $P_s$ ): \_\_\_\_\_ MW

Output signal for testing: Type: \_\_\_\_\_ Level: \_\_\_\_\_ V

Corresponding factor for test output: \_\_\_\_\_ Wh/pulse

Display unit options for testing: MJ  kWh  Wh

Dynamic behavior (circumstances of temperature measurement and integration): .....

Other functions in addition to heat indication: .....

For the flow sensor:

Physical dimensions (length, thread/flange specification): .....

Installation conditions (e.g. straight sections of piping): .....

Upstream/downstream, vertical/horizontal position: .....

Maximum admissible working pressure (PN-class): .....

Maximum pressure loss at  $q_p$ : \_\_\_\_\_ bar \_\_\_\_\_ PaTemperature sensor installed: Yes  No Filter installed: Yes  No Straightener installed: Yes  No Range of electrical conductivity of water (if necessary): \_\_\_\_\_  $\mu\text{S/cm}$  to \_\_\_\_\_  $\mu\text{S/cm}$ Length of the connection cable to the electrodes  
(if the electronic part is separated from the sensor head): \_\_\_\_\_ m

Response time (for fast response meters): \_\_\_\_\_ s

Limits of flowrate:  $q_p =$  \_\_\_\_\_  $\text{m}^3/\text{h}$   $q_i =$  \_\_\_\_\_  $\text{m}^3/\text{h}$   $q_s =$  \_\_\_\_\_  $\text{m}^3/\text{h}$ Low flow threshold value: \_\_\_\_\_  $\text{m}^3/\text{h}$ Limits of temperature (heat conveying liquid):  $\theta_{\min} =$  \_\_\_\_\_  $^{\circ}\text{C}$   $\theta_{\max} =$  \_\_\_\_\_  $^{\circ}\text{C}$ 

Nominal meter factor: \_\_\_\_\_ litres/pulse

Output signal for testing: Type: \_\_\_\_\_ Level: \_\_\_\_\_ V

Corresponding factor for test output: \_\_\_\_\_ litres/pulse

**1.2.2 Calculator specifications**Type of temperature sensors: Pt 100  Pt 500  Pt 1000  Pt 10000 (or declaration of sensor coefficients:  $R_0$ : \_\_\_\_\_  $\Omega$  A: \_\_\_\_\_ B: \_\_\_\_\_)Wiring of sensors: 4-wire  3-wire  2-wire Indication if shielding: Yes  No Flow sensor to be operated: In the flow  In the return Environmental class: A  B  C Heat conveying liquid: Water  Water-glycol solution  Mixing: \_\_\_/\_\_\_Limits of temperature:  $\theta_{\min} =$  \_\_\_\_\_  $^{\circ}\text{C}$   $\theta_{\max} =$  \_\_\_\_\_  $^{\circ}\text{C}$ Limits of temperature difference:  $\Delta\theta_{\min} =$  \_\_\_\_\_ K  $\Delta\theta_{\max} =$  \_\_\_\_\_ K

Display unit options: GJ  MJ  kWh

Maximum value of thermal power ( $P_s$ ): \_\_\_\_\_ MW

RMS value of temperature sensor current: \_\_\_\_\_ mA

Required input signal from the flow sensor:

Nominal meter factor: \_\_\_\_\_ litres/pulse (or corresponding factor for test input)

Input signal for testing, type: \_\_\_\_\_ level: \_\_\_\_\_ V

Maximum frequency of flow sensor signal: For testing: \_\_\_\_\_ Hz In normal use: \_\_\_\_\_ Hz

Output signal for testing: Type: \_\_\_\_\_ level: \_\_\_\_\_ V

Corresponding factor for test output: \_\_\_\_\_ Wh/pulse

Display unit options for testing: MJ  kWh  Wh

Dynamic behavior (circumstances of temperature measurement and integration): .....

Other functions in addition to heat indication: .....

### 1.2.3 Flow sensor specifications

Accuracy class: Class 1  Class 2  Class 3

Environmental class: A  B  C

Heat conveying liquid: Water  Water-glycol solution  Mixing: \_\_\_/\_\_\_

Physical dimensions (length, thread/flange specification): .....

Installation conditions (e.g. straight sections of piping): .....

Upstream/downstream, vertical/horizontal position: .....

Maximum admissible working pressure (PN-class): .....

Maximum pressure loss at  $q_p$ : \_\_\_\_\_ bar \_\_\_\_\_ Pa

Temperature sensor installed: Yes  No

Filter installed: Yes  No

Straightener installed: Yes  No

Limits of temperature (heat conveying liquid):  $\theta_{\min} =$  \_\_\_\_\_ °C  $\theta_{\max} =$  \_\_\_\_\_ °C

Range of electrical conductivity of water (if necessary): \_\_\_\_\_  $\mu\text{S/cm}$  to \_\_\_\_\_  $\mu\text{S/cm}$

Length of the connection cable to the electrodes  
(if the electronic part is separated from the sensor head): \_\_\_\_\_ m

Response time (for fast response meters): \_\_\_\_\_ s



Limits of flowrate:  $q_p =$  \_\_\_\_\_ m<sup>3</sup>/h     $q_i =$  \_\_\_\_\_ m<sup>3</sup>/h     $q_s =$  \_\_\_\_\_ m<sup>3</sup>/h  
 Low flow threshold value: \_\_\_\_\_ m<sup>3</sup>/h  
 Nominal meter factor: \_\_\_\_\_ litres/pulse  
 Corresponding factor for test output: \_\_\_\_\_ litres/pulse  
 Output signal for testing, type: \_\_\_\_\_ level: \_\_\_\_\_ V

### 1.2.4 Temperature sensor pair specifications

Type identification: Pt 100     Pt 500     Pt 1000     Pt 10000   
 (or declaration of sensor coefficients:  $R_0:$  \_\_\_\_\_  $\Omega$      $A:$  \_\_\_\_\_     $B:$  \_\_\_\_\_ )  
 Wiring of sensors: 4-wire     3-wire     2-wire   
 Total resistance of a 2-cable wire: \_\_\_\_\_  $\Omega$ /m    Cross section of a wire: \_\_\_\_\_ mm<sup>2</sup>  
 Maximum length of a cable for: Pt 100 \_\_\_\_\_ m, Pt 500 \_\_\_\_\_ m, Pt 1000 \_\_\_\_\_ m, other \_\_\_\_\_ m  
 Indication if shielding: Yes     No   
 Limits of temperature:  $\theta_{min} =$  \_\_\_\_\_ °C     $\theta_{max} =$  \_\_\_\_\_ °C  
 Limits of temperature difference:  $\Delta\theta_{min} =$  \_\_\_\_\_ K     $\Delta\theta_{max} =$  \_\_\_\_\_ K  
 Installation requirements (pocket mounting): Yes     No   
 Physical dimensions: Length: \_\_\_\_\_ mm    Diameter: \_\_\_\_\_ mm  
 Minimum immersion depth: \_\_\_\_\_ mm  
 Maximum liquid velocity for sensors over 200 mm length: \_\_\_\_\_ m/s  
 Maximum admissible working pressure for direct mounted sensors (PN-class): \_\_\_\_\_  
 $\tau_{0,5}$  response time: \_\_\_\_\_ s  
 Identification of flow and return temperature sensors (if needed): At the flow     At the return   
 Maximum RMS value of sensor current: \_\_\_\_\_ mA

### 1.2.5 Combined sub-assemblies specifications (calculator + temperature sensor pair)

Type of temperature sensors: Pt 100     Pt 500     Pt 1000     Pt 10000   
 (or declaration of sensor coefficients:  $R_0:$  \_\_\_\_\_  $A:$  \_\_\_\_\_     $B:$  \_\_\_\_\_ )  
 Wiring of sensors: 4-wire     3-wire     2-wire     Indication if shielding: Yes     No   
 Environmental class: A     B     C

Heat conveying liquid: Water  Water-glycol solution  Mixing: \_\_\_/\_\_\_

Flow sensor to be operated: In the flow  In the return

Limits of temperature:  $\theta_{\min} =$  \_\_\_\_\_ °C  $\theta_{\max} =$  \_\_\_\_\_ °C

Limits of temperature difference:  $\Delta\theta_{\min} =$  \_\_\_\_\_ K  $\Delta\theta_{\max} =$  \_\_\_\_\_ K

Installation requirements (pocket mounting): Yes  No

Physical dimensions: Length: \_\_\_\_\_ mm Diameter: \_\_\_\_\_ mm

Minimum immersion depth: \_\_\_\_\_ mm

Maximum liquid velocity for sensors over 200 mm length: \_\_\_\_\_ m/s

Maximum admissible working pressure for direct mounted sensors (PN-class): \_\_\_\_\_

$\tau_{0.5}$  response time: \_\_\_\_\_ s

Display unit options: GJ  MJ  kWh

Maximum value of thermal power ( $P_s$ ): \_\_\_\_\_ MW

Output signal for testing: Type: \_\_\_\_\_ Level: \_\_\_\_\_ V

Corresponding factor for test output: \_\_\_\_\_ Wh/pulse

Display unit options for testing: MJ  kWh  Wh

Required input signal from the flow sensor:

Input signal for testing: Type: \_\_\_\_\_ Level: \_\_\_\_\_ V

Nominal meter factor: \_\_\_\_\_ litres/pulse (or corresponding factor for test input)

Maximum frequency of flow sensor signal: For testing: \_\_\_\_\_ Hz In normal use: \_\_\_\_\_ Hz

Dynamic behavior (circumstances of temperature measurement and integration): .....

Other functions in addition to heat indication: .....

Correctness of identification of flow and return temperature sensors: Yes  No

**1.2.6 Combined sub-assemblies specifications (calculator + flow sensor)**

Accuracy class: Class 1  Class 2  Class 3

Environmental class: A  B  C

Type of temperature sensors: Pt 100  Pt 500  Pt 1000  Pt 10000

Wiring of sensors: 4-wire  3-wire  2-wire  Indication if shielding: Yes  No

Heat conveying liquid: Water  Water-glycol solution  Mixing: \_\_\_/\_\_\_

Flow sensor to be operated: In the flow  In the return

Limits of temperature:  $\theta_{\min} =$  \_\_\_ °C  $\theta_{\max} =$  \_\_\_ °C

Limits of temperature difference:  $\Delta\theta_{\min} =$  \_\_\_ K  $\Delta\theta_{\max} =$  \_\_\_ K

Display unit options (MJ, kWh): \_\_\_\_\_

Maximum value of thermal power ( $P_s$ ): \_\_\_\_\_ MW

Output signal for testing: Type: \_\_\_\_\_ Level: \_\_\_\_\_ V

Corresponding factor for test output: \_\_\_\_\_ Wh/pulse

Display unit options for testing: MJ  kWh  Wh

Dynamic behavior (circumstances of temperature measurement and integration): .....

Other functions in addition to heat indication: .....

For the flow sensor:

Physical dimensions (length, thread/flange specification): .....

Installation conditions (e.g. straight sections of piping): .....

Upstream/downstream, vertical/horizontal position: .....

Maximum admissible working pressure (PN-class): \_\_\_\_\_

Maximum pressure loss at  $q_p$ : \_\_\_\_\_ bar \_\_\_\_\_ Pa

Temperature sensor installed:  Yes  No

Filter installed:  Yes  No

Straightener installed:  Yes  No

Range of electrical conductivity of water (if necessary): \_\_\_\_\_  $\mu\text{S/cm}$  to \_\_\_\_\_  $\mu\text{S/cm}$

Length of the connection cable to the electrodes (if the electronic part is separated from the sensor head): \_\_\_\_\_ m

Response time (for fast response meters): \_\_\_\_\_ s

Limits of flowrate:  $q_p =$  \_\_\_\_\_ m<sup>3</sup>/h     $q_i =$  \_\_\_\_\_ m<sup>3</sup>/h     $q_s =$  \_\_\_\_\_ m<sup>3</sup>/h

Low flow threshold value: \_\_\_\_\_ m<sup>3</sup>/h

Limits of temperature (heat conveying liquid):  $\theta_{min} =$  \_\_\_\_\_ °C     $\theta_{max} =$  \_\_\_\_\_ °C

Nominal meter factor: \_\_\_\_\_ litres/pulse

Corresponding factor for test output: \_\_\_\_\_ litres/pulse

Output signal for testing:            Type: \_\_\_\_\_            Level: \_\_\_\_\_ V

### 1.3 Rated operating conditions

#### Complete instrument, (combined) sub-assemblies

	Environmental class			Remarks
	A <input type="checkbox"/>	B <input type="checkbox"/>	C <input type="checkbox"/>	
Ambient temperature °C	+ 5 to + 55	- 25 to + 55	+ 5 to + 55	
Relative humidity %	< 93			
Mains supply voltage V Mains frequency Hz	$U_{nom}$ (+ 10 %/- 15 %) $f_{nom}$ (± 2 %)			Frequency used for measurement purpose: Yes <input type="checkbox"/> No <input type="checkbox"/>
External low voltage V (< 50 V)	AC <input type="checkbox"/> $U_{nom}$ (+ 50 %/- 50 %) DC <input type="checkbox"/> $U_{nom}$ (+ 75 %/- 50 %)	Frequency used for measurement purpose: Yes <input type="checkbox"/> No <input type="checkbox"/>		
Battery voltage V	Voltage in service under normal conditions			Type, lifetime

#### General information concerning ambient test conditions

Test No.: .....

Application No.: .....

Ambient temperature: \_\_\_\_\_ °C    Relative humidity: \_\_\_\_\_ %

Barometric pressure: \_\_\_\_\_ kPa

**2 Summary of the tests (Ref.: 6.2, Table 2 in R 75-2)**

Test according to Subclause	Temperature sensor pair	Flow sensor	Calculator	Complete instrument	Combined sub-assemblies	
	<i>Serial No.</i> _____	<i>Serial No.</i> _____	<i>Serial No.</i> _____	<i>Serial No.</i> _____	Calculator + temp. sensor pair <i>Serial No.</i> _____	Calculator + flow sensor <i>Serial No.</i> _____
6.4	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
6.5	--- ---	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
6.6	--- ---	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
6.7	--- ---	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
6.8	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
6.9	--- ---	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
6.10	--- ---	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
6.11	--- ---	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
6.12	--- ---	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
6.13	--- ---	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
6.14	--- ---	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
6.15	--- ---	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
6.16	--- ---	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	--- ---	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	--- ---	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
6.17	--- ---	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	--- ---	Pass <input type="checkbox"/> Fail <input type="checkbox"/>	--- ---	Pass <input type="checkbox"/> Fail <input type="checkbox"/>

### 3 Performance tests

#### 3.1 Flow sensor

Test results: Flow sensor

**Table 1: Performance test (Ref.: 6.4.1 in R 75-2)**

Initial intrinsic error at RVM-conditions: \_\_\_\_\_ %

$K = (q_s/q_i)^{1/4} =$  \_\_\_\_\_ Electrical conductivity of water (if necessary): \_\_\_\_\_  $\mu\text{S/cm}$

Test number	Test point flowrate		Temperature of liquid		Flow sensor output signal volume $\text{m}^3$	Conventional true volume $\text{m}^3$	Error %	MPE %
	$\text{m}^3/\text{h}$		$^{\circ}\text{C}$					
	Calculated	Actual	Level	Measured				
1	$q_1$		$(\theta_{\min} + 5)$					
2	$q_2$		$(\theta_{\min} + 5)$					
3	$q_3$		$(\theta_{\min} + 5)$					
4	$q_4$		$(\theta_{\min} + 5)$					
5	$q_5$		$(\theta_{\min} + 5)$					
6	$q_1$		$(50 \pm 5)$					
7	$q_2$		$(50 \pm 5)$					
8	$q_3$		$(50 \pm 5)$					
9	$q_4$		$(50 \pm 5)$					
10	$q_5$		$(50 \pm 5)$					
11	$q_1$		$(85 \pm 5)$					
12	$q_2$		$(85 \pm 5)$					
13	$q_3$		$(85 \pm 5)$					
14	$q_4$		$(85 \pm 5)$					
15	$q_5$		$(85 \pm 5)$					

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

### 3.1.1 Electromagnetic type flow sensors (Ref.: 6.4.1.2 in R 75-2)

The test results have to be noted according to Table 1. The electrical conductivity of water and the length of the connecting cable to the electrodes shall be noted in the type test report.

### 3.1.2 Fast response meters (Ref.: 6.4.1.3 in R 75-2)

**Test results: Flow sensor**

**Table 2: Performance test - fast response meters (Ref.: 6.4.1.3 in R 75-2)**

Initial intrinsic error at RVM-conditions: \_\_\_\_\_ %

In the case of a complete instrument or combined sub-assemblies:

Temperature difference: \_\_\_\_\_ K

Cycle No.	Test point flowrate $q_s$ $m^3/h$	Temperature of liquid $^{\circ}C$		Flow sensor output signal volume $m^3$	Conventional true volume $m^3$	Error %	MPE %
		Level	Measured				
1		$\theta_{min}$ to $(\theta_{min} + 5)$					
2		$\theta_{min}$ to $(\theta_{min} + 5)$					
3		$\theta_{min}$ to $(\theta_{min} + 5)$					
4		$\theta_{min}$ to $(\theta_{min} + 5)$					
5		$\theta_{min}$ to $(\theta_{min} + 5)$					
6		$\theta_{min}$ to $(\theta_{min} + 5)$					
7		$\theta_{min}$ to $(\theta_{min} + 5)$					
8		$\theta_{min}$ to $(\theta_{min} + 5)$					
9		$\theta_{min}$ to $(\theta_{min} + 5)$					
10		$\theta_{min}$ to $(\theta_{min} + 5)$					

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

### 3.2 Calculator (Ref.: 6.4.2 in R 75-2)

**Test results: Calculator**

**Table 3: Performance test (Ref.: 6.4.2 in R 75-2)**

Initial intrinsic error at RVM-conditions: \_\_\_\_\_ %

Simulated volume: \_\_\_\_\_ m<sup>3</sup>

Simulated flowrate: \_\_\_\_\_ m<sup>3</sup>/h

Test No.	Test point °C $\theta_{\text{return}} = \theta_{\text{min}}^*)$	Temperature difference $\Delta\theta$ K									
		$\Delta\theta_{\text{min}}^*)$		5 <sup>*)</sup>		20 <sup>*)</sup>		$\Delta\theta_{\text{RVM}}^*)$		$\Delta\theta_{\text{max}}^*)$	
		Error %	MPE %	Error %	MPE %	Error %	MPE %	Error %	MPE %	Error %	MPE %
1											
2											
3											
Test No.	$\theta_{\text{return}} = \theta_{\text{RVM}}^*)$	$\Delta\theta_{\text{min}}^*)$		5 <sup>*)</sup>		20 <sup>*)</sup>		$\Delta\theta_{\text{RVM}}^*)$			
		Error %	MPE %	Error %	MPE %	Error %	MPE %	Error %	MPE %		
4											
5											
6											
Test No.	$\theta_{\text{flow}} = \theta_{\text{max}}^*)$	20 <sup>*)</sup>		$\Delta\theta_{\text{RVM}}^*)$		$\Delta\theta_{\text{max}}^*)$					
		Error %	MPE %	Error %	MPE %	Error %	MPE %				
7											
8											
9											

<sup>\*)</sup> Test points are measured values.

Errors calculated from (pulse) output signal  or display indication

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_



### 3.3 Temperature sensors (Ref.: 6.4.3 in R 75-2)

#### Test results: Temperature sensors

**Table 4:** Minimum immersion depth, single sensors (Ref.: 4.16 in R 75-1 and 6.4.3.1 in R 75-2)

Temperature sensor serial No: \_\_\_\_\_

Temperature of water bath: \_\_\_\_\_ °C

Maximum permissible change of the output value < 0.1 K

Immersion depth mm	Measured resistance $\Omega$	Calculated temperature <sup>*)</sup> °C
10		
15		
20		
25		
30		
35		
40		
45		
50		

<sup>\*)</sup> using standard IEC 60751 constants

*Note:* Values of immersion depths are examples.

Minimum immersion depth specified by measurements: \_\_\_\_\_ mm

Minimum immersion depth specified by the supplier: \_\_\_\_\_ mm

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Table 5a:** Thermal response time, single sensors are not installed in pockets  
(Ref.: 4.1 in R 75-1 and 6.4.3.2 in R 75-2)

Water bath temperature: \_\_\_\_\_ °C

Thermal response time specified by the supplier: \_\_\_\_\_ s

Temperature sensor type, serial number	Measured response 50 % time $\tau_{0.5}$ s	Specified response 50 % time $\tau_{0.5}$ s

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

*Note:* Repeat the measurements with sensors in pockets, if the tolerated gap between the sensor and the pocket is more than 0.125 mm or the immersion depth of the pocket is less than 70 mm.

**Table 5b: Thermal response time, single sensors are installed in pockets**  
**(Ref.: 4.1 in R 75-1 and 6.4.3.2 in R 75-2)**

Water bath temperature: \_\_\_\_\_ °C

Thermal response time specified by the supplier: \_\_\_\_\_ s

Temperature sensor serial number	Measured response 50 % time	Specified response 50 % time
	$\tau_{0.5}$ s	$\tau_{0.5}$ s

Markings:                      Pass: \_\_\_\_\_      Fail: \_\_\_\_\_      Signature: \_\_\_\_\_

**Table 6a: Calculation of constants of the temperature/resistance equation of IEC 60751.**  
**Sensors are tested without pockets (Ref.: 9.2.2.2 in R 75-1 and 6.4.3.3 in R 75-2, IEC 60751)**

Sensor pair serial No.: \_\_\_\_\_

Temperature range specified by the supplier from \_\_\_\_\_ °C to \_\_\_\_\_ °C

Temperature difference for the pair specified by the supplier from \_\_\_\_\_ K to \_\_\_\_\_ K

Type of temperature sensors:    Pt 100     Pt 500     Pt 1000     Pt 10000

Sensors are intended to be installed in pockets:    Yes                       No

Temperature °C		Measured resistance Ω	
Level <sup>*)</sup>	Measured	Sensor 1 (flow)	Sensor 2 (return)
(5 ± 5)			
(40 ± 5)			
(70 ± 5)			
(90 ± 5)			
(130 ± 5)			
(160 ± 10)			

<sup>\*)</sup> The temperature sensors shall be tested at least at three temperature levels. Temperature levels shall be chosen to optimize the spread of temperature over the temperature range specified by the supplier.

Constants of sensor 1 calculated according to IEC 60751:

R<sub>0</sub>: \_\_\_\_\_ Ω    A: \_\_\_\_\_    B: \_\_\_\_\_

Constants of sensor 2 calculated according to IEC 60751:

R<sub>0</sub>: \_\_\_\_\_ Ω    A: \_\_\_\_\_    B: \_\_\_\_\_

Markings:                      Pass: \_\_\_\_\_      Fail: \_\_\_\_\_      Signature: \_\_\_\_\_

**Table 6b: Calculation of constants of the temperature/resistance equation of IEC 60751.**  
**Sensors are tested in pockets (Ref.: 9.2.2.2 in R 75-1 and 6.4.3.3 in R 75-2, IEC 60751)**

Test is performed if sensors are intended to be installed in pockets and if the maximum tolerated gap between the sensor and the pocket is more than 0.125 mm or the immersion depth of the pocket is less than 70 mm.

Sensor pair: Serial No. (flow): \_\_\_\_\_ Serial No. (return): \_\_\_\_\_

Temperature range specified by the supplier from \_\_\_\_ °C to \_\_\_\_ °C

Temperature difference for the pair specified by the supplier from \_\_\_\_ K to \_\_\_\_ K

Type of temperature sensors: Pt 100  Pt 500  Pt 1000  Pt 10000

Temperature °C		Measured resistance Ω	
Level <sup>*)</sup>	Measured	Sensor 1 (flow)	Sensor 2 (return)
(5 ± 5)			
(40 ± 5)			
(70 ± 5)			
(90 ± 5)			
(130 ± 5)			
(160 ± 10)			

<sup>\*)</sup> The temperature sensors shall be tested at least at three temperature levels. Temperature levels shall be chosen to optimize the spread of temperature over the temperature range specified by the supplier.

Constants of sensor 1 calculated according to IEC 60751:

R<sub>0</sub>: \_\_\_\_\_ Ω    A: \_\_\_\_\_    B: \_\_\_\_\_

Constants of sensor 2 calculated according to IEC 60751:

R<sub>0</sub>: \_\_\_\_\_ Ω    A: \_\_\_\_\_    B: \_\_\_\_\_

Markings:            Pass: \_\_\_\_\_    Fail: \_\_\_\_\_    Signature: \_\_\_\_\_

**Table 7: Performance tests. Maximum absolute error of each sensor of a temperature sensor pair. Single sensors are tested without pockets (Ref.: 9.2.2.2 in R 75-1 and 6.4.3.3 in R 75-2, IEC 60751)**

Sensor pair: Serial No. (flow): \_\_\_\_\_ Serial No. (return): \_\_\_\_\_

Temperature range specified by the supplier from \_\_\_\_ °C to \_\_\_\_ °C

Temperature difference for the pair specified by the supplier from \_\_\_\_ K to \_\_\_\_ K

Type of temperature sensors: Pt 100  Pt 500  Pt 1000  Pt 10000 Sensors are intended to be installed in pockets: Yes  No 

Sensor	Flow temperature °C	Return temperature °C	Maximum absolute error <sup>*)</sup> K	MPE K
Sensor 1 (flow)		---		± 2
Sensor 2 (return)	---			± 2

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

<sup>\*)</sup> *Note:* The “ideal” sensor curve (with constants of IEC 60751) shall be subtracted from the characteristic curve for the sensor (calculated constants are below Table 6a). The difference between characteristics shall be determined over the temperature range specified for the temperature sensor. The maximum difference in  $\Omega$  between characteristics at measured points of the temperature range shall be calculated as a difference in K. The maximum permissible difference between characteristics (MPE) is  $\pm 2$  K.

**Table 8a: Performance test. Maximum relative error of a temperature sensor pair. Sensors are tested without pockets (Ref.: 9.2.2.2 in R 75-1 and 6.4.3.3 in R 75-2)**

Sensor pair: Serial No. (flow): \_\_\_\_\_ Serial No. (return): \_\_\_\_\_

Temperature range specified by the supplier from \_\_\_\_ °C to \_\_\_\_ °C

Temperature difference for the pair specified by the supplier from \_\_\_\_ K to \_\_\_\_ K

Type of temperature sensors: Pt 100  Pt 500  Pt 1000  Pt 10000 Sensors are intended to be installed in pockets: Yes  No 

Used temperature levels for the test: \_\_\_\_\_ °C and \_\_\_\_\_ °C and \_\_\_\_\_ °C

Constants of sensor 1 calculated according to IEC 60751:

R<sub>0</sub>: \_\_\_\_\_ Ω A: \_\_\_\_\_ B: \_\_\_\_\_

Constants of sensor 2 calculated according to IEC 60751:

R<sub>0</sub>: \_\_\_\_\_ Ω A: \_\_\_\_\_ B: \_\_\_\_\_

(Calculated constants are below Table 6a.)

Flow temperature °C	Return temperature °C	Relative error %	MPE %
22	20	0.40	3.5
73	71	- 0.59	3.5
40	20	0.06	0.8
60	20	0.03	0.65
120	20	- 0.01	0.56

*Note to this Table with measurement results (all values are examples):*

The Table shows examples of the relative error calculated at different temperature combinations. This example shows that the maximum relative error (- 0.59 %) is found at the temperature combination of 73 °C/71 °C.

**Test result (summary)**

Flow temperature °C	Return temperature °C	Maximum relative error <sup>*)</sup> $E_{T_{max}}$ %	MPE %
73	71	- 0.59	3.5

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

<sup>\*)</sup> The calculation of the maximum relative error of the temperature sensor pair  $E_{T_{max}}$  can be performed as on the following page (recommended method):

**Calculation of the maximum relative error of the temperature sensor pair,  $E_{T_{\max}}$ :**

1) First calculate:

$$E_T = \frac{e_1 - e_2}{\Delta\theta} \cdot 100 \%$$

where:

$e_1, e_2$  are the absolute errors of single sensors in relation to the “ideal” sensor (IEC) at one temperature within the temperature range specified by the supplier (1 for the flow sensor, 2 for the return sensor);

$\Delta\theta$  is the temperature difference specified by the supplier ( $\theta_{\text{flow}} - \theta_{\text{return}}$ ) (it is recommended to start with  $\Delta\theta_{\text{min}}$ ).

The maximum values of the absolute errors of the single sensors tested without pockets are given in Table 7.

2) An auxiliary equation for the determination of  $E_{T_{\max}}$  is:

$$x = E_T / E_{t \text{ MPE}}$$

where:

$$E_{t \text{ MPE}} = \pm (0.5 + 3 \Delta\theta_{\text{min}} / \Delta\theta)$$

(see: OIML R 75-1, clause 9.2.2.2, maximum permissible error of the temperature sensor pair).

3) To obtain the maximum value of  $x$ , the calculation according to the equation in 1) above has to be repeated taking into account the whole temperature range and the whole temperature difference range specified by the supplier, separately in two ranges of return temperature  $\theta_{\text{return}}$ :

- a) for  $\theta_{\text{return}} \leq 80 \text{ }^\circ\text{C}$  in the whole range of temperature difference;
- b) for  $\theta_{\text{return}} > 80 \text{ }^\circ\text{C}$  only for temperature differences over 10 K.

4) The biggest value of  $x$  calculated according to 3) above is “the worst case”  $x_{\text{max}}$

5) The value of  $x_{\text{max}}$  shall be used for the calculation of the maximum value of the relative error  $E_T$  ( $E_{T_{\max}}$ ):

$$E_{T_{\max}} = x_{\text{max}} E_{t \text{ MPE}}$$

The combination of values of the flow temperature  $\theta_{\text{flow}}$  and the return temperature  $\theta_{\text{return}}$ , for which  $E_{T_{\max}}$  has appeared shall be determined.  $E_{T_{\max}}$  shall be within the limits of the MPE, observing the range of  $\Delta\theta$  (see: OIML R 75-1, clause 9.2.2.2).

**Table 8b: Performance test. Maximum relative error of a temperature sensor pair. Sensors are tested in pockets (Ref.: 9.2.2.2 in R 75-1 and 6.4.3.3 in R 75-2)**

This test is performed if the sensors are intended to be installed in pockets and if the maximum tolerated gap between the sensor and the pocket is more than 0.125 mm or the immersion depth of the pocket is less than 70 mm.

Sensor pair: Serial No. (flow): \_\_\_\_\_ Serial No. (return): \_\_\_\_\_

Temperature range specified by the supplier from \_\_\_\_\_ °C to \_\_\_\_\_ °C

Temperature difference for the pair specified by the supplier from \_\_\_\_\_ K to \_\_\_\_\_ K

Type of temperature sensors: Pt 100  Pt 500  Pt 1000  Pt 10000

Used temperature levels for the test: \_\_\_\_\_ °C and \_\_\_\_\_ °C and \_\_\_\_\_ °C

Constants of sensor 1 calculated according to IEC 60751:

R<sub>0</sub>: \_\_\_\_\_ Ω A: \_\_\_\_\_ B: \_\_\_\_\_

Constants of sensor 2 calculated according to IEC 60751:

R<sub>0</sub>: \_\_\_\_\_ Ω A: \_\_\_\_\_ B: \_\_\_\_\_

(Calculated constants are beneath the table 6b.)

**Test result (summary)**

Flow temperature °C	Return temperature °C	Maximum relative error <sup>*)</sup> %	Maximum relative error deviation without/in pockets <sup>**)</sup> %	MPE %	1/3 MPE %

<sup>\*)</sup> Calculations as in Table 8a

<sup>\*\*)</sup> The maximum relative error determined for the sensor pair tested in pockets shall be subtracted from the maximum relative error of the sensor pair determined for sensors tested without pockets. The maximum permissible deviation from the value determined without pockets is 1/3 MPE.

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**3.4 Combined sub-assemblies or complete instrument (Ref.: 6.4.4 in R 75-2)**

In the case of combined sub-assemblies or complete instruments the relevant tests as described in 3.1 for the flow sensor, 3.2 for the calculator and/or 3.3 for the temperature sensors shall be carried out.

#### 4 Dry heat (Ref.: 6.5 in R 75-2)

*Note:* In the case of combined sub-assemblies or complete instruments the relevant tests as described for the calculator and flow sensor shall be carried out.

##### Test results: Calculator

**Table 9:** Dry heat (Ref.: 6.5.1 and 5.3 in R 75-2)

Simulated flowrate (impulse signal): \_\_\_\_\_ m<sup>3</sup>/h

Test number	Test point return temperature °C	Temperature difference $\Delta\theta$ K			
		$\Delta\theta_{\min} =$		$\Delta\theta_{\text{RVM}} =$	
		Error %	MPE %	Error %	MPE %
1	$\theta_{\min} =$	$\Delta\theta_{\min} =$		$\Delta\theta_{\text{RVM}} =$	
		Error %	MPE %	Error %	MPE %
2	$\theta_{\text{RVM}} =$	$\Delta\theta_{\min} =$		$\Delta\theta_{\text{RVM}} =$	
		Error %	MPE %	Error %	MPE %

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

##### Test results: Flow sensor

**Table 10:** Dry heat (Ref.: 6.5.2 in R 75-2 and 5.3 in R 75-2)

Water temperature: \_\_\_\_\_ °C

Test number	Test point flowrate		Error %	MPE %
	Calculated m <sup>3</sup> /h	Actual m <sup>3</sup> /h		
1	(1 to 1.1) $q_i$			
2 *)	(0.7 to 0.75) $q_p$			

\*) This test shall only be carried out if  $q_p > 3.5$  m<sup>3</sup>/h

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_



## 5 Cold (Ref.: 6.6 in R 75-2)

*Note:* In the case of combined sub-assemblies or complete instruments the relevant tests as described for the calculator and flow sensor shall be carried out.

### Test results: Calculator

**Table 11:** Cold (Ref.: 6.6.1 in R 75-2)

Simulated flowrate (impulse signal): \_\_\_\_\_ m<sup>3</sup>/h

Test number	Test point return temperature °C	Temperature difference $\Delta\theta$ K			
		$\Delta\theta_{\min} =$		$\Delta\theta_{\text{RVM}} =$	
1	$\theta_{\min} =$	Error %	MPE %	Error %	MPE %
		2	$\theta_{\text{RVM}} =$	Error %	MPE %

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

### Test results: Flow sensor

**Table 12:** Cold (Ref.: 6.6.2 in R 75-2 and 5.3 in R 75-2)

Water temperature: \_\_\_\_\_ °C

Test number	Test point flowrate		Error %	MPE %
	Calculated m <sup>3</sup> /h	Actual m <sup>3</sup> /h		
1	(1 to 1.1) $q_i$			
2 *)	(0.7 to 0.75) $q_p$			

\*) This test shall only be carried out if  $q_p > 3.5$  m<sup>3</sup>/h

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

## 6 Variations in supply voltage and frequency (Ref.: 6.7 in R 75-2)

*Note:* In the case of combined sub-assemblies or complete instruments the relevant tests as described for the calculator and flow sensor shall be carried out.

### Test results: Calculator. Variation in supply voltage

**Table 13:** Supply mode a), mains operation with a single rated voltage  $U_{\text{nom}}$   
(Ref.: 6.7a and 5.3 in R 75-2)

$U_{\text{nom}}$  specified by the supplier: \_\_\_\_\_ V

$f_{\text{nom}}$  specified by the supplier: \_\_\_\_\_ Hz

$\theta_{\text{RVM}}$	$\Delta\theta_{\text{RVM}}$	Simulated flowrate	$U_{\text{max}} = 1.1 U_{\text{nom}}$	Error at $U_{\text{max}}$	$U_{\text{min}} = 0.85 U_{\text{nom}}$	Error at $U_{\text{min}}$	MPE
°C	K	m <sup>3</sup> /h	V	%	V	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

### Test results: Calculator. Variation in supply frequency

**Table 14:** Supply mode a), mains operation with variations of frequency if mains frequency is used for measuring purposes (Ref.: 6.7a and 5.3 in R 75-2)

$U_{\text{nom}}$  specified by the supplier: \_\_\_\_\_ V

$f_{\text{nom}}$  specified by the supplier: \_\_\_\_\_ Hz

$\theta_{\text{RVM}}$	$\Delta\theta_{\text{RVM}}$	Simulated flowrate	$f_{\text{max}} = 1.02 f_{\text{nom}}$	Error at $f_{\text{max}}$	$f_{\text{min}} = 0.98 f_{\text{nom}}$	Error at $f_{\text{min}}$	MPE
°C	K	m <sup>3</sup> /h	Hz	%	Hz	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Flow sensor. Variation in supply voltage****Table 15:** Supply mode a), mains operation with a single rated voltage  $U_{\text{nom}}$   
(Ref.: 6.7a and 5.3 in R 75-2) $U_{\text{nom}}$  specified by the supplier: \_\_\_\_\_ V $f_{\text{nom}}$  specified by the supplier: \_\_\_\_\_ Hz

Water temperature: \_\_\_\_\_ °C

Flowrate	$U_{\text{max}} = 1.1 U_{\text{nom}}$	Error at $U_{\text{max}}$	$U_{\text{min}} = 0.85 U_{\text{nom}}$	Error at $U_{\text{min}}$	MPE
m <sup>3</sup> /h	V	%	V	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Flow sensor. Variation in supply frequency****Table 16:** Supply mode a), mains operation with variations of frequency if mains frequency is used for measuring purposes (Ref.: 6.7a and 5.3 in R 75-2) $U_{\text{nom}}$  specified by the supplier: \_\_\_\_\_ V $f_{\text{nom}}$  specified by the supplier: \_\_\_\_\_ Hz

Water temperature: \_\_\_\_\_ °C

Flowrate	$f_{\text{max}} = 1.02 f_{\text{nom}}$	Error at $f_{\text{max}}$	$f_{\text{min}} = 0.98 f_{\text{nom}}$	Error at $f_{\text{min}}$	MPE
m <sup>3</sup> /h	Hz	%	Hz	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Calculator. Variation in supply voltage****Table 17:** Supply mode b), mains operation with a nominal range of voltage from  $U_{nom1}$  to  $U_{nom2}$  (Ref.: 6.7b and 5.3 in R 75-2) $U_{nom1}$  specified by the supplier: \_\_\_\_\_ V $U_{nom2}$  specified by the supplier: \_\_\_\_\_ V $f_{nom}$  specified by the supplier: \_\_\_\_\_ Hz

$\theta_{RVM}$	$\Delta\theta_{RVM}$	Simulated flowrate	$U_{max} = 1.1 U_{nom2}$	Error at $U_{max}$	$U_{min} = 0.85 U_{nom1}$	Error at $U_{min}$	MPE
°C	K	m <sup>3</sup> /h	V	%	V	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Calculator. Variation in supply frequency****Table 18:** Supply mode b), mains operation with variations of frequency if mains frequency is used for measuring purposes (Ref.: 6.7b and 5.3 in R 75-2) $U_{nom1}$  specified by the supplier: \_\_\_\_\_ V $U_{nom2}$  specified by the supplier: \_\_\_\_\_ V $U_{nom,calculated} = (U_{nom2} + U_{nom1})/2$ : \_\_\_\_\_ V $f_{nom}$  specified by the supplier: \_\_\_\_\_ Hz

$\theta_{RVM}$	$\Delta\theta_{RVM}$	Simulated flowrate	$f_{max} = 1.02 f_{nom}$	Error at $f_{max}$	$f_{min} = 0.98 f_{nom}$	Error at $f_{min}$	MPE
°C	K	m <sup>3</sup> /h	Hz	%	Hz	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Flow sensor. Variation in supply voltage****Table 19:** Supply mode b), mains operation with a nominal range of voltage from  $U_{nom1}$  to  $U_{nom2}$   
(Ref.: 6.7b and 5.3 in R 75-2) $U_{nom1}$  specified by the supplier: \_\_\_\_\_ V $U_{nom2}$  specified by the supplier: \_\_\_\_\_ V $f_{nom}$  specified by the supplier: \_\_\_\_\_ Hz

Water temperature: \_\_\_\_\_ °C

Flowrate	$U_{max} = 1.1 U_{nom2}$	Error at $U_{max}$	$U_{min} = 0.85 U_{nom1}$	Error at $U_{min}$	MPE
m <sup>3</sup> /h	V	%	V	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Flow sensor. Variation in supply frequency****Table 20:** Supply mode b), mains operation with variations of frequency if mains frequency is used for measuring purposes (Ref.: 6.7b and 5.3 in R 75-2) $U_{nom1}$  specified by the supplier: \_\_\_\_\_ V $U_{nom2}$  specified by the supplier: \_\_\_\_\_ V $U_{nom,calculated} = (U_{nom2} + U_{nom1})/2$ : \_\_\_\_\_ V $f_{nom}$  specified by the supplier: \_\_\_\_\_ Hz

Water temperature: \_\_\_\_\_ °C

Flowrate	$f_{max} = 1.02 f_{nom}$	Error at $f_{max}$	$f_{min} = 0.98 f_{nom}$	Error at $f_{min}$	MPE
m <sup>3</sup> /h	Hz	%	Hz	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Calculator. Variation in supply voltage****Table 21:** Supply mode c), external AC low voltage operation with a single rated voltage (Ref.: 6.7c and 5.3 in R 75-2) $U_{\text{nom}}$  specified by the supplier: \_\_\_\_\_ V $f_{\text{nom}}$  specified by the supplier: \_\_\_\_\_ Hz

$\theta_{\text{RVM}}$	$\Delta\theta_{\text{RVM}}$	Simulated flowrate	$U_{\text{max}} = 1.5 U_{\text{nom}}$	Error at $U_{\text{max}}$	$U_{\text{min}} = 0.5 U_{\text{nom}}$	Error at $U_{\text{min}}$	MPE
°C	K	m <sup>3</sup> /h	V	%	V	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Calculator. Variation in supply frequency****Table 22:** Supply mode c), external AC low voltage operation with variations of frequency if AC frequency is used for measuring purposes (Ref.: 6.7c and 5.3 in R 75-2) $U_{\text{nom}}$  specified by the supplier: \_\_\_\_\_ V $f_{\text{nom}}$  specified by the supplier: \_\_\_\_\_ Hz

$\theta_{\text{RVM}}$	$\Delta\theta_{\text{RVM}}$	Simulated flowrate	$f_{\text{max}} = 1.02 f_{\text{nom}}$	Error at $f_{\text{max}}$	$f_{\text{min}} = 0.98 f_{\text{nom}}$	Error at $f_{\text{min}}$	MPE
°C	K	m <sup>3</sup> /h	Hz	%	Hz	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Flow sensor. Variation in supply voltage****Table 23:** Supply mode c), external AC low voltage operation with a single rated voltage (Ref: 6.7c and 5.3 in R 75-2) $U_{\text{nom}}$  specified by the supplier: \_\_\_\_\_ V $f_{\text{nom}}$  specified by the supplier: \_\_\_\_\_ Hz

Water temperature: \_\_\_\_\_ °C

Flowrate	$U_{\text{max}} = 1.5 U_{\text{nom}}$	Error at $U_{\text{max}}$	$U_{\text{min}} = 0.5 U_{\text{nom}}$	Error at $U_{\text{min}}$	MPE
m <sup>3</sup> /h	V	%	V	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Flow sensor. Variation in supply frequency****Table 24:** Supply mode c), external AC low voltage operation with variations of frequency if AC frequency is used for measuring purposes (Ref.: 6.7c and 5.3 in R 75-2) $U_{\text{nom}}$  specified by the supplier: \_\_\_\_\_ V $f_{\text{nom}}$  specified by the supplier: \_\_\_\_\_ Hz

Water temperature: \_\_\_\_\_ °C

Flowrate	$f_{\text{max}} = 1.02 f_{\text{nom}}$	Error at $f_{\text{max}}$	$f_{\text{min}} = 0.98 f_{\text{nom}}$	Error at $f_{\text{min}}$	MPE
m <sup>3</sup> /h	Hz	%	Hz	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Calculator. Variation in DC supply voltage****Table 25:** Supply mode d), external DC low voltage operation with a single rated voltage  
(Ref.: 6.7d and 5.3 in R 75-2) $U_{\text{nom}}$  specified by the supplier: \_\_\_\_\_ V

$\theta_{\text{RVM}}$	$\Delta\theta_{\text{RVM}}$	Simulated flowrate	$U_{\text{max}} = 1.75 U_{\text{nom}}$	Error at $U_{\text{max}}$	$U_{\text{min}} = 0.5 U_{\text{nom}}$	Error at $U_{\text{min}}$	MPE
°C	K	m <sup>3</sup> /h	V	%	V	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Flow sensor. Variation in DC supply voltage****Table 26:** Supply mode d), external DC low voltage operation and having a single rated voltage  
(Ref.: 6.7d and 5.3 in R 75-2) $U_{\text{nom}}$  specified by the supplier: \_\_\_\_\_ V

Water temperature: \_\_\_\_\_ °C

Flowrate	$U_{\text{max}} = 1.75 U_{\text{nom}}$	Error at $U_{\text{max}}$	$U_{\text{min}} = 0.5 U_{\text{nom}}$	Error at $U_{\text{min}}$	MPE
m <sup>3</sup> /h	V	%	Hz	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_



**Test results: Calculator. Variation in battery supply voltage****Table 27: Supply mode e), operation with batteries (Ref.: 6.7e and 5.3 in R 75-2)** $U_{\max}$  specified by the supplier: \_\_\_\_\_ V $U_{\min}$  specified by the supplier: \_\_\_\_\_ V

$\theta_{RVM}$	$\Delta\theta_{RVM}$	Simulated flowrate	$U_{\max}$	Error at $U_{\max}$	$U_{\min}$	Error at $U_{\min}$	MPE
°C	K	m <sup>3</sup> /h	V	%	V	%	%

Markings: \_\_\_\_\_ Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Flow sensor. Variation in battery supply voltage****Table 28: Supply mode e), operation with batteries (Ref.: 6.7e and 5.3 in R 75-2)** $U_{\max}$  specified by the supplier: \_\_\_\_\_ V $U_{\min}$  specified by the supplier: \_\_\_\_\_ V

Water temperature: \_\_\_\_\_ °C

Flowrate	$U_{\max}$	Error at $U_{\max}$	$U_{\min}$	Error at $U_{\min}$	MPE
m <sup>3</sup> /h	V	%	Hz	%	%

Markings: \_\_\_\_\_ Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

## 7 Durability test (Ref.: 6.8 in R 75-2)

*Note:* According to 6.8.3 in R 75-2 in the case of combined sub-assemblies or complete instruments the relevant tests for each sub-assembly shall be carried out. One exception is the insulation resistance for temperature sensors when they are not a part of the heat meter or the sub-assemblies.

### Test results: Flow sensor

**Table 29: Performance test after basic test (Ref.: 6.8.1 in R 75-2)**

$$K = (q_s/q_i)^{1/4} = \underline{\hspace{2cm}}$$

Initial intrinsic error at RVM-conditions: \_\_\_\_\_ %

Test number	Test point flowrate m <sup>3</sup> /h		Temperature of liquid °C	Flow sensor output signal volume m <sup>3</sup>	Conventional true volume m <sup>3</sup>	Error of indication %	MPE %
	Calculated	Actual					
1	$q_1$						
2	$q_2$						
3	$q_3$						
4	$q_4$						
5	$q_5$						

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Flow sensor****Table 30: Performance test after additional test for long life sensors (Ref.: 6.8.1 in R 75-2)**

$$K = (q_s/q_i)^{1/4} = \underline{\hspace{2cm}}$$

Initial intrinsic error at RVM-conditions: \_\_\_\_\_ %

Test number	Test point flowrate m <sup>3</sup> /h		Temperature of liquid °C	Flow sensor output signal volume m <sup>3</sup>	Conventional true volume m <sup>3</sup>	Error of indication %	MPE %
	Calculated	Actual					
1	$q_1$						
2	$q_2$						
3	$q_3$						
4	$q_4$						
5	$q_5$						

Markings:                  Pass: \_\_\_\_\_          Fail: \_\_\_\_\_          Signature: \_\_\_\_\_

**Test results: Temperature sensor pair**

**Table 31a: Durability test. Sensor constants before and after test (Ref: 6.8.2 in R 75-2)**

Sensor 1: Serial No. (flow): \_\_\_\_\_ Sensor 2: Serial No. (return): \_\_\_\_\_

Temperature range specified by the supplier from \_\_\_\_ °C to \_\_\_\_ °C

Temperature difference for the pair specified by the supplier from \_\_\_\_ K to \_\_\_\_ K

Type of temperature sensors: Pt 100  Pt 500  Pt 1000  Pt 10000

Upper temperature of test: \_\_\_\_ °C Lower temperature of test: \_\_\_\_ °C

Immersion depth: \_\_\_\_ mm

<b>Measurements</b>								
Test temperature	Before test				After test (10 cycles)			
	Sensor 1 (flow)		Sensor 2 (return)		Sensor 1 (flow)		Sensor 2 (return)	
	Temp. °C	$R_{\text{measured}} \Omega$	Temp. °C	$R_{\text{measured}} \Omega$	Temp. °C	$R_{\text{measured}} \Omega$	Temp. °C	$R_{\text{measured}} \Omega$
$\theta_1$								
$\theta_2$								
$\theta_3$								
<b>Calculation of constants according to IEC 60751</b>								
IEC 60751	Before test <sup>*)</sup>		After test (10 cycles)		Unit			
	Sensor 1	Sensor 2	Sensor 1	Sensor 2				
$R_0$					$\Omega$			
A					$^{\circ}\text{C}^{-1}$			
B					$^{\circ}\text{C}^{-2}$			

<sup>\*)</sup> Calculated constants are below Table 6a.

Sensors are tested without pockets.

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Table 31b: Change of resistance corresponding to temperature (Ref: 6.8.2 in R 75-2, durability error)**

Sensor 1: Serial No. (flow): \_\_\_\_\_ Sensor 2: Serial No. (return): \_\_\_\_\_

Temperature range specified by the supplier from \_\_\_\_ °C to \_\_\_\_ °C

Temperature difference for the pair specified by the supplier from \_\_\_\_ K to \_\_\_\_ K

Type of temperature sensors: Pt 100  Pt 500  Pt 1000  Pt 10000 

Temperature sensors	Measured point of temperature range °C	Maximum change of resistance corresponding to temperature <sup>*)</sup> K	MPE K
Sensor 1 (flow)			±0.1
Sensor 2 (return)			±0.1

\*) The characteristic curve for the sensor before the test shall be subtracted from the characteristic curve for the sensor after the test. The difference between the characteristics before and after the test shall be determined over the temperature range specified for the temperature sensor. The maximum difference in  $\Omega$  between the characteristics at the measured points of the temperature range shall be calculated as a difference in K. The maximum permissible difference between the characteristics is  $\pm 0.1$  K.

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Temperature sensors****Table 32: Insulation resistance after durability test (Ref.: 6.8.2 in R 75-2)**

Temperature sensor, serial number	Insulation resistance at reference temperature M $\Omega$	Requirement: insulation resistance M $\Omega$	Insulation resistance at maximum temperature M $\Omega$	Requirement: insulation resistance M $\Omega$
	at positive polarity:	$\geq 100$	at positive polarity:	$\geq 10$
	at negative polarity:	$\geq 100$	at negative polarity:	$\geq 10$
	at positive polarity:	$\geq 100$	at positive polarity:	$\geq 10$
	at negative polarity:	$\geq 100$	at negative polarity:	$\geq 10$

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

## 8 Damp heat cyclic (Ref.: 6.9 in R 75-2)

*Note:*

In case of combined sub-assemblies or complete instrument the relevant tests as described for the calculator and flow sensor shall be carried out.

**Test results: Calculator**

**Table 33: Damp heat cyclic. Comparison: Initial intrinsic error, phase 1 and phase 2 (Ref.: 6.9 and 5.3 in R 75-2)**

Lower temperature: \_\_\_\_\_ °C  
 Upper temperature: \_\_\_\_\_ °C  
 Relative humidity: \_\_\_\_\_ %  
 Simulated flowrate: \_\_\_\_\_ m<sup>3</sup>/h  
 $\theta_{RVM}$ : \_\_\_\_\_ °C  
 $\Delta\theta_{RVM}$ : \_\_\_\_\_ K

Initial intrinsic error %	Intrinsic error after phase 1 %	Intrinsic error after phase 2 %	MPE %

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

*Note:* After phase 1 means during the second cycle, phase 2 means after recovery.

**Test results: Flow sensor**

**Table 34: Damp heat cyclic. Comparison: Initial intrinsic error, phase 1 and phase 2 (Ref.: 6.9 and 5.3 in R 75-2)**

Lower temperature: \_\_\_\_\_ °C  
 Upper temperature: \_\_\_\_\_ °C  
 Relative humidity: \_\_\_\_\_ %  
 Flowrate: \_\_\_\_\_ m<sup>3</sup>/h  
 Water temperature in flow sensor: \_\_\_\_\_ °C

Initial intrinsic error %	Intrinsic error after phase 1 %	Intrinsic error after phase 2 %	MPE %

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

*Note:* After phase 1 means during the second cycle, phase 2 means after recovery.

**Test results: Complete instrument**

**Table 35: Damp heat cyclic. Comparison: Initial intrinsic error, phase 1 and phase 2 (Ref.: 6.9 and 5.3 in R 75-2)**

Lower temperature: \_\_\_\_\_ °C  
 Upper temperature: \_\_\_\_\_ °C  
 Relative humidity: \_\_\_\_\_ %  
 Flowrate: \_\_\_\_\_ m<sup>3</sup>/h  
 Water temperature in flow sensor: \_\_\_\_\_ °C  
 $\theta_{RVM}$ : \_\_\_\_\_ °C  
 $\Delta\theta_{RVM}$ : \_\_\_\_\_ K

Initial intrinsic error %	Intrinsic error after phase 1 %	Intrinsic error after phase 2 %	MPE %

*Note:* After phase 1 means during the second cycle, phase 2 means after recovery.

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**9 Short time mains voltage reduction (Ref.: 6.10 in R 75-2)**

*Note:* In the case of combined sub-assemblies or complete instruments the relevant tests as described for the calculator and flow sensor shall be carried out.

**Test results: Calculator**

**Table 36: Short time mains voltage reduction. Comparison: Initial intrinsic error, after short time mains voltage reduction (Ref.: 6.10 and 5.3 in R 75-2)**

Simulated flowrate: \_\_\_\_\_ m<sup>3</sup>/h  
 $\theta_{RVM}$ : \_\_\_\_\_ °C  
 $\Delta\theta_{RVM}$ : \_\_\_\_\_ K

Initial intrinsic error %	Intrinsic error after test %	MPE %

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Flow sensor**

**Table 37:** Short time mains voltage reduction. Comparison: Initial intrinsic error, after short time voltage reduction (Ref: 6.10 and 5.3 in R 75-2)

Flowrate: \_\_\_\_\_ m<sup>3</sup>/h

Water temperature in flow sensor: \_\_\_\_\_ °C

Initial intrinsic error	Intrinsic error after test	MPE
%	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Complete instrument**

**Table 38:** Short time mains voltage reduction. Comparison: Initial intrinsic error, after short time mains voltage reduction (Ref.: 6.10 and 5.3 in R 75-2)

Flowrate: \_\_\_\_\_ m<sup>3</sup>/h

Water temperature in flow sensor: \_\_\_\_\_ °C

$\theta_{RVM}$ : \_\_\_\_\_ °C

$\Delta\theta_{RVM}$ : \_\_\_\_\_ K

Initial intrinsic error	Intrinsic error after test	MPE
%	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_



## 10 Electrical transients (Ref.: 6.11 in R 75-2)

*Note:* The electrical transient disturbance tests shall be carried out on fast transients and surge transients. In the case of combined sub-assemblies or complete instruments the relevant tests as described for the calculator and flow sensor shall be carried out. If the sub-assemblies or the combined sub-assemblies or complete instrument under test have a standardized data output(s), determination of intrinsic error before and after the test shall also be made using this data output(s).

### Test results: Calculator

**Table 39:** Transients, coupled into DC lines. Comparison: Initial intrinsic error, change of display/readings and error after test (Ref.: 6.11.1/6.11.2 and 5.3 in R 75-2)

Kind of transients: Fast transients (bursts)  Surge transients

Simulated flowrate: \_\_\_\_\_ m<sup>3</sup>/h

$\theta_{RVM}$ : \_\_\_\_\_ °C

$\Delta\theta_{RVM}$ : \_\_\_\_\_ K

Display information/readings have changed due to the exposure:

Yes  No  Figure: \_\_\_\_\_

Initial intrinsic error	Intrinsic error after test	MPE
%	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

### Test results: Flow sensor

**Table 40:** Transients coupled into DC lines. Comparison: Initial intrinsic error, change of display/readings and error after test (Ref.: 6.11.1/6.11.2 and 5.3 in R 75-2)

Kind of transients: Fast transients (bursts)  Surge transients

Flowrate: \_\_\_\_\_ m<sup>3</sup>/h

Water temperature in flow sensor: \_\_\_\_\_ °C

Display information/readings have changed due to the exposure:

Yes  No  Figure: \_\_\_\_\_

Initial intrinsic error	Intrinsic error after test	MPE
%	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Complete instrument**

**Table 41:** Transients coupled into DC lines. Comparison: Initial intrinsic error, change of display/readings and error after test (Ref.: 6.11.1/6.11.2 and 5.3 in R 75-2)

Kind of transients: Fast transients (bursts)  Surge transients

Flowrate: \_\_\_\_\_ m<sup>3</sup>/h

Water temperature in flow sensor: \_\_\_\_\_ °C

$\theta_{RVM}$ : \_\_\_\_\_ °C

$\Delta\theta_{RVM}$ : \_\_\_\_\_ K

Display information/readings have changed due to the exposure:

Yes  No  Figure: \_\_\_\_\_

Initial intrinsic error	Intrinsic error after test	MPE
%	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Calculator**

**Table 42:** Transients coupled into AC power lines. Comparison: Initial intrinsic error, change of display/readings and error after test (Ref.: 6.11.1/6.11.2 and 5.3 in R 75-2)

Kind of transients: Fast transients (bursts)  Surge transients

Simulated flowrate: \_\_\_\_\_ m<sup>3</sup>/h

$\theta_{RVM}$ : \_\_\_\_\_ °C

$\Delta\theta_{RVM}$ : \_\_\_\_\_ K

Display information/readings have changed due to the exposure:

Yes  No  Figure: \_\_\_\_\_

Initial intrinsic error	Intrinsic error after test	MPE
%	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Flow sensor**

**Table 43:** Transients coupled into AC power lines. Comparison: Initial intrinsic error, change of display/readings and error after test (Ref.: 6.11.1/6.11.2 and 5.3 in R 75-2)

Kind of transients: Fast transients (bursts)  Surge transients

Flowrate: \_\_\_\_\_ m<sup>3</sup>/h

Water temperature in flow sensor: \_\_\_\_\_ °C

Display information/readings have changed due to the exposure:

Yes  No  Figure: \_\_\_\_\_

Initial intrinsic error	Intrinsic error after test	MPE
%	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Complete instrument**

**Table 44:** Transients coupled into AC power lines. Comparison: Initial intrinsic error, change of display/readings and error after test (Ref.: 6.11.1/6.11.2 and 5.3 in R 75-2)

Kind of transients: Fast transients (bursts)  Surge transients

Flowrate: \_\_\_\_\_ m<sup>3</sup>/h

Water temperature in flow sensor: \_\_\_\_\_ °C

$\theta_{RVM}$ : \_\_\_\_\_ °C

$\Delta\theta_{RVM}$ : \_\_\_\_\_ K

Display information/readings have changed due to the exposure:

Yes  No  Figure: \_\_\_\_\_

Initial intrinsic error	Intrinsic error after test	MPE
%	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

## 11 Electromagnetic field (Ref.: 6.12 in R 75-2)

*Note:* In the case of combined sub-assemblies or complete instruments the relevant tests as described for the calculator and flow sensor shall be carried out. If the sub-assemblies or the combined sub-assemblies or complete instrument under test have a standardized data output(s), the intrinsic error determination and determination of the intrinsic error after the test shall also be made using this data output(s). The responses within three requests have to be carried out according to the protocol in accordance with IEC 60870-5-1 or IEC 61107, see note to 6.12 in R 75-2.

### Test results: Calculator

**Table 45:** Electromagnetic field (Ref.: 6.12 and 5.3 in R 75-2)

Test level: \_\_\_\_\_ V/m

Antenna polarization: Horizontal  Vertical

Dwell time: \_\_\_\_\_ s

Determination of intrinsic error: By display  By standardized data output

Protocol of standardized data output: \_\_\_\_\_

Simulated flowrate: \_\_\_\_\_ m<sup>3</sup>/h

$\theta_{RVM}$ : \_\_\_\_\_ °C

$\Delta\theta_{RVM}$ : \_\_\_\_\_ K

Carrier frequencies MHz	Transmitting antenna	Intrinsic error at test level %	MPE %
26	biconical		
40	biconical		
60	biconical		
80	biconical		
100	biconical		
120	biconical		
144	biconical		
150	biconical		
160	biconical		
180	biconical		
200	biconical		
250	log-periodic		
350	log-periodic		
400	log-periodic		
435	log-periodic		
500	log-periodic		
600	log-periodic		
700	log-periodic		
800	log-periodic		
934	log-periodic		
1000	log-periodic		

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Flow sensor**

**Table 46: Electromagnetic field (Ref.: 6.12 and 5.3 in R 75-2)**

Test level: \_\_\_\_ V/m

Antenna polarization: Horizontal  Vertical

Dwell time: \_\_\_\_ s

Determination of intrinsic error: By display  By standardized data output

Protocol of standardized data output: \_\_\_\_\_

Test with water flow: Yes  No

Flowrate: \_\_\_\_\_ m<sup>3</sup>/h

Water temperature in flow sensor: \_\_\_\_\_ °C

Carrier frequencies MHz	Transmitting antenna	Intrinsic error at test level %	MPE %
26	biconical		
40	biconical		
60	biconical		
80	biconical		
100	biconical		
120	biconical		
144	biconical		
150	biconical		
160	biconical		
180	biconical		
200	biconical		
250	log-periodic		
350	log-periodic		
400	log-periodic		
435	log-periodic		
500	log-periodic		
600	log-periodic		
700	log-periodic		
800	log-periodic		
934	log-periodic		
1000	log-periodic		

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Complete instrument****Table 47: Electromagnetic field (Ref: 6.12 and 5.3 in R 75-2)**

Test level: \_\_\_\_\_ V/m

Antenna polarization: Horizontal  Vertical 

Dwell time: \_\_\_\_\_ s

Determination of intrinsic error: By display  By standardized data output 

Protocol of standardized data output: \_\_\_\_\_

Test with water flow: Yes  No Flowrate: \_\_\_\_\_ m<sup>3</sup>/h

Water temperature in flow sensor: \_\_\_\_\_ °C

 $\theta_{RVM}$ : \_\_\_\_\_ °C $\Delta\theta_{RVM}$ : \_\_\_\_\_ K

Carrier frequencies MHz	Transmitting antenna	Intrinsic error at test level %	MPE %
26	biconical		
40	biconical		
60	biconical		
80	biconical		
100	biconical		
120	biconical		
144	biconical		
150	biconical		
160	biconical		
180	biconical		
200	biconical		
250	log-periodic		
350	log-periodic		
400	log-periodic		
435	log-periodic		
500	log-periodic		
600	log-periodic		
700	log-periodic		
800	log-periodic		
934	log-periodic		
1000	log-periodic		

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

## 12 Electrostatic discharge (Ref.: 6.13 in R 75-2)

*Note:* In the case of combined sub-assemblies or complete instruments the relevant tests as described for the calculator and flow sensor shall be carried out. If the sub-assemblies or the combined sub-assemblies or complete instrument under test have a standardized data output(s), the intrinsic error determination and determination of intrinsic error after the test shall also be made using this data output(s).

### Test results: Calculator

**Table 48:** Electrostatic discharge. Comparison: Initial intrinsic error, change of display/readings and error after test (Ref.: 6.13 and 5.3 in R 75-2)

Simulated flowrate: \_\_\_\_\_ m<sup>3</sup>/h

$\theta_{RVM}$ : \_\_\_\_\_ °C

$\Delta\theta_{RVM}$ : \_\_\_\_\_ K

Display information/readings have changed due to the exposure:

Yes  No  Figure: \_\_\_\_\_

Initial intrinsic error	Intrinsic error after test	MPE
%	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

### Test results: Flow sensor

**Table 49:** Electrostatic discharge. Comparison: Initial intrinsic error, change of display/readings and error after test (Ref.: 6.13 and 5.3 in R 75-2)

Flowrate: \_\_\_\_\_ m<sup>3</sup>/h

Water temperature in flow sensor: \_\_\_\_\_ °C

Display information/readings have changed due to the exposure:

Yes  No  Figure: \_\_\_\_\_

Initial intrinsic error	Intrinsic error after test	MPE
%	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Complete instrument**

**Table 50: Electrostatic discharge. Comparison: Initial intrinsic error, change of display/readings and error after test (Ref.: 6.13 and 5.3 in R 75-2)**

Flowrate: \_\_\_\_\_ m<sup>3</sup>/h

Water temperature in flow sensor: \_\_\_\_\_ °C

$\theta_{RVM}$ : \_\_\_\_\_ °C

$\Delta\theta_{RVM}$ : \_\_\_\_\_ K

Display information/readings have changed due to the exposure:

Yes  No  Figure: \_\_\_\_\_

Initial intrinsic error	Intrinsic error after test	MPE
%	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**13 Static magnetic field (Fraud protection, Ref.: 6.14 in R 75-2)**

*Note:* In the case of combined sub-assemblies or complete instruments the relevant tests as described for the calculator and flow sensor shall be carried out.

**Test results: Calculator**

**Table 51: Static magnetic field. Comparison: Initial intrinsic error, change of display information and error during test (Ref.: 6.14 and 5.3 in R 75-2)**

Simulated flowrate: \_\_\_\_\_ m<sup>3</sup>/h

$\theta_{RVM}$ : \_\_\_\_\_ °C

$\Delta\theta_{RVM}$ : \_\_\_\_\_ K

Display information/readings have changed due to the exposure:

Yes  No  Figure: \_\_\_\_\_

Initial intrinsic error	Intrinsic error after test	MPE
%	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_



**Test results: Flow sensor**

**Table 52:** Static magnetic field. Comparison: Initial intrinsic error, change of display information and error during test (Ref.: 6.14 and 5.3 in R 75-2)

Flowrate: \_\_\_\_\_ m<sup>3</sup>/h

Water temperature in flow sensor: \_\_\_\_\_ °C

Display information/readings have changed due to the exposure:

Yes  No  Figure: \_\_\_\_\_

Initial intrinsic error	Intrinsic error after test	MPE
%	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Complete instrument**

**Table 53:** Static magnetic field. Comparison: Initial intrinsic error, change of display information and error during test (Ref.: 6.14 and 5.3 in R 75-2)

Flowrate: \_\_\_\_\_ m<sup>3</sup>/h

Water temperature in flow sensor: \_\_\_\_\_ °C

$\theta_{RVM}$ : \_\_\_\_\_ °C

$\Delta\theta_{RVM}$ : \_\_\_\_\_ K

Display information/readings have changed due to the exposure:

Yes  No  Figure: \_\_\_\_\_

Initial intrinsic error	Intrinsic error after test	MPE
%	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

## 14 Electromagnetic field at mains frequency (Ref.: 6.15 in R 75-2)

*Note:* In the case of combined sub-assemblies or complete instruments the relevant tests as described for the calculator and flow sensor shall be carried out.

### Test results: Calculator

**Table 54:** Electromagnetic field at mains frequency. Comparison: Initial intrinsic error, change of display information and error after test (Ref.: 6.15 and 5.3 in R 75-2)

Simulated flowrate: \_\_\_\_\_ m<sup>3</sup>/h

$\theta_{RVM}$ : \_\_\_\_\_ °C

$\Delta\theta_{RVM}$ : \_\_\_\_\_ K

Display information/readings have changed due to the exposure:

Yes  No  Figure: \_\_\_\_\_

Initial intrinsic error	Intrinsic error after test	MPE
%	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

### Test results: Flow sensor

**Table 55:** Electromagnetic field at mains frequency. Comparison: Initial intrinsic error, change of display information and error after test (Ref.: 6.15 and 5.3 in R 75-2)

Flowrate: \_\_\_\_\_ m<sup>3</sup>/h

Water temperature in flow sensor: \_\_\_\_\_ °C

Display information/readings have changed due to the exposure:

Yes  No  Figure: \_\_\_\_\_

Initial intrinsic error	Intrinsic error after test	MPE
%	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Complete instrument****Table 56: Electromagnetic field at mains frequency. Comparison: Initial intrinsic error, change of display information and error after test (Ref.: 6.15 and 5.3 in R 75-2)**Flowrate: \_\_\_\_\_ m<sup>3</sup>/h

Water temperature in flow sensor: \_\_\_\_\_ °C

 $\theta_{RVM}$ : \_\_\_\_\_ °C $\Delta\theta_{RVM}$ : \_\_\_\_\_ K

Display information/readings have changed due to the exposure:

Yes  No  Figure: \_\_\_\_\_

Initial intrinsic error	Intrinsic error after test	MPE
%	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**15 Internal pressure (Ref.: 6.16 in R 75-2)**

*Note:* In the case of combined sub-assemblies or complete instruments the relevant tests as described for the calculator and flow sensor shall be carried out.

**Test results: Flow sensor****Table 57: Internal pressure. Comparison: Initial intrinsic error before and intrinsic error after internal pressure test at RVM conditions (Ref.: 6.16 in R 75-2)**Flowrate: \_\_\_\_\_ m<sup>3</sup>/h

Water temperature in flow sensor: \_\_\_\_\_ °C

Initial intrinsic error	Intrinsic error after test	MPE
%	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Test results: Complete instrument****Table 58: Internal pressure. Comparison: Initial intrinsic error after internal pressure test (Ref.: 6.16 in R 75-2)**Flowrate: \_\_\_\_\_ m<sup>3</sup>/h

Water temperature in flow sensor: \_\_\_\_\_ °C

 $\theta_{RVM}$ : \_\_\_\_\_ °C $\Delta\theta_{RVM}$ : \_\_\_\_\_ K

Initial intrinsic error	Intrinsic error after test	MPE
%	%	%

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**16 Pressure loss (Ref.: 6.17 in R 75-2)****Test results: Flow sensor. Complete instrument****Table 59: Pressure loss (Ref.: 6.17 in R 75-2 and 6.7 in R 49-2)**

Flowrate set to (0.9 to 1.0) $q_p$ m <sup>3</sup> /h	Temperature set to $(50 \pm 5)$ °C °C	Pressure loss		Requirement: Max. pressure loss	
		bar	Pa	bar	Pa
				0.25 <sup>*)</sup>	$2.5 \times 10^4$ <sup>*)</sup>

\*) Except where the flow sensor/heat meter includes a flow controller or also acts as a pressure-reducing device.

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

## II INITIAL VERIFICATION REPORT (CERTIFICATE)

### 1 Information concerning the EUT verified

#### 1.1 General information

**Testing authority**

Name: .....

Address: .....

Accredited laboratory:     Yes     No

Accreditation No.: ..... by Company: .....

Test No.: .....

Declaration of expanded uncertainty of test equipment No.: .....

Contact information: .....

Date of beginning and end of tests: .....

Name(s) of test engineer(s): .....

**Applicant/manufacturer information**

Application No.: .....

Application date: .....

Model designation: .....

Applicant: .....

Address: .....

.....

Manufacturer: .....

Address: .....

.....

Representative (name, telephone): .....

.....

#### 1.2 Information concerning the EUT

Instrument category:

Complete instrument  Documentation No.: \_\_\_\_\_ Serial No.: \_\_\_\_\_ Year of manufacture: \_\_\_\_\_

Calculator  Documentation No.: \_\_\_\_\_ Serial No.: \_\_\_\_\_ Year of manufacture: \_\_\_\_\_

Flow sensor  Documentation No.: \_\_\_\_\_ Serial No.: \_\_\_\_\_ Year of manufacture: \_\_\_\_\_

Temperature sensor pair  Documentation No.: \_\_\_\_\_ Serial No.: \_\_\_\_\_ Year of manufacture: \_\_\_\_\_

Combined Sub-Assemblies  Documentation No.: \_\_\_\_\_ Serial No.: \_\_\_\_\_ Year of manufacture: \_\_\_\_\_

Type approval number of the EUT: .....

Short description of the principle of measurement (measuring method): .....

List of documents provided by the manufacturer: .....

All values in this table are taken from documentation pages .....

Additional qualifying information supplied: Yes  No  Remarks: .....

Completeness and correctness of instruction manual, marking, assembly instruction, installation instruction, security sealing plan, initial functionality check and operation instruction submitted for verification (requirements of sections 11 and 12 in R 75-1 and 8.2 in R 75-2):

Pass  Fail  Remarks: .....

### 1.2.1 Complete instrument specifications

Accuracy class: Class 1  Class 2  Class 3

Heat conveying liquid: Water  Water-glycol solution  Mixing: \_\_\_/\_\_\_

Environmental class: A  B  C

Type of temperature sensors: Pt 100  Pt 500  Pt 1000  Pt 10000  other

Indication if shielding: Yes  No

Flow sensor to be operated: In the flow  In the return

Limits of temperature:  $\theta_{\min} = \text{___ } ^\circ\text{C}$   $\theta_{\max} = \text{___ } ^\circ\text{C}$

Limits of temperature difference:  $\Delta\theta_{\min} = \text{___ } \text{K}$   $\Delta\theta_{\max} = \text{___ } \text{K}$

Display unit options: GJ  MJ  kWh

Maximum value of thermal power ( $P_s$ ): \_\_\_ MW

Output signal for testing: Type: \_\_\_\_\_ Level: \_\_\_ V

Corresponding factor for test output: \_\_\_\_\_ Wh/pulse

Display unit options for testing: MJ  kWh  Wh

Dynamic behavior (circumstances of temperature measurement and integration): .....

Other functions in addition to heat indication: .....

#### For the flow sensor:

Physical dimensions (length, thread/flange specification): .....

Installation conditions (e.g. straight sections of piping): .....

Upstream/downstream, vertical/horizontal position: .....

Maximum admissible working pressure (PN-class): \_\_\_\_\_

Maximum pressure loss at  $q_p$ : \_\_\_ bar \_\_\_ Pa

Temperature sensor installed: Yes  No

Filter installed: Yes  No Straightener installed: Yes  No Range of electrical conductivity of water (if necessary): \_\_\_  $\mu\text{S}/\text{cm}$  to \_\_\_  $\mu\text{S}/\text{cm}$ 

Length of the connection cable to the electrodes (if the electronic part is separated from the sensor head): \_\_\_\_\_ m

Response time (for fast response meters): \_\_\_\_\_ s

Limits of flowrate:  $q_p =$  \_\_\_\_\_  $\text{m}^3/\text{h}$   $q_i =$  \_\_\_\_\_  $\text{m}^3/\text{h}$   $q_s =$  \_\_\_\_\_  $\text{m}^3/\text{h}$ Low flow threshold value: \_\_\_\_\_  $\text{m}^3/\text{h}$ Limits of temperature (heat conveying liquid):  $\theta_{\min} =$  \_\_\_\_\_  $^{\circ}\text{C}$   $\theta_{\max} =$  \_\_\_\_\_  $^{\circ}\text{C}$ 

Nominal meter factor: \_\_\_\_\_ litres/pulse

Output signal for testing: Type: \_\_\_\_\_ Level: \_\_\_\_\_ V

Corresponding factor for test output: \_\_\_\_\_ litres/pulse

**1.2.2 Calculator specifications**Type of temperature sensors: Pt 100  Pt 500  Pt 1000  Pt 10000  other (or declaration of sensor coefficients:  $R_0:$  \_\_\_\_\_  $\Omega$  A: \_\_\_\_\_ B: \_\_\_\_\_)Wiring of sensors: 4-wire  3-wire  2-wire Indication if shielding: Yes  No Flow sensor to be operated: In the flow  In the return Environmental class: A  B  C Heat conveying liquid: Water  Water-glycol solution  Mixing: \_\_\_/\_\_\_Limits of temperature:  $\theta_{\min} =$  \_\_\_\_\_  $^{\circ}\text{C}$   $\theta_{\max} =$  \_\_\_\_\_  $^{\circ}\text{C}$ Limits of temperature difference:  $\Delta\theta_{\min} =$  \_\_\_\_\_ K  $\Delta\theta_{\max} =$  \_\_\_\_\_ KDisplay unit options: GJ  MJ  kWh Maximum value of thermal power ( $P_s$ ): \_\_\_\_\_ MW

RMS value of temperature sensor current: \_\_\_\_\_ mA

Required input signal from the flow sensor:

Nominal meter factor: \_\_\_\_\_ litres/pulse (or corresponding factor for test input)

Input signal for testing: Type: \_\_\_\_\_ Level: \_\_\_\_\_ V

Maximum frequency of flow sensor signal: For testing: \_\_\_\_\_ Hz In normal use: \_\_\_\_\_ Hz

Output signal for testing: Type: \_\_\_\_\_ Level: \_\_\_\_\_ V

Corresponding factor for test output: \_\_\_\_\_ Wh/pulse

Display unit options for testing: MJ  kWh  Wh 

Dynamic behavior (circumstances of temperature measurement and integration): .....

Other functions in addition to heat indication: .....

**1.2.3 Flow sensor specifications**Accuracy class: Class 1  Class 2  Class 3 Heat conveying liquid: Water  Water-glycol solution  Mixing: \_\_\_/\_\_\_Environmental class: A  B  C 

Physical dimensions (length, thread/flange specification): .....

Installation conditions (e.g. straight sections of piping): .....

Upstream/downstream, vertical/horizontal position: .....

Maximum admissible working pressure (PN-class): \_\_\_\_\_

Maximum pressure loss at  $q_p$ : \_\_\_ bar \_\_\_ PaTemperature sensor installed: Yes  No Filter installed: Yes  No Straightener installed: Yes  No Limits of temperature (heat conveying liquid):  $\theta_{\min} =$  \_\_\_\_\_ °C  $\theta_{\max} =$  \_\_\_\_\_ °CRange of electrical conductivity of water (if necessary): \_\_\_  $\mu\text{S}/\text{cm}$  to \_\_\_  $\mu\text{S}/\text{cm}$ 

Length of the connection cable to the electrodes (if the electronic part is separated from the sensor head): \_\_\_\_\_ m

Response time (for fast response meters): \_\_\_\_\_ s

Limits of flowrate:  $q_p =$  \_\_\_\_\_  $\text{m}^3/\text{h}$   $q_i =$  \_\_\_\_\_  $\text{m}^3/\text{h}$   $q_s =$  \_\_\_\_\_  $\text{m}^3/\text{h}$ Low flow threshold value: \_\_\_\_\_  $\text{m}^3/\text{h}$ 

Nominal meter factor: \_\_\_\_\_ litres/pulse

Corresponding factor for test output: \_\_\_\_\_ litres/pulse

Output signal for testing: Type: \_\_\_\_\_ Level: \_\_\_\_\_ V



**1.2.4 Temperature sensor pair specifications**Type of temperature sensors: Pt 100  Pt 500  Pt 1000  Pt 10000  other (or declaration of sensor coefficients:  $R_0$ : \_\_\_\_\_  $\Omega$  A: \_\_\_\_\_ B: \_\_\_\_\_)Wiring of sensors: 4-wire  3-wire  2-wire Total resistance of a 2-cable wire: \_\_\_\_\_  $\Omega$ /m Cross section of a wire: \_\_\_\_\_  $\text{mm}^2$ 

Maximum length of a cable for: Pt 100 \_\_\_\_\_ m, Pt 500 \_\_\_\_\_ m, Pt 1000 \_\_\_\_\_ m, other \_\_\_\_\_ m

Indication if shielding: Yes  No Limits of temperature:  $\theta_{\min} =$  \_\_\_\_\_  $^{\circ}\text{C}$   $\theta_{\max} =$  \_\_\_\_\_  $^{\circ}\text{C}$ Limits of temperature difference:  $\Delta\theta_{\min} =$  \_\_\_\_\_ K  $\Delta\theta_{\max} =$  \_\_\_\_\_ KInstallation requirements (pocket mounting): Yes  No 

Physical dimensions: Length: \_\_\_\_\_ mm Diameter: \_\_\_\_\_ mm

Minimum immersion depth: \_\_\_\_\_ mm

Maximum liquid velocity for sensors over 200 mm length: \_\_\_\_\_ m/s

Maximum admissible working pressure for direct mounted sensors (PN-class): \_\_\_\_\_

 $\tau_{0,5}$  response time: \_\_\_\_\_ sIdentification of flow and return temperature sensors (if needed): At the flow  At the return 

Maximum RMS value of sensor current: \_\_\_\_\_ mA

**1.2.5 Combined sub-assemblies specifications (calculator + temperature sensor pair)**Type of temperature sensors: Pt 100  Pt 500  Pt 1000  Pt 10000  other (or declaration of sensor coefficients:  $R_0$ : \_\_\_\_\_  $\Omega$  A: \_\_\_\_\_ B: \_\_\_\_\_)Wiring of sensors: 4-wire  3-wire  2-wire Indication if shielding: Yes  No Environmental class: A  B  C Heat conveying liquid: Water  Water-glycol solution  Mixing: \_\_\_\_/\_\_\_\_Flow sensor to be operated: In the flow  In the return Limits of temperature:  $\theta_{\min} =$  \_\_\_\_\_  $^{\circ}\text{C}$   $\theta_{\max} =$  \_\_\_\_\_  $^{\circ}\text{C}$ Limits of temperature difference:  $\Delta\theta_{\min} =$  \_\_\_\_\_ K  $\Delta\theta_{\max} =$  \_\_\_\_\_ KInstallation requirements (pocket mounting): Yes  No 

Physical dimensions: Length: \_\_\_\_\_ mm Diameter: \_\_\_\_\_ mm

Minimum immersion depth: \_\_\_\_\_ mm

Maximum liquid velocity for sensors over 200 mm length: \_\_\_\_\_ m/s

Maximum admissible working pressure for direct mounted sensors (PN-class): \_\_\_\_\_

 $\tau_{0,5}$  response time: \_\_\_\_\_ s

Maximum value of thermal power ( $P_s$ ): \_\_\_\_ MW

Output signal for testing: Type: \_\_\_\_\_ Level: \_\_\_\_ V

Corresponding factor for test output: \_\_\_\_\_ Wh/pulse

Display unit options for testing: MJ  kWh  Wh

Required input signal from the flow sensor:

Input signal for testing: Type: \_\_\_\_\_ Level: \_\_\_\_ V

Nominal meter factor: \_\_\_\_ litres/pulse (or corresponding factor for test input)

Maximum frequency of flow sensor signal: For testing: \_\_\_\_ Hz In normal use: \_\_\_\_ Hz

Dynamic behavior (circumstances of temperature measurement and integration): .....

Other functions in addition to heat indication: .....

Correctness of identification of flow and return temperature sensors: Yes  No

### 1.2.6 Combined sub-assemblies specifications (calculator + flow sensor)

Accuracy class: Class 1  Class 2  Class 3

Heat conveying liquid: Water  Water-glycol solution  Mixing: \_\_\_\_/\_\_\_\_

Environmental class: A  B  C

Type of temperature sensors: Pt 100  Pt 500  Pt 1000  Pt 10000

Wiring of sensors: 4-wire  3-wire  2-wire

Indication if shielding: Yes  No

Flow sensor to be operated: In the flow  In the return

Limits of temperature:  $\theta_{\min} =$  \_\_\_\_ °C  $\theta_{\max} =$  \_\_\_\_ °C

Limits of temperature difference:  $\Delta\theta_{\min} =$  \_\_\_\_ K  $\Delta\theta_{\max} =$  \_\_\_\_ K

Display unit options (MJ, kWh): \_\_\_\_\_

Maximum value of thermal power ( $P_s$ ): \_\_\_\_ MW

Output signal for testing: Type: \_\_\_\_\_ Level: \_\_\_\_ V

Corresponding factor for test output: \_\_\_\_\_ Wh/pulse

Display unit options for testing: MJ  kWh  Wh

Dynamic behavior (circumstances of temperature measurement and integration): .....

Other functions in addition to heat indication: .....

For the flow sensor:

Physical dimensions (length, thread/flange specification): .....

Installation conditions (e.g. straight sections of piping): .....

Upstream/downstream, vertical/horizontal position: .....

Maximum admissible working pressure (PN-class): \_\_\_\_\_

Maximum pressure loss at  $q_p$ : \_\_\_\_\_ bar \_\_\_\_\_ PaTemperature sensor installed: Yes  No Filter installed: Yes  No Straightener installed: Yes  No Range of electrical conductivity of water (if necessary): \_\_\_\_\_  $\mu\text{S}/\text{cm}$  to \_\_\_\_\_  $\mu\text{S}/\text{cm}$ 

Length of the connection cable to the electrodes (if the electronic part is separated from the sensor head): \_\_\_\_\_ m

Response time (for fast response meters): \_\_\_\_\_ s

Limits of flowrate:  $q_p =$  \_\_\_\_\_  $\text{m}^3/\text{h}$   $q_i =$  \_\_\_\_\_  $\text{m}^3/\text{h}$   $q_s =$  \_\_\_\_\_  $\text{m}^3/\text{h}$ Low flow threshold value: \_\_\_\_\_  $\text{m}^3/\text{h}$ Limits of temperature (heat conveying liquid):  $\theta_{\min} =$  \_\_\_\_\_  $^{\circ}\text{C}$   $\theta_{\max} =$  \_\_\_\_\_  $^{\circ}\text{C}$ 

Nominal meter factor: \_\_\_\_\_ litres/pulse

Corresponding factor for test output: \_\_\_\_\_ litres/pulse

Output signal for testing: Type: \_\_\_\_\_ Level: \_\_\_\_\_ V

---

### 1.3 Rated operating conditions

#### Complete instrument, (combined) sub-assemblies

	Environmental class			Remarks
	A <input type="checkbox"/>	B <input type="checkbox"/>	C <input type="checkbox"/>	
Ambient temperature °C	+ 5 to + 55	- 25 to + 55	+ 5 to + 55	
Relative humidity %	< 93			
Mains supply voltage V	$U_{\text{nom}}$ (+ 10 %/- 15 %)			Frequency used for measurement purpose: Yes <input type="checkbox"/> No <input type="checkbox"/>
Mains frequency Hz	$f_{\text{nom}}$ ( $\pm 2$ %)			
External low voltage V ( $< 50$ V)	AC <input type="checkbox"/>	$U_{\text{nom}}$ (+ 50 %/- 50 %)		Frequency used for measurement purpose: Yes <input type="checkbox"/> No <input type="checkbox"/>
	DC <input type="checkbox"/>	$U_{\text{nom}}$ (+ 75 %/- 50 %)		
Battery voltage V	Voltage in service under normal conditions			Type, lifetime

#### General information concerning ambient test conditions

Test No.: .....

Application No.: .....

Ambient temperature: \_\_\_\_\_ °C    Relative humidity: \_\_\_\_\_ %

Barometric pressure: \_\_\_\_\_ kPa

## 2 Initial verification tests (Ref.: 7 in R 75-2)

### 2.1 Summary of the verification tests

*Note for combined instruments:* According to 7.5 in R 75-2 the flow sensor, the temperature sensor pair and the calculator shall be tested separately, in accordance with 7.1 to 7.3 in R 75-2.

Temperature sensor pair  <i>Serial No.</i>  _____	Flow sensor  <i>Serial No.</i>  _____	Calculator  <i>Serial No.</i>  _____	Combined sub-assemblies		Complete instrument  <i>Serial No.</i>  _____
			Calculator + temp. sensor pair <i>Serial No.</i>  _____	Calculator + flow sensor <i>Serial No.</i>  _____	
Pass <input type="checkbox"/>	Pass <input type="checkbox"/>	Pass <input type="checkbox"/>	Pass <input type="checkbox"/>	Pass <input type="checkbox"/>	Pass <input type="checkbox"/>
Fail <input type="checkbox"/>	Fail <input type="checkbox"/>	Fail <input type="checkbox"/>	Fail <input type="checkbox"/>	Fail <input type="checkbox"/>	Fail <input type="checkbox"/>

### 2.2 Results of verification tests

#### 2.2.1 Flow sensor (Ref.: 7.1 in R 75-2)

**Table 1: Verification test**

Electrical conductivity of water (if necessary): \_\_\_\_  $\mu\text{S/cm}$

Remarks (e.g. straight inlet/outlet pipes, etc.): .....

Test No.	Test point flow rate  $\text{m}^3/\text{h}$		Water temperature  $^{\circ}\text{C}$		Flow sensor output sign. volume $\text{m}^3$	Conventional true volume $\text{m}^3$	Error  %	MPE  %
	Calculated	Actual	Level	Measured				
1	$q_i \leq q \leq 1.1 q_i$		$(50 \pm 5)$					
2	$q_i \leq q \leq 1.1 q_i$		$(50 \pm 5)$					
3	$q_i \leq q \leq 1.1 q_i$		$(50 \pm 5)$					
4	$0.1 q_p \leq q \leq 0.11 q_p$		$(50 \pm 5)$					
5	$0.1 q_p \leq q \leq 0.11 q_p$		$(50 \pm 5)$					
6	$0.1 q_p \leq q \leq 0.11 q_p$		$(50 \pm 5)$					
7	$0.9 q_p \leq q \leq 1.0 q_p$		$(50 \pm 5)$					
8	$0.9 q_p \leq q \leq 1.0 q_p$		$(50 \pm 5)$					
9	$0.9 q_p \leq q \leq 1.0 q_p$		$(50 \pm 5)$					

*Note:* The verification may be carried out with cold water in accordance with the procedure laid down in the type approval certificate.

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**2.2.2 Temperature sensor pair (Ref.: 7.2 in R 75-2)****Table 2a: Verification test, temperature sensor pair, calculations of constants for each of the temperature sensors, resistance equation of IEC 60751**

Sensor pair serial No.: \_\_\_\_\_

Temperature range specified by the supplier from \_\_\_ °C to \_\_\_ °C

Temperature difference for the pair specified by the supplier from \_\_\_ K to \_\_\_ K

Type of temperature sensors: Pt 100  Pt 500  Pt 1000  Pt 10000 

Test point No.	For $\theta_{\min}$	Test temperature range °C		Measured resistance $\Omega$	
		Level *)	Measured	Sensor 1 (flow)	Sensor 2 (return)
1	< 20 °C	$\theta_{\min}$ to $(\theta_{\min} + 10)$			
	$\geq 20$ °C	35 to 45			
2	all $\theta_{\min}$	75 to 85			
3	all $\theta_{\min}$	$(\theta_{\max} - 30)$ to $\theta_{\max}$			

Sensors are tested without pockets in the same temperature bath.

\*) If specified in the type approval certificate, variations in the temperature ranges and the number of temperature points are permissible. The immersion depth of the temperature sensors shall not be less than their minimum immersion depth. The immersion depth of short temperature sensors should not be less than the total length plus 50 % of the thread respectively the mounting (recommended).

Constants of sensor 1 calculated according to IEC 60751:

R<sub>0</sub>: \_\_\_\_\_  $\Omega$     A: \_\_\_\_\_    B: \_\_\_\_\_

Constants of sensor 2 calculated according to IEC 60751:

R<sub>0</sub>: \_\_\_\_\_  $\Omega$     A: \_\_\_\_\_    B: \_\_\_\_\_

Markings:            Pass: \_\_\_\_\_    Fail: \_\_\_\_\_    Signature: \_\_\_\_\_

**Table 2b: Verification test, temperature sensor pair, maximum absolute error of each single temperature sensor of a pair**

Sensor pair serial No.: \_\_\_\_\_

Temperature range specified by the supplier from \_\_\_ °C to \_\_\_ °C

Temperature difference for the pair specified by the supplier from \_\_\_ K to \_\_\_ K

Type of temperature sensors: Pt 100  Pt 500  Pt 1000  Pt 10000 Sensors are intended to be installed in pockets: Yes  No 

Sensor	Flow temperature °C	Return temperature °C	Maximum absolute error <sup>*)</sup> K	MPE K
Sensor 1 (flow)		---		± 2
Sensor 2 (return)	---			± 2

\*) The “ideal” sensor curve (with constants of IEC 60751) shall be subtracted from the characteristic curve for the sensor (calculated constants are given below Table 2a). The difference between the characteristics shall be determined over the temperature range specified for the temperature sensor. The maximum difference in  $\Omega$  between the characteristics at the measured points of the temperature range shall be calculated as a difference in K. The maximum permissible difference between the characteristics (MPE) is  $\pm 2$  K.

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Table 2c: Verification test, temperature sensor pair, maximum relative error of a pair**

Sensor pair serial No.: \_\_\_\_\_

Temperature range specified by the supplier from \_\_\_ °C to \_\_\_ °C

Temperature difference for the pair specified by the supplier from \_\_\_ K to \_\_\_ K

Type of temperature sensors: Pt 100  Pt 500  Pt 1000  Pt 10000 

Flow temperature °C	Return temperature °C	Maximum relative error <sup>*)</sup> %	MPE %

\*) Calculations as in Table 8a (the maximum values of the absolute errors of the single sensors are given in Table 2b).

Markings: Pass: \_\_\_\_\_ Fail: \_\_\_\_\_ Signature: \_\_\_\_\_

**Table 2d: Insulation resistance between terminal and sheath**

Temperature sensor, serial number	Insulation resistance under ambient conditions MΩ	Requirement: Insulation resistance MΩ
	at positive polarity:	≥ 100
	at negative polarity:	≥ 100
	at positive polarity:	≥ 100
	at negative polarity:	≥ 100

Markings:                      Pass: \_\_\_\_\_      Fail: \_\_\_\_\_      Signature: \_\_\_\_\_

### 2.2.3 Calculator (Ref.: 7.3 in R 75-2)

**Table 3: Verification test**

Simulated flowrate: \_\_\_\_\_ l/h

Test No.	Return temperature *) °C	Temperature difference $\Delta\theta$ K		Error %	MPE %
		Level	Simulated		
1	50	$\Delta\theta_{\min} \leq \Delta\theta \leq 1.2 \Delta\theta_{\min}$			
2	50	$\Delta\theta_{\min} \leq \Delta\theta \leq 1.2 \Delta\theta_{\min}$			
3	50	$\Delta\theta_{\min} \leq \Delta\theta \leq 1.2 \Delta\theta_{\min}$			
1	50	10 K $\leq \Delta\theta \leq$ 20 K			
2	50	10 K $\leq \Delta\theta \leq$ 20 K			
3	50	10 K $\leq \Delta\theta \leq$ 20 K			
1	50	$\Delta\theta_{\max} - 5 \text{ K} \leq \Delta\theta \leq \Delta\theta_{\max}$			
2	50	$\Delta\theta_{\max} - 5 \text{ K} \leq \Delta\theta \leq \Delta\theta_{\max}$			
3	50	$\Delta\theta_{\max} - 5 \text{ K} \leq \Delta\theta \leq \Delta\theta_{\max}$			

\*) Values in the table are examples. The return temperature shall be in the temperature range between 40 °C and 70 °C, if  $\theta_{\max}$  is not exceeded.

Test of meter's indication: Pass \_\_\_\_\_      Fail \_\_\_\_\_

Markings:                      Pass: \_\_\_\_\_      Fail: \_\_\_\_\_      Signature: \_\_\_\_\_



**2.2.4 Subassembly of the calculator and temperature sensor pair (Ref.: 7.4 in R 75-2)***Notes:*

- (1) If the calculator and temperature sensor pair are tested as an inseparable sub-assembly, tests shall be done in accordance with 17.3 with the temperature sensor pair immersed in two temperature-regulated baths.
- (2) The sub-assembly of the calculator and temperature sensor pair shall be tested using the temperature ranges of 17.2 and the temperature difference ranges of 17.3.

Additionally a final test is necessary, with the temperature sensor pair immersed in two temperature-regulated baths (see the following table No. 63).

**Table 4: Additional test, sensor pair is immersed in temperature baths**

Simulated flowrate: \_\_\_\_\_ l/h

Test No.	Return temperature *) °C	Temperature difference $\Delta\theta$ K		Error %	MPE %
		Level	Measured		
1	50	$3 \leq \Delta\theta \leq 4$			
2	50	$3 \leq \Delta\theta \leq 4$			
3	50	$3 \leq \Delta\theta \leq 4$			

\*) Values in the table are examples. The return temperature shall be in the temperature range between 40 °C and 70 °C, if  $\theta_{\max}$  is not exceeded.

Markings:                      Pass: \_\_\_\_\_      Fail: \_\_\_\_\_      Signature: \_\_\_\_\_

**2.2.5 Combined instrument (Ref.: 7.5 in R 75-2)**

The flow sensor, the temperature sensor pair and the calculator shall be tested separately; see 2.2.1, 2.2.2 and 2.2.3.

## 2.2.6 Complete instrument (Ref.: 7.6 in R 75-2)

**Table 5: Verification test**

Test No.	Test point				Error %	MPE %
	Temperature difference $\Delta\theta$ K		Flowrate $q$ m <sup>3</sup> /h			
	Level	Measured	Level	Measured		
1	$\Delta\theta_{\min} \leq \Delta\theta \leq 1.2 \Delta\theta_{\min}$		$0.9 q_p \leq q \leq q_p$			
2	$\Delta\theta_{\min} \leq \Delta\theta \leq 1.2 \Delta\theta_{\min}$		$0.9 q_p \leq q \leq q_p$			
3	$\Delta\theta_{\min} \leq \Delta\theta \leq 1.2 \Delta\theta_{\min}$		$0.9 q_p \leq q \leq q_p$			
1	$10 \text{ K} \leq \Delta\theta \leq 20 \text{ K}$		$0.2q_p \leq q \leq 0.22q_p$			
2	$10 \text{ K} \leq \Delta\theta \leq 20 \text{ K}$		$0.2q_p \leq q \leq 0.22q_p$			
3	$10 \text{ K} \leq \Delta\theta \leq 20 \text{ K}$		$0.2q_p \leq q \leq 0.22q_p$			
1	$\Delta\theta_{\max} - 5 \text{ K} \leq \Delta\theta \leq \Delta\theta_{\max}$		$q_i \leq q \leq 1.1 q_i$			
2	$\Delta\theta_{\max} - 5 \text{ K} \leq \Delta\theta \leq \Delta\theta_{\max}$		$q_i \leq q \leq 1.1 q_i$			
3	$\Delta\theta_{\max} - 5 \text{ K} \leq \Delta\theta \leq \Delta\theta_{\max}$		$q_i \leq q \leq 1.1 q_i$			

Markings:                      Pass: \_\_\_\_\_                      Fail: \_\_\_\_\_                      Signature: \_\_\_\_\_