
Discontinuous totalizing automatic weighing
instruments (totalizing hopper weighers)

Part 2: Test report format

Instruments de pesage totalisateurs discontinus à fonctionnement automatique
(peseuses totalisatrices à trémie)

Partie 2: Format du rapport d'essai



Contents

Foreword	4
Introduction	5
Type evaluation report	6
Explanatory notes	6
General information concerning the type	8
Identification of the instrument	10
Test equipment	12
Configuration for test	13
Summary of type evaluation	14
1 Zero-setting device	16
2 Warm-up time	18
3 Stability of equilibrium for static weighing	19
4 Influence factors	20
4.1 Static temperatures	20
4.2 Temperature effect on no-load indication	30
4.3 Damp heat, steady state (non-condensing)	31
4.4 Mains power voltage variations test	37
5 Disturbances	39
5.1 AC mains voltage dips and short interruptions	39
5.2 Bursts (transients) on mains power lines and on signal and communication lines	41
5.3 Electrical surges on mains power lines and on I/O signal and communication lines	46
5.4 Electrostatic discharge	51
5.5 Immunity to electromagnetic fields	57
5.6 Electrical transient conduction for instruments powered by road vehicle batteries	64
6 Span stability	68
7 Material tests	74
7.1 Material testing (separate verification method)	74
7.2 Material testing (integral verification method)	76
8 Examination of the construction of the instrument	82
9 Checklist	83

Foreword

The International Organization of Legal Metrology (OIML) is a worldwide, intergovernmental organization whose primary aim is to harmonize the regulations and metrological controls applied by the national metrological services, or related organizations, of its Member States. The main categories of OIML publications are:

- **International Recommendations (OIML R)**, which are model regulations that establish the metrological characteristics, required of certain measuring instruments and which specify methods and equipment for checking their conformity. OIML Member States shall implement these Recommendations to the greatest possible extent;
- **International Documents (OIML D)**, which are informative in nature and which are intended to harmonize and improve work in the field of legal metrology;
- **International Guides (OIML G)**, which are also informative in nature and which are intended to give guidelines for the application of certain requirements to legal metrology; and
- **International Basic Publications (OIML B)**, which define the operating rules of the various OIML structures and systems.

OIML Draft Recommendations, Documents and Guides are developed by Technical Committees or Subcommittees which comprise representatives from the Member States. Certain international and regional institutions also participate on a consultation basis. Cooperative agreements have been established between the OIML and certain institutions, such as ISO and the IEC, with the objective of avoiding contradictory requirements. Consequently, manufacturers and users of measuring instruments, test laboratories, etc. may simultaneously apply OIML publications and those of other institutions.

International Recommendations, Documents, Guides and Basic Publications are published in English (E) and translated into French (F) and are subject to periodic revision.

Additionally, the OIML publishes or participates in the publication of **Vocabularies (OIML V)** and periodically commissions legal metrology experts to write **Expert Reports (OIML E)**. Expert Reports are intended to provide information and advice, and are written solely from the viewpoint of their author, without the involvement of a Technical Committee or Subcommittee, nor that of the CIML. Thus, they do not necessarily represent the views of the OIML.

This publication – reference OIML R 107-2, Edition 2007 – was developed by Technical Subcommittee TC 9/SC 2. It was approved for final publication by the International Committee of Legal Metrology in 2007 and supersedes the previous edition dated 1997.

OIML Publications may be downloaded from the OIML web site in the form of PDF files. Additional information on OIML Publications may be obtained from the Organization's headquarters:

Bureau International de Métrologie Légale
11, rue Turgot - 75009 Paris - France
Telephone: +33 (0)1 48 78 12 82
Fax: +33 (0)1 42 82 17 27
E-mail: biml@oiml.org
Internet: www.oiml.org

Introduction

This “Test report format” aims at presenting, in a standardized format, the results of the various tests and examinations to which a type of a totalizing automatic weighing instrument shall be submitted with a view to its approval.

The test report format consists of two parts, a “checklist” and the “test report” itself.

The checklist is a summary of the examinations carried out on the instrument. It includes the conclusions of the results of the test performed, experimental or visual checks based on the requirements of Part 1. The words or condensed sentences aim at reminding the examiner of the requirements in OIML R 107-1 without reproducing them.

The test report is a record of the results of the tests carried out on the instrument. The “test report” forms have been produced based on the tests detailed in OIML R 107-1:2007.

All metrology services or laboratories evaluating types of totalizing automatic weighing instruments according to R 107 or to national or regional regulations based on this OIML Recommendation are strongly advised to use this test report format, directly or after translation into a language other than English or French. Its direct use in English or in French, or in both languages, is even more strongly recommended whenever test results may be transmitted by the country performing these tests to the approving authorities of another country, under bi- or multilateral cooperation agreements. In the framework of the *OIML Certificate System for Measuring Instruments*, use of this test report format is mandatory.

The “information concerning the test equipment used for type evaluation” shall cover all test equipment which has been used in determining the test results given in a report. The information may be a short list containing only essential data (name, type, reference number for purpose of traceability). For example:

- Verification standards (accuracy, or accuracy class, and no.);
- Simulator for testing of modules (name, type, traceability and no.);
- Climatic test and static temperature chamber (name, type and no.);
- Electrical tests, bursts (name of the instrument, type and no.);
- Description of the procedure of field calibration for the test of immunity to radiated electromagnetic fields.

Note concerning the numbering of the following pages:

In addition to a sequential numbering: “R 107-2 page ...” at the bottom of the pages of this publication, a special place is left at the top of each page (starting with the following page) for numbering the pages of reports established following this model; in particular, some tests (e.g. metrological performance tests) shall be repeated several times, each test being reported individually on a separate page following the relevant format; in the same way, a multiple range instrument shall be tested separately for each range and a separate form (including the general information form) shall be filled out for each range. For a given report, it is advisable to complete the sequential numbering of each page by the indication of the total number of pages of the report.

**DISCONTINUOUS TOTALIZING AUTOMATIC WEIGHING INSTRUMENTS
(TOTALIZING HOPPER WEIGHERS)**

Type evaluation report

Explanatory notes

The name(s) or symbol(s) of the unit(s) used to express test results shall be specified in each form.

For each test, the “summary of type evaluation” and the “checklist” shall be completed according to this example:

	Passed	Failed
When the instrument has passed the test:	X	
When the instrument has failed the test:		X
When the test is not applicable:	–	–

The white spaces in boxes in the headings of the report should always be filled according to the following example:

	At start	At end	
Temp.:	20.5	21.1	°C
Rel. h.:			%
Date:	2006-01-29	2006-01-30	yyyy-mm-dd
Time:	16:00:05	16:30:25	hh:mm:ss
Bar pres.:			hPa

“Date” in the test report refers to the date on which the test was performed.

In the disturbance tests, faults greater than d are acceptable provided that they are detected and acted upon, or that they result from circumstances such that these faults shall not be considered as significant; an appropriate explanation shall be given in the column “Yes (remarks)”.

Section numbers in brackets refer to the corresponding subclauses of R 107-1:2007.

Symbol	Meaning
I	Indication
I_n	n th indication
L	Load
ΔL	Additional load to next changeover point
P	$I + \frac{1}{2}d - \Delta L =$ Indication prior to rounding (digital indication)
E	$I - L$ or $P - L =$ Error
$E\%$	$(P - L)/L \%$
E_0	Error at zero load
d	Actual scale interval
d_t	Totalization scale interval
p_i	Fraction of the MPE applicable to a module of the instrument which is examined separately
mpe	Maximum permissible error
EUT	Equipment under test
sf	Significant fault
Max	Maximum capacity of the weighing instrument
Min	Minimum capacity of the weighing instrument
T	Tare capacity
T	Indication of the totalization device
U_{nom}	Nominal voltage value marked on the instrument
U_{max}	Highest value of a voltage range marked on the instrument
U_{min}	Lowest value of a voltage range marked on the instrument
v_{min}	Minimum operating speed
v_{max}	Maximum operating speed
e.m.f.	Electromotive force
I/O	Input/output ports
RF	Radio frequency
V/m	Volts per metre
kV	kilovolt
DC	Direct current
AC	Alternating current
MHz	Megahertz
Σ_{min}	Minimum totalized load

General information concerning the type

Application no.: _____ Manufacturer: _____
 Type designation: _____ Applicant: _____
 Instrument category: _____

Testing on: Complete instrument Module ¹
 Accuracy class 0.2 0.5 1 2
 Min = Σ_{\min} =
 Max =
 T+ = T- = d = d_t =
 U_{nom} = V U_{min} = V U_{max} = V f = Hz Battery, U = V

Zero-setting device:

- Non-automatic
 Semi-automatic
 Automatic zero-setting
 Initial zero-setting
 Zero-tracking

Initial zero-setting range: % of Max Temperature range: °C

Printer: Built in Connected Not present but connectable No connection

¹ The test equipment (simulator or part of a complete instrument) connected to the module shall be defined in the test form(s) used.

Instrument submitted:	_____	Load sensor:	_____
Identification no.:	_____	Manufacturer:	_____
Software version:	_____	Type:	_____
Connected equipment:	_____	Capacity:	_____
	_____	Number:	_____
Interfaces (number, nature):	_____	Classification symbol:	_____
	_____	Remarks:	_____
	_____		_____
Evaluation period:	_____		_____
Date of report:	_____		_____
Observer:	_____		_____

Use this space to indicate additional remarks and/or information: other connected equipment, interfaces and load cells, choice of the manufacturer regarding protection against disturbances, etc.

Identification of the instrument

Application no.: _____ Type designation: _____
 Identification no.: _____ Manufacturer: _____
 Software version: _____ Report date: _____

Manufacturing documentation

(Record as necessary to identify the equipment under test)

System or module name	Drawing number or software reference	Issue level	Serial no.

Simulator documentation

System or module name	Drawing number or software reference	Issue level	Serial no.

Simulator function (summary)

(Simulator description and drawings, block diagram etc should be attached to the report if available.)

Description or other information pertaining to identification of the instrument:
(attach photograph here if available)

Test equipment

Application no.: _____ Type designation: _____
 Report date: _____ Manufacturer: _____

List all test equipment used in this report (including descriptions of the reference vehicles used for testing)

Equipment name	Manufacturer	Type no.	Serial no.	Used for (test references)

Configuration for test

Application no.: _____

Type designation: _____

Report date: _____

Manufacturer: _____

Use this space for additional information relating to equipment configuration, interfaces, data rates, load cells EMC protection options etc., for the instrument and/or simulator.

Summary of type evaluation

Application no.: _____

Type designation: _____

Report date: _____

Manufacturer: _____

	TESTS	Report page	Passed	Failed	Remarks
1	Zero-setting				
2	Warm-up time test				
3	Stability of equilibrium				
4	Influence factors				
4.1	Static temperatures				
4.2	Temperature effect on no load indication				
4.3	Damp heat, steady state				
4.4	Voltage variation tests				
5	Disturbances				
5.1	AC mains short-time power reductions				
5.2.1	Electrical bursts on mains voltage supply lines				
5.2.2	Electrical bursts on I/O circuits and communication lines				
5.3.1	Surges on AC mains voltage lines				
5.3.2	Surges on I/O signal and communication lines (if any)				
5.4.1	Electrostatic discharges on direct application				
5.4.2	Electrostatic discharges on indirect application (contact discharges only)				
5.5.1	Immunity to radiated electromagnetic fields				
5.5.2	Immunity to conducted radio-frequency fields				
5.6.1	Electrical transient conduction along supply lines of 12 V or 24 V road vehicle batteries				
5.6.2	Electrical transient conduction via lines other supply lines 12 V or 24 V road vehicle batteries				
6	Span stability				
7	Material tests:				
7.1	Separate verification method				
7.2	Integral verification method				
	EXAMINATIONS				
8	Examination of the construction				
9	Checklist				

Use this page to detail remarks from the summary of the type evaluation.

1 Zero-setting device (3.8, A.5.4)

Application no.: _____
 Type designation: _____
 Observer: _____
 Control scale interval, d : _____
 Resolution during test: _____
 (smaller than d)

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

1.1 Modes of zero-setting (A.5.4.1)

Mode of zero-setting	Present
Non-automatic	
Semi-automatic	
Automatic operation	

1.2 Range of zero-setting (3.8.2, A.5.4.2)

1.2.1 Initial zero-setting range (A.5.4.2.1)

Positive range, L_p		Negative range, L_n		Zero setting range, $(L_p + L_n)$	% of Max load

1.2.2 Zero-setting range (A.5.4.2.3)

Weight added	Zero Yes/no	Zero setting range	% of Max load

1.3 Accuracy of zero-setting (A.5.4.3)

$$E = I + \frac{1}{2}d - \Delta L$$

$$E = I - L \text{ or } P - L = \text{Error}$$

Zero-setting mode:	Add. load, ΔL	$E = I + \frac{1}{2}d - \Delta L$	E/d

Passed

Failed

Remarks:

1.4 Zero offset interlock (3.8.3, A.6.8)

Method of zero-setting:

Non-automatic

Semi-automatic

Automatic operation

Positive offset:

Load applied after zeroing:		
Automatic operation	Inhibited	
	Not inhibited	

Negative offset:

Load removed after zeroing:		
Automatic operation	Inhibited	
	Not inhibited	

Passed

Failed

Remarks:

2 Warm-up time (4.2.5, A.5.3)

Application no.: _____
 Type designation: _____
 Observer: _____
 Control scale interval, d : _____
 Resolution during test: _____
 (smaller than d)

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

Duration of disconnection before test: _____ hours

Automatic zero-setting device is:

Non-existent Not in operation Out of working range In operation²

$$E = I + \frac{1}{2} d - \Delta L - L$$

E_0 = error calculated prior to each measurement at zero or near zero (unloaded)

E_L = error calculated at load (loaded)

	Time*	Load, L	Indication, I	Add. load, ΔL	Error	$E_L - E_0$
Unloaded	0 min				$E_{01} =$	
Loaded					$E_L =$	
Unloaded	5 min				$E_0 =$	
Loaded					$E_L =$	
Unloaded	15 min				$E_0 =$	
Loaded					$E_L =$	
Unloaded	30 min				$E_0 =$	
Loaded					$E_L =$	

* Counted from the moment an indication has first appeared.

	Error	MPE	R 107-1 clause
Check if:	a) Initial zero-setting error, E_{01}	$\leq 0.25 d_t$	
	b) Maximum value of error unloaded, E_0	$\leq 0.25 d_t$	A.5.4
	c) Maximum value of zero variation, $E_0 - E_{01}$	$\leq 0.25 d_t \times p_i$	
	d) Maximum value of error loaded, $E_L - E_0$	$\leq 0.25 d_t \times p_i$	

Passed Failed

Remarks:

² In operation only if zero operates as part of every automatic weighing cycle

3 Stability of equilibrium for static weighing (3.2.10, A.6.1)

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval, <i>d</i> : _____ Resolution during test: _____ (smaller than <i>d</i>)	<table border="1" style="border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;"></th> <th style="width: 15%;">At start</th> <th style="width: 15%;">At end</th> <th style="width: 10%;"></th> </tr> </thead> <tbody> <tr> <td>Temp.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>°C</td> </tr> <tr> <td>Rel. h.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>%</td> </tr> <tr> <td>Date:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>yyyy-mm-dd</td> </tr> <tr> <td>Time:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>hh:mm:ss</td> </tr> <tr> <td>Bar. pres.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>hPa</td> </tr> </tbody> </table>		At start	At end		Temp.:			°C	Rel. h.:			%	Date:			yyyy-mm-dd	Time:			hh:mm:ss	Bar. pres.:			hPa
	At start	At end																							
Temp.:			°C																						
Rel. h.:			%																						
Date:			yyyy-mm-dd																						
Time:			hh:mm:ss																						
Bar. pres.:			hPa																						

In the case of printing or data storage:

Load =

Printing or data storage			
Number	First recorded or printed value after manual disturbance and command	Reading during 5 seconds after print-out or storage	
		Minimum	Maximum
1			
2			
3			
4			
5			

Check separately for each of the five tests if only two adjacent figures appear, one being the printed value.

In the case of zero-setting:

$$E = I + \frac{1}{2} d - \Delta L - L = \text{zero or near zero}$$

Zero-setting				
Number	Load, <i>L</i>	Indication, <i>I</i>	Add. load, ΔL	Error, <i>E</i>
1				
2				
3				
4				
5				

Check the accuracy according to A.5.4.3 for zero-setting.

Passed Failed

Remarks:

4 Influence factors (2.7, A.7.3)

4.1 Static temperatures (2.7.1.1, A.7.3.1)

4.1.1 Reference of 20 °C

Application no.:	_____	Temp.:	At start	At end	°C
Type designation:	_____	Rel. h.:			%
Observer:	_____	Date:			yyyy-mm-dd
Control scale interval, <i>d</i> :	_____	Time:			hh:mm:ss
Resolution during test: (smaller than <i>d</i>)	_____	Bar. pres.:			hPa

Automatic zero-setting device is:

Non-existent
 Not in operation
 Out of working range
 In operation

$E = I + \frac{1}{2} d - \Delta L - L$, $E_c = E - E_0$ with E_0 = error calculated at or near zero*

Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Load, <i>L</i>	Indication, <i>I</i>		Add. load, ΔL		Error		Corrected error, E_c		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
*					*				

Result sheet B

Used in conjunction with result sheet A to record the retained totalization

Totalization indication		
At start of test	At end of test	Max deviation observed (except for non-recordable transients)

Result sheet C

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Static load	Calculated change in totalization, T_c	Totalization before adding load, T_b	Totalization after adding load, T_a	Indicated change in totalization, $T_i = T_a - T_b$	Error, $T_c - T_i$

Passed

Failed

Remarks:

4.1.2 Static temperatures, specified high of: °C

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$E = I + \frac{1}{2} d - \Delta L - L,$ $E_c = E - E_0$ with E_0 = error calculated at or near zero*

Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Load, L	Indication, I		Add. load, ΔL		Error		Corrected error, E_c		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
*					*				

Result sheet B

Used in conjunction with result sheet A to record the retained totalization

Totalization indication		
At start of test	At end of test	Max deviation observed (except for non-recordable transients)

Result sheet C

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Static Load	Calculated change in totalization, T_c	Totalization before adding load, T_b	Totalization after adding load, T_a	Indicated change in totalization, $T_i = T_a - T_b$	Error, $T_c - T_i$

Passed

Failed

Remarks:

4.1.3 Static temperatures, specified low of: °C

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$E = I + \frac{1}{2} d - \Delta L - L,$ $E_c = E - E_0$ with E_0 = error calculated at or near zero*

Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Load, L	Indication, I		Add. load, ΔL		Error		Corrected error, E_c		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
*					*				

Result sheet B

Used in conjunction with result sheet A to record the retained totalization

Totalization indication		
At start of test	At end of test	Max deviation observed (except for non-recordable transients)

Result sheet C

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Static load	Calculated change in totalization, T_c	Totalization before adding load, T_b	Totalization after adding load, T_a	Indicated change in totalization, $T_i = T_a - T_b$	Error, $T_c - T_i$

Passed

Failed

Remarks:

4.1.4 Static temperatures, 5 °C (if applicable)

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$E = I + \frac{1}{2} d - \Delta L - L,$ $E_c = E - E_0$ with E_0 = error calculated at or near zero*

Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Load, <i>L</i>	Indication, <i>I</i>		Add. load, ΔL		Error		Corrected error, E_c		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
*					*				

Result sheet B

Used in conjunction with result sheet A to record the retained totalization

Totalization indication		
At start of test	At end of test	Max deviation observed (except for non-recordable transients)

Result sheet C

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Static load	Calculated change in totalization, T_c	Totalization before adding load, T_b	Totalization after adding load, T_a	Indicated change in totalization, $T_i = T_a - T_b$	Error, $T_c - T_i$

Passed

Failed

Remarks:

4.1.5 Static temperatures, reference of 20 °C

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$E = I + \frac{1}{2} d - \Delta L - L,$ $E_c = E - E_0$ with E_0 = error calculated at or near zero*

Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Load, <i>L</i>	Indication, <i>I</i>		Add. load, ΔL		Error		Corrected error, E_c		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
*					*				

Result sheet B

Used in conjunction with result sheet A to record the retained totalization

Totalization indication		
At start of test	At end of test	Max deviation observed (except for non-recordable transients)

Result sheet C

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Static load	Calculated change in totalization, T_c	Totalization before adding load, T_b	Totalization after adding load, T_a	Indicated change in totalization, $T_i = T_a - T_b$	Error, $T_c - T_i$

Passed

Failed

Remarks:

4.2 Temperature effect on no-load indication (2.7.1.2, A.7.3.2)

Application no.: _____

Type designation: _____

Observer: _____

Control scale interval, d : _____

Totalization scale interval, d_t : _____

Automatic zero-setting device is:

Non-existent Not in operation Out of working range In operation

$P = I + \frac{1}{2}d - \Delta L$

Report page ³	Date	Time	Temp (°C)	Zero indication, I	Add. load, ΔL	P	ΔP	Δ Temp	Zero-change per °C

ΔP = difference of P for two consecutive tests at different temperatures

Δ Temp = difference of temperature for two consecutive tests at different temperatures

Check if the zero-change per 5 °C is smaller than d .

Passed Failed

Remarks:

³ Give the report page of the relevant weighing test where weighing tests and temperature effect on no-load indication test are conducted together.

4.3 Damp heat, steady state (non-condensing) (4.2.3, A.7.3.3)

4.3.1 Reference temperature of 20 °C at 50 % humidity

Application no.:	Temp.:	At start	After 3 h	At end	°C
Type designation:	Rel. h.:				%
Observer:	Date:				yyyy-mm-dd
Scale interval, d :	Time:				hh:mm:ss
Totalization scale interval, d_t :	Bar. pres.:				hPa

Automatic zero-setting device is:

Non-existent
 Not in operation
 Out of working range
 In operation

$E = I + \frac{1}{2} d - \Delta L - L$, $E_c = E - E_0$ with E_0 = error calculated at or near zero*

Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Load, L	Indication, I		Add. load, ΔL		Error		Corrected error, E_c		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
*					*				

Result sheet B

Used in conjunction with result sheet A to record the retained totalization

Totalization indication		
At start of test	At end of test	Max deviation observed (except for non-recordable transients)

Result sheet C

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Static load	Calculated change in totalization, T_c	Totalization before adding load, T_b	Totalization after adding load, T_a	Indicated change in totalization, $T_i = T_a - T_b$	Error, $T_c - T_i$

Passed

Failed

Remarks:

4.3.2 Damp heat, steady state, upper limit temperature of:°C and 85 % humidity

	At start	After 3 h	At end	
Temp.:				°C
Rel. h.:				%
Date:				yyyy-mm-dd
Time:				hh:mm:ss
Bar. pres.:				hPa

$E = I + \frac{1}{2} d - \Delta L - L,$ $E_c = E - E_0$ with E_0 = error calculated at or near zero*

Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Load, <i>L</i>	Indication, <i>I</i>		Add. load, ΔL		Error		Corrected error, E_c		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
*					*				

Result sheet B

Used in conjunction with result sheet A to record the retained totalization

Totalization indication		
At start of test	At end of test	Max deviation observed (except for non-recordable transients)

Result sheet C

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Static load	Calculated change in totalization, T_c	Totalization before adding load, T_b	Totalization after adding load, T_a	Indicated change in totalization, $T_i = T_a - T_b$	Error, $T_c - T_i$

Passed

Failed

Remarks:

4.3.3 Damp heat, steady state, reference temperature of 20 °C and 50 % humidity

	At start	After 3 h	At end	
Temp.:				°C
Rel. h.:				%
Date:				yyyy-mm-dd
Time:				hh:mm:ss
Bar. pres.:				hPa

$E = I + \frac{1}{2} d - \Delta L - L,$ $E_c = E - E_0$ with E_0 = error calculated at or near zero*

Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Load, <i>L</i>	Indication, <i>I</i>		Add. load, ΔL		Error		Corrected error, E_c		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
*					*				

Result sheet B

Used in conjunction with result sheet A to record the retained totalization

Totalization indication		
At start of test	At end of test	Max deviation observed (except for non-recordable transients)

Result sheet C

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Static load	Calculated change in totalization, T_c	Totalization before adding load, T_b	Totalization after adding load, T_a	Indicated change in totalization, $T_i = T_a - T_b$	Error, $T_c - T_i$

Passed

Failed

Remarks:

4.4 Mains power voltage variations test (2.7.2, A.7.3)

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval, d : _____ Totalization scale interval, d_t : _____	<table border="1" style="border-collapse: collapse; text-align: center;"> <thead> <tr> <th style="padding: 2px 10px;"></th> <th style="padding: 2px 10px;">At start</th> <th style="padding: 2px 10px;">At end</th> <th style="padding: 2px 10px;"></th> </tr> </thead> <tbody> <tr> <td style="padding: 2px 10px;">Temp.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td style="padding: 2px 10px;">°C</td> </tr> <tr> <td style="padding: 2px 10px;">Rel. h.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td style="padding: 2px 10px;">%</td> </tr> <tr> <td style="padding: 2px 10px;">Date:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td style="padding: 2px 10px;">yyyy-mm-dd</td> </tr> <tr> <td style="padding: 2px 10px;">Time:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td style="padding: 2px 10px;">hh:mm:ss</td> </tr> <tr> <td style="padding: 2px 10px;">Bar. pres.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td style="padding: 2px 10px;">hPa</td> </tr> </tbody> </table>		At start	At end		Temp.:			°C	Rel. h.:			%	Date:			yyyy-mm-dd	Time:			hh:mm:ss	Bar. pres.:			hPa
	At start	At end																							
Temp.:			°C																						
Rel. h.:			%																						
Date:			yyyy-mm-dd																						
Time:			hh:mm:ss																						
Bar. pres.:			hPa																						

- AC mains voltage variations, A.7.3.4
- DC mains voltage variations, A.7.3.5
- Battery power supply (DC), A.7.3.6
- 12 V or 24 V road vehicle battery voltage variations, A.7.3.7

Supply voltage⁴: $U_{\text{nom}} =$ V $U_{\text{min}} =$ V $U_{\text{max}} =$ V

Automatic zero-setting device is:

- Non-existent
 Not in operation
 Out of working range
 In operation

⁴ a) Calculate the lower and upper limits of applied voltages according to 2.7.2. If a voltage range ($U_{\text{min}} / U_{\text{max}}$) is marked, use the average value as the reference value.

b) For a road vehicle battery, the U_{nom} of the vehicle's electrical system is usually 12 V or 24 V. However, the practical voltage at the battery terminals of a road vehicle can vary considerably.

Category of power supply: _____

Note: Reproduce this form if an instrument has more than one power supply

$$E = I + \frac{1}{2} d - \Delta L - L, \quad E_c = E - E_0 \text{ with } E_0 = \text{error calculated at or near zero}$$

Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Voltage conditions	U (V)	Load, L	Indication, I	Add. load, ΔL	Error	Corrected error, E_c
U_{nom}						
Lower limit						
Upper limit						

Result sheet B

Used in conjunction with result sheet A to record the retained totalization

Voltage conditions	U (V)	Totalization indication		
		At start of test	At end of test	Max deviation observed (except for non-recordable transients)
U_{nom}				
Lower limit				
Upper limit				

Result sheet C

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Voltage conditions	U (V)	Static load	Calculated change in totalization, T_c	Totalization before adding load, T_b	Totalization after adding load, T_a	Indicated change in totalization, $T_i = T_a - T_b$	Error, $T_c - T_i$
U_{nom}							
Lower limit							
Upper limit							

Passed

Failed

Remarks:

5 Disturbances (4.1.2, A.7.4)

5.1 AC mains voltage dips and short interruptions (A.7.4.1)

Application no.:	_____	Temp.:	At start	At end	_____ °C
Type designation:	_____	Rel. h.:	_____	_____	_____ %
Observer:	_____	Date:	_____	_____	_____ yyyy-mm-dd
Control scale interval, d :	_____	Time:	_____	_____	_____ hh:mm:ss
Totalization scale interval, d_t :	_____	Bar. pres.:	_____	_____	_____ hPa

Automatic zero-setting device is:

Non-existent
 Not in operation
 Out of working range
 In operation

Supply voltage⁵: $U_{nom} =$ V $U_{min} =$ V $U_{max} =$ V

Pre-test information

Disturbance parameters			
Amplitude (% of U_{nom})	Duration (cycles)	Number of disturbances	Repetition interval (s)
0	0.5	10	
0	1	10	
40	10	10	
70	25	10	
80	250 / 300*	10	
0	250 / 300*	10	

* These values are for 50 Hz / 60 Hz respectively

Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Disturbance Amplitude (% of U_{nom}) (other pre-test information)	Result			
	Load	Indication, I	Significant fault (>1 d_t)	
			No	Yes (remarks)
without disturbance				
0				
0				
40				
70				
80				
0				

⁵ Calculate the lower and upper limits of applied voltages according to 2.7.2. If a voltage-range (U_{min} / U_{max}) is marked, use the average value as the reference value.

Result sheet B

Used in conjunction with result sheet A to record the retained totalization

Disturbance Amplitude % of U_{nom} (other pre-test information)	Result			
	Totalization indication		Significant fault ($>1 d_t$)	
	At start of test	At end of test	No	Yes (remarks)
without disturbance				
0				
0				
40				
70				
80				
0				

Result sheet C

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Disturbance Amplitude (% of U_{nom}) (other pre-test information)	Result						
	Load	Calculated change in totalization, T_c	Totalization before adding load, T_b	Totalization after adding load, T_a	Indicated change in totalization, $T_i = T_a - T_b$	Significant fault ($T_c - T_i$) or detection and reaction	
						No	Yes (remarks)
without disturbance							
0 %							
0 %							
40 %							
70 %							
80 %							
0 %							

Passed

Failed

Remarks:

5.2 Bursts (transients) on mains power lines and on signal and communication lines (A.7.4.2)

5.2.1 Mains power lines

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval, d : _____ Totalization scale interval, d_t : _____	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;"></th> <th style="width: 20%;">At start</th> <th style="width: 20%;">At end</th> <th style="width: 10%;"></th> </tr> </thead> <tbody> <tr> <td>Temp.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>°C</td> </tr> <tr> <td>Rel. h.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>%</td> </tr> <tr> <td>Date:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>yyyy-mm-dd</td> </tr> <tr> <td>Time:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>hh:mm:ss</td> </tr> <tr> <td>Bar. pres.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>hPa</td> </tr> </tbody> </table>		At start	At end		Temp.:			°C	Rel. h.:			%	Date:			yyyy-mm-dd	Time:			hh:mm:ss	Bar. pres.:			hPa
	At start	At end																							
Temp.:			°C																						
Rel. h.:			%																						
Date:			yyyy-mm-dd																						
Time:			hh:mm:ss																						
Bar. pres.:			hPa																						

Automatic zero-setting device is:

Non-existent
 Not in operation
 Out of working range
 In operation

Mains power lines: test voltage 1.0 kV (peak), duration of the test > 1 minute at each amplitude and polarity

Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Connection	Polarity	Result			
		Load	Indication, I	Significant fault (>1 d_t)	
				No	Yes (remarks)
without disturbance					
Live ↓ ground	pos				
	neg				
without disturbance					
Neutral ↓ ground	pos				
	neg				
without disturbance					
Protective earth ↓ ground	pos				
	neg				

Result sheet B

Used in conjunction with result sheet A to record the retained totalization

Connection	Polarity	Result			
		Totalization indication		Significant fault ($> 1 d_t$)	
		At start of test	At end of test	No	Yes (remarks)
without disturbance					
Live ↓ ground	pos				
	neg				
without disturbance					
Neutral ↓ ground	pos				
	neg				
without disturbance					
Protective earth ↓ ground	pos				
	neg				

Result sheet C

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Connection	Polarity	Result						
		Load	Calculated change in totalization, T_c	Totalization before adding load, T_b	Totalization after adding load, T_a	Indicated change in totalization, $T_i = T_a - T_b$	Significant fault ($T_c - T_i$)	
							No	Yes (remarks)
without disturbance								
Live ↓ ground	pos							
	neg							
without disturbance								
Neutral ↓ ground	pos							
	neg							
without disturbance								
Protective earth ↓ ground	pos							
	neg							

Passed

Failed

Remarks:

5.2.2 Signal and communication lines

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval, d : _____ Totalization scale interval, d_t : _____	<table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th style="width: 15%;"></th> <th style="width: 35%;">At start</th> <th style="width: 35%;">At end</th> <th style="width: 15%;"></th> </tr> </thead> <tbody> <tr> <td>Temp.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>°C</td> </tr> <tr> <td>Rel. h.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>%</td> </tr> <tr> <td>Date:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>yyyy-mm-dd</td> </tr> <tr> <td>Time:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>hh:mm:ss</td> </tr> <tr> <td>Bar. pres.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>hPa</td> </tr> </tbody> </table>		At start	At end		Temp.:			°C	Rel. h.:			%	Date:			yyyy-mm-dd	Time:			hh:mm:ss	Bar. pres.:			hPa
	At start	At end																							
Temp.:			°C																						
Rel. h.:			%																						
Date:			yyyy-mm-dd																						
Time:			hh:mm:ss																						
Bar. pres.:			hPa																						

Automatic zero-setting device is:

<input type="checkbox"/> Non-existent	<input type="checkbox"/> Not in operation	<input type="checkbox"/> Out of working range	<input type="checkbox"/> In operation
---------------------------------------	---	---	---------------------------------------

Signal and communication lines: test voltage 0.5 kV (peak), duration of the test > 1 minute at each amplitude and polarity

Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Cable/interface	Polarity	Result			
		Load	Indication, I	Significant fault ($>1 d_t$)	
				No	Yes (remarks)
without disturbance					
C/1,1	pos				
	neg				
without disturbance					
C/1,2	pos				
	neg				
without disturbance					
C/1,3	pos				
	neg				
without disturbance					
C/1,4	pos				
	neg				
without disturbance					
C/1,5	pos				
	neg				
without disturbance					
C/1,6	pos				
	neg				

- Notes:*
- 1) Explain or make a sketch indicating where the clamp is located on the cable; if necessary, add additional page.
 - 2) The cell references C/1,1 to C/1,6 should be used to cross-reference the cable or interface between Tables A and B.

Result sheet B*Used in conjunction with result sheet A to record the retained totalization*

Cable/interface	Polarity	Result			
		At start of test	At end of test	Significant fault ($>1 d_t$)	
				No	Yes (remarks)
without disturbance					
C/1,1	pos				
	neg				
without disturbance					
C/1,2	pos				
	neg				
without disturbance					
C/1,3	pos				
	neg				
without disturbance					
C/1,4	pos				
	neg				
without disturbance					
C/1,5	pos				
	neg				
without disturbance					
C/1,6	pos				
	neg				

Result sheet C

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Cable/interface	Polarity	Result						Significant fault ($T_c - T_i$)	
		Load	Calculated change in totalization, T_c	Totalization before adding load, T_b	Totalization after adding load, T_a	Indicated change in totalization, $T_i = T_a - T_b$	Significant fault ($T_c - T_i$)		
							No	Yes (remarks)	
without disturbance									
C/1,1	pos								
	neg								
without disturbance									
C/1,2	pos								
	neg								
without disturbance									
C/1,3	pos								
	neg								
without disturbance									
C/1,4	pos								
	neg								
without disturbance									
C/1,5	pos								
	neg								
without disturbance									
C/1,6	pos								
	neg								

Passed

Failed

Remarks:

5.3 Electrical surges on mains power lines and on I/O signal and communication lines (if any) (A.7.4.3)

5.3.1 Mains power lines

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval, d_c : _____ Totalization scale interval, d_t : _____	Temp.: _____ °C Rel. h.: _____ % Date: _____ yyyy-mm-dd Time: _____ hh:mm:ss Bar. pres.: _____ hPa
---	--

Automatic zero-setting device is:

Non-existent
 Not in operation
 Out of working range
 In operation

Mains power lines: test voltage 1.0 kV, duration of the test > 1 minute at each amplitude and polarity

Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Connection	Polarity	Result			
		Load	Indication, I	Significant fault (>1 d_t)	
				No	Yes (remarks)
without disturbance					
Live ↓ ground	pos				
	neg				
without disturbance					
Neutral ↓ ground	pos				
	neg				
without disturbance					
Protective earth ↓ ground	pos				
	neg				

Result sheet B

Used in conjunction with result sheet A to record the retained totalization

Connection	Polarity	Result			
		Totalization indication		Significant fault ($>1 d_t$)	
		At start of test	At end of test	No	Yes (remarks)
without disturbance					
Live ↓ ground	pos				
	neg				
without disturbance					
Neutral ↓ ground	pos				
	neg				
without disturbance					
Protective earth ↓ ground	pos				
	neg				

Result sheet C

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Connection	Polarity	Result						
		Load	Calculated change in totalization, T_c	Totalization before adding load, T_b	Totalization after adding load, T_a	Indicated change in totalization, $T_i = T_a - T_b$	Significant fault ($T_c - T_i$)	
							No	Yes (remarks)
without disturbance								
Live ↓ ground	pos							
	neg							
without disturbance								
Neutral ↓ ground	pos							
	neg							
without disturbance								
Protective earth ↓ ground	pos							
	neg							

Passed

Failed

Remarks (including additional test setup information):

5.3.2 Electrical surges on I/O signal and communication lines (if any)

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval, d : _____ Totalization scale interval, d_t : _____	Temp.: _____ °C Rel. h.: _____ % Date: _____ yyyy-mm-dd Time: _____ hh:mm:ss Bar. pres.: _____ hPa
---	--

Automatic zero-setting device is:

Non-existent
 Not in operation
 Out of working range
 In operation

I/O signal and communication lines (if any): test voltage 0.5 kV, duration of the test 1 minute at each amplitude and polarity

Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Cable/interface	Polarity	Result			
		Load	Indication, I	Significant fault (>1 d_t)	
				No	Yes (remarks)
without disturbance					
C/1,1	pos				
	neg				
without disturbance					
C/1,2	pos				
	neg				
without disturbance					
C/1,3	pos				
	neg				
without disturbance					
C/1,4	pos				
	neg				
without disturbance					
C/1,5	pos				
	neg				
without disturbance					
C/1,6	pos				
	neg				

- Notes:
- 1) Explain or make a sketch indicating where the clamp is located on the cable; if necessary, add additional page.
 - 2) The cell references C/1,1 to C/1,6 should be used to cross-reference the cable or interface between Tables A and B.

Result sheet B*Used in conjunction with result sheet A to record the retained totalization*

Cable/interface	Polarity	Result			
		At start of test	At end of test	Significant fault ($>1 d_t$)	
				No	Yes (remarks)
without disturbance					
C/1,1	pos				
	neg				
without disturbance					
C/1,2	pos				
	neg				
without disturbance					
C/1,3	pos				
	neg				
without disturbance					
C/1,4	pos				
	neg				
without disturbance					
C/1,5	pos				
	neg				
without disturbance					
C/1,6	pos				
	neg				

Result sheet C

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Cable/ interface	Polarity	Result						Significant fault ($T_c - T_i$)	
		Load	Calculated change in totalization, T_c	Totalization before adding load, T_b	Totalization after adding load, T_a	Indicated change in totalization, $T_i = T_a - T_b$	No	Yes (remarks)	
without disturbance									
C/1,1	pos								
	neg								
without disturbance									
C/1,2	pos								
	neg								
without disturbance									
C/1,3	pos								
	neg								
without disturbance									
C/1,4	pos								
	neg								
without disturbance									
C/1,5	pos								
	neg								
without disturbance									
C/1,6	pos								
	neg								

Passed

Failed

Remarks:

5.4 Electrostatic discharge (A.7.4.4)

5.4.1 Direct application

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval, d : _____ Totalization scale interval, d_t : _____	<table border="1" style="border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;"></th> <th style="width: 15%;">At start</th> <th style="width: 15%;">At end</th> <th style="width: 10%;"></th> </tr> </thead> <tbody> <tr> <td>Temp.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>°C</td> </tr> <tr> <td>Rel. h.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>%</td> </tr> <tr> <td>Date:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>yyyy-mm-dd</td> </tr> <tr> <td>Time:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>hh:mm:ss</td> </tr> <tr> <td>Bar. pres.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>hPa</td> </tr> </tbody> </table>		At start	At end		Temp.:			°C	Rel. h.:			%	Date:			yyyy-mm-dd	Time:			hh:mm:ss	Bar. pres.:			hPa
	At start	At end																							
Temp.:			°C																						
Rel. h.:			%																						
Date:			yyyy-mm-dd																						
Time:			hh:mm:ss																						
Bar. pres.:			hPa																						

Automatic zero-setting device is:

Non-existent
 Not in operation
 Out of working range
 In operation

Contact discharges
 Paint penetration
 Air discharges
 Polarity⁶:
 pos
 neg

Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Discharges			Result			
Test voltage (kV)	Number of discharges (≥ 10)	Repetition interval (s)	Load	Indication, I	Significant fault (>1 d_t)	
					No	Yes (remarks)
without disturbance						
2						
4						
6						
8 (air discharges)						

⁶ IEC 61000-4-2 specifies that the test shall be conducted with the most sensitive polarity.

Result sheet B

Used in conjunction with result sheet A to record the retained totalization

Discharges			Result			
Test voltage (kV)	Number of discharges ≥ 10	Repetition interval (s)	At start of test	At end of test	Significant fault ($>1 d_t$)	
					No	Yes (remarks)
without disturbance						
2						
4						
6						
8 (air discharges)						

Result sheet C

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Discharges			Result						
Test voltage (kV)	Number of discharges ≥ 10	Repetition interval (s)	Load	Calculated change, T_c	Before adding load, T_b	After adding load, T_a	Indicated change $T_i = T_a - T_b$	Significant fault ($T_c - T_i$)	
								No	Yes (remarks)
without disturbance									
2									
4									
6									
8 (air discharges)									

Note: If the EUT fails, the test point at which this occurs shall be recorded.

Passed

Failed

Remarks:

5.4.2 Indirect application (contact discharges only)

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval d_t : _____ Totalization scale interval d_t : _____	<table border="1" style="border-collapse: collapse; width: 100%;"> <thead> <tr> <th style="width: 50%;"></th> <th style="width: 20%;">At start</th> <th style="width: 20%;">At end</th> <th style="width: 10%;"></th> </tr> </thead> <tbody> <tr> <td>Temp.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>°C</td> </tr> <tr> <td>Rel. h.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>%</td> </tr> <tr> <td>Date:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>yyyy-mm-dd</td> </tr> <tr> <td>Time:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>hh:mm:ss</td> </tr> <tr> <td>Bar. pres.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>hPa</td> </tr> </tbody> </table>		At start	At end		Temp.:			°C	Rel. h.:			%	Date:			yyyy-mm-dd	Time:			hh:mm:ss	Bar. pres.:			hPa
	At start	At end																							
Temp.:			°C																						
Rel. h.:			%																						
Date:			yyyy-mm-dd																						
Time:			hh:mm:ss																						
Bar. pres.:			hPa																						

Automatic zero-setting device is:

Non-existent
 Not in operation
 Out of working range
 In operation

Polarity⁷: pos neg

Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Horizontal coupling plane

Discharges			Result			
Test voltage (kV)	Number of discharges ≥ 10	Repetition interval (s)	Load	Indication, I	Significant fault ($>1 d_t$)	
					No	Yes (remarks)
without disturbance						
2						
4						
6						

Vertical coupling plane

Discharges			Result			
Test voltage (kV)	Number of discharges ≥ 10	Repetition interval (s)	Load	Indication, I	Significant fault ($>1 d_t$)	
					No	Yes (remarks)
without disturbance						
2						
4						
6						

⁷ IEC 61000-4-2 specifies that the test shall be conducted with the most sensitive polarity.

Result sheet B*Used in conjunction with result sheet A to record the retained totalization***Horizontal coupling plane**

Discharges			Result			
Test voltage (kV)	Number of discharges ≥ 10	Repetition interval (s)	Totalization		Significant fault (>1 d_t)	
			At start of test	At end of test	No	Yes (remarks)
without disturbance						
2						
4						
6						

Vertical coupling plane

Discharges			Result			
Test voltage (kV)	Number of discharges ≥ 10	Repetition interval (s)	Totalization		Significant fault (>1 d_t)	
			At start of test	At end of test	No	Yes (remarks)
without disturbance						
2						
4						
6						

Result sheet C

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Horizontal coupling plane

Discharges			Result						
Test voltage (kV)	Number of discharges ≥ 10	Repetition interval (s)	Totalization					Significant fault ($T_c - T_i$)	
			Load	Calculated change, T_c	Before adding load, T_b	After adding load, T_a	Indicated change, $T_i = T_a - T_b$	No	Yes (remarks)
without disturbance									
2									
4									
6									

Vertical coupling plane

Discharges			Result						
Test voltage (kV)	Number of discharges ≥ 10	Repetition interval (s)	Totalization					Significant fault ($T_c - T_i$)	
			Load	Calculated change, T_c	Before adding load, T_b	After adding load, T_a	Indicated change, $T_i = T_a - T_b$	No	Yes (remarks)
without disturbance									
2									
4									
6									

Note: If the EUT fails, the test point at which this occurs shall be recorded.

Passed

Failed

Remarks:

5.4 Electrostatic discharge test (A.7.4.4) (continued)

Specification of test points of EUT (direct application), e.g. by photos or sketches

a) Direct application

Contact discharges:

Air discharges:

b) Indirect application

5.5 Immunity to electromagnetic fields (A.7.4.5)

5.5.1 Immunity to radiated electromagnetic fields (A.7.4.5.1)

Application no.:	_____	Temp.:	At start	At end	°C
Type designation:	_____	Rel. h.:			%
Observer:	_____	Date:			yyyy-mm-dd
Control scale interval, d :	_____	Time:			hh:mm:ss
Totalization scale interval, d_t :	_____	Bar. pres.:			hPa

Rate of sweep:

Test severity;

Frequency range: 80 MHz¹ to 2000 MHz

RF amplitude (50 ohms): 10 V/m

Modulation: 80 % AM, 1 kHz, sine wave

¹ Lower limit is 26 MHz if the test according to A.7.4.5.2 cannot be applied due to lack of mains or I/O ports.

Note: If the EUT fails, the frequency and field strength at which this occurs must be recorded.

Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Disturbances				Result			
Antenna	Frequency range (MHz)	Polarization	EUT facing	Load	Indication, I	Significant fault (>1 d_t)	
						No	Yes (remarks)
without disturbance							
		Vertical	Front				
			Right				
			Left				
			Rear				
		Horizontal	Front				
			Right				
			Left				
			Rear				
		Vertical	Front				
			Right				
			Left				
			Rear				
		Horizontal	Front				
			Right				
			Left				
			Rear				

Passed Failed

Remarks:

Result sheet B

Used in conjunction with result sheet A to record the retained totalization

Disturbances				Result			
Antenna	Frequency range (MHz)	Polarization	EUT facing	Totalization indication		Significant fault (>1 d_t)	
				At start of test	At end of test	No	Yes (remarks)
without disturbance							
		Vertical	Front				
			Right				
			Left				
			Rear				
without disturbance							
		Horizontal	Front				
			Right				
			Left				
			Rear				
without disturbance							
		Vertical	Front				
			Right				
			Left				
			Rear				
without disturbance							
		Horizontal	Front				
			Right				
			Left				
			Rear				

Result sheet C

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Disturbances				Result							
Antenna	Frequency range (MHz)	Polarization	EUT facing	Totalization					Significant fault ($T_c - T_i$)		
				Load	Calculated change, T_c	Before adding load, T_b	After adding load, T_a	Indicated change, $T_i = T_a - T_b$	No	Yes (remarks)	
without disturbance											
		Vertical	Front								
			Right								
			Left								
			Rear								
without disturbance											
		Horizontal	Front								
			Right								
			Left								
			Rear								
without disturbance											
		Vertical	Front								
			Right								
			Left								
			Rear								
without disturbance											
		Horizontal	Front								
			Right								
			Left								
			Rear								

Passed

Failed

Remarks:

5.5.2 Immunity to conducted electromagnetic fields (A.7.4.5.2)

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval, d : _____ Totalization scale interval, d_t : _____	<table border="1" style="border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;"></th> <th style="width: 15%;">At start</th> <th style="width: 15%;">At end</th> <th style="width: 10%;"></th> </tr> </thead> <tbody> <tr> <td>Temp.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>°C</td> </tr> <tr> <td>Rel. h.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>%</td> </tr> <tr> <td>Date:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>yyyy-mm-dd</td> </tr> <tr> <td>Time:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>hh:mm:ss</td> </tr> <tr> <td>Bar. pres.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>hPa</td> </tr> </tbody> </table>		At start	At end		Temp.:			°C	Rel. h.:			%	Date:			yyyy-mm-dd	Time:			hh:mm:ss	Bar. pres.:			hPa
	At start	At end																							
Temp.:			°C																						
Rel. h.:			%																						
Date:			yyyy-mm-dd																						
Time:			hh:mm:ss																						
Bar. pres.:			hPa																						

Rate of sweep:

Test severity;
 Frequency range: 0.15 MHz – 80 MHz
 RF amplitude (50 ohms): 10 V (e.m.f.)
 Modulation: 80 % AM, 1 kHz, sine wave

Note: If EUT fails, the frequency and field strength at which this occurs must be recorded.

Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Disturbances				Result			
Antenna	Frequency range (MHz)	Polarization	Level (volts e.m.f)	Load	Indication, I	Significant fault (>1 d_t)	
						No	Yes (remarks)
without disturbance							
		Vertical	Front				
			Right				
			Left				
			Rear				
		Horizontal	Front				
			Right				
			Left				
			Rear				
		Vertical	Front				
			Right				
			Left				
			Rear				
		Horizontal	Front				
			Right				
			Left				
			Rear				

Passed Failed

Remarks:

Result sheet B

Used in conjunction with result sheet A to record the retained totalization

Disturbances				Result			
Antenna	Frequency range (MHz)	Polarization	Level (volts e.m.f)	Totalization indication		Significant fault (>1 d_t)	
				At start of test	At end of test	No	Yes (remarks)
without disturbance							
		Vertical	Front				
			Right				
			Left				
			Rear				
without disturbance							
		Horizontal	Front				
			Right				
			Left				
			Rear				
without disturbance							
		Vertical	Front				
			Right				
			Left				
			Rear				
without disturbance							
		Horizontal	Front				
			Right				
			Left				
			Rear				

Result sheet C

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Disturbances				Result						
Antenna	Frequency range (MHz)	Polarization	Level (volts e.m.f)	Totalization					Significant fault ($T_c - T_i$)	
				Load	Calculated change, T_c	Before adding load, T_b	After adding load, T_a	Indicated change, $T_i = T_a - T_b$	No	Yes (remarks)
without disturbance										
		Vertical	Front							
			Right							
			Left							
			Rear							
without disturbance										
		Horizontal	Front							
			Right							
			Left							
			Rear							
without disturbance										
		Vertical	Front							
			Right							
			Left							
			Rear							
without disturbance										
		Horizontal	Front							
			Right							
			Left							
			Rear							

Passed

Failed

Remarks:

Include a description of the setup of the EUT, e.g. by photos or sketches.

Radiated:

Conducted:

5.6 Electrical transient conduction for instruments powered by road vehicle batteries (A.7.4.6)

5.6.1 Conduction along supply lines of 12 V or 24 V road vehicle batteries (A.7.4.6.1)

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval, d : _____ Totalization scale interval, d_t : _____	<table border="1"> <tr> <td></td> <td style="text-align: center;">At start</td> <td style="text-align: center;">At end</td> <td></td> </tr> <tr> <td>Temp.:</td> <td></td> <td style="background-color: #cccccc;"></td> <td>°C</td> </tr> <tr> <td>Rel. h.:</td> <td></td> <td style="background-color: #cccccc;"></td> <td>%</td> </tr> <tr> <td>Date:</td> <td></td> <td style="background-color: #cccccc;"></td> <td>yyyy-mm-dd</td> </tr> <tr> <td>Time:</td> <td></td> <td style="background-color: #cccccc;"></td> <td>hh:mm:ss</td> </tr> <tr> <td>Bar. pres.:</td> <td></td> <td style="background-color: #cccccc;"></td> <td>hPa</td> </tr> </table>		At start	At end		Temp.:			°C	Rel. h.:			%	Date:			yyyy-mm-dd	Time:			hh:mm:ss	Bar. pres.:			hPa
	At start	At end																							
Temp.:			°C																						
Rel. h.:			%																						
Date:			yyyy-mm-dd																						
Time:			hh:mm:ss																						
Bar. pres.:			hPa																						

12 V battery voltage
 24 V battery voltage

Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Voltage conditions, U_{nom}	Test pulse	Pulse voltage, U_s	Result			
			Load	Indication, I	Significant fault ($>1 d_t$)	
					No	Yes (remarks) ⁸
12 V	2a	+ 50 V				
	2b ⁹	+10 V				
	3a	-150 V				
	3b	+100 V				
	4	-7 V				
24 V	2a	+50 V				
	2b	+20 V				
	3a	-200 V				
	3b	+200 V				
	4	-16 V				

⁸ Functional status of the instrument during and after exposure to test pulses.

⁹ Test pulse 2b is only applicable if the instrument is connected to the battery via the main (ignition) switch of the car, i.e. if the manufacturer has not specified that the instrument is to be connected directly (or by its own main switch) to the battery.

Result sheet B

Used in conjunction with result sheet A to record the retained totalization

Voltage conditions, U_{nom}	Test pulse	Pulse voltage, U_s	Result			
			Totalization indication		Significant fault ($>1 d_t$)	
			At start of test	At end of test	No	Yes (remarks)
12 V	2a	+50 V				
	2b	+10 V				
	3a	-150 V				
	3b	+100 V				
	4	-7 V				
24 V	2a	+50 V				
	2b	+20 V				
	3a	-200 V				
	3b	+200 V				
	4	-16 V				

Result sheet C

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Voltage conditions, U_{nom}	Test pulse	Pulse voltage, U_s	Result						
			Totalization indication				Significant fault ($T_c - T_i$)		
			Load	Calculated change, T_c	Before adding load, T_b	After adding load, T_a	Indicated change, $T_i = T_a - T_b$	No	Yes (remarks)
12 V	2a	+50 V							
	2b	+10 V							
	3a	-150 V							
	3b	+100 V							
	4	-7 V							
24 V	2a	+50 V							
	2b	+20 V							
	3a	-200 V							
	3b	+200 V							
	4	-16 V							

Passed

Failed

Remarks:

5.6.2 Electrical transient conduction via lines other than supply lines, for external 12 V or 24 V road vehicle batteries (A.7.4.6.2)

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval, d : _____ Totalization scale interval, d_t : _____	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 15%;"></th> <th style="width: 15%;">At start</th> <th style="width: 15%;">At end</th> <th style="width: 15%;"></th> </tr> </thead> <tbody> <tr> <td>Temp.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>°C</td> </tr> <tr> <td>Rel. h.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>%</td> </tr> <tr> <td>Date:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>yyyy-mm-dd</td> </tr> <tr> <td>Time:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>hh:mm:ss</td> </tr> <tr> <td>Bar. pres.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>hPa</td> </tr> </tbody> </table>		At start	At end		Temp.:			°C	Rel. h.:			%	Date:			yyyy-mm-dd	Time:			hh:mm:ss	Bar. pres.:			hPa
	At start	At end																							
Temp.:			°C																						
Rel. h.:			%																						
Date:			yyyy-mm-dd																						
Time:			hh:mm:ss																						
Bar. pres.:			hPa																						

12 V battery voltage
 24 V battery voltage

Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Voltage conditions, U_{nom}	Test pulse	Pulse voltage, U_s	Result			
			Load	Indication, I	Significant fault ($>1 d_t$)	
					No	Yes (remarks) ¹⁰
12 V	a	-60 V				
	b	+40 V				
24 V	a	-80 V				
	b	+80 V				

Result sheet B

Used in conjunction with result sheet A to record the retained totalization

Voltage conditions, U_{nom}	Test pulse	Pulse voltage, U_s	Result			
			Totalization indication		Significant fault ($>1 d_t$)	
			At start of test	At end of test	No	Yes (remarks)
12 V	a	-60 V				
	b	+40 V				
24 V	a	-80 V				
	b	+80 V				

¹⁰ Functional status of the instrument during and after exposure to test pulses.

Result sheet C

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Voltage conditions, U_{nom}	Test pulse	Pulse voltage, U_s	Result						
			Totalization indication					Significant fault ($T_c - T_i$)	
			Load	Calculated change, T_c	Before adding load, T_b	After adding load, T_a	Indicated change, $T_i = T_a - T_b$	No	Yes (remarks)
12 V	a	-60 V							
	b	+40 V							
24 V	a	-80 V							
	b	+80 V							

 Passed

 Failed

Remarks:

6 Span stability (6.7.3, A.8)

Application no.: _____

Type designation: _____

Control scale interval, *d*: _____

Resolution during test (smaller than *d*): _____

Automatic zero-setting and zero-tracking device is:

Non-existent Not in operation Out of working range

Zero load =

Test load =

Automatic span adjustment device:

Non-existent In operation

Measurement no. 1: Initial measurement

Application no.: _____

Type designation: _____

Observer: _____

	At start	At end	
Temp.:	<input type="text"/>	<input type="text"/>	°C
Rel. h.:	<input type="text"/>	<input type="text"/>	%
Date:	<input type="text"/>	<input type="text"/>	yyyy-mm-dd
Time:	<input type="text"/>	<input type="text"/>	hh:mm:ss
Bar. pres.:	<input type="text"/>	<input type="text"/>	Pa

$$E_0 = I_0 + \frac{1}{2} d - \Delta L_0 - L_0, \quad E_L = I_L + \frac{1}{2} d - \Delta L - L$$

No.	Indication of zero, I_0	Add. load, ΔL_0	E_0	Indication of load, I_L	Add. load, ΔL	E_L	$E_L - E_0$	Corrected value*
1	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
2	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
3	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
4	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
5	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>

* When applicable, necessary corrections resulting from variations of temperature, pressure, etc. See remarks.

Average error = average ($E_L - E_0$)

$(E_L - E_0)_{\max} - (E_L - E_0)_{\min} =$

$0.1 d =$

If $|(E_L - E_0)_{\max} - (E_L - E_0)_{\min}| \leq 0.1 d$, one loading and reading will be sufficient for each of the subsequent measurements. If not, five loadings and readings shall be performed at each measurement.

Remarks:

For each of the subsequent measurements (at least seven), indicate under “Remarks”, as appropriate, if the measurement has been performed after:

- the temperature test, the EUT having been stabilized for at least 16 h
- the damp heat test, the EUT having been stabilized for at least 16 h
- the EUT has been disconnected from the mains for at least 8 h and then stabilized for at least 5 h
- any change in the test location
- any other specific condition: _____

Measurement no. 2

Application no.: _____
 Type designation: _____
 Observer: _____

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$$E_0 = I_0 + \frac{1}{2} d - \Delta L_0 - L_0, \quad E_L = I_L + \frac{1}{2} d - \Delta L - L$$

No.	Indication of zero, I_0	Add. load, ΔL_0	E_0	Indication of load, I_L	Add. load, ΔL	E_L	$E_L - E_0$	Corrected value*
1								
2								
3								
4								
5								

* When applicable, necessary corrections resulting from variations of temperature, pressure, etc. See remarks.

If five loadings and readings have been performed: Average error = average ($E_L - E_0$)

Remarks:

Measurement no. 3

Application no.: _____
 Type designation: _____
 Observer: _____

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$$E_0 = I_0 + \frac{1}{2} d - \Delta L_0 - L_0, \quad E_L = I_L + \frac{1}{2} d - \Delta L - L$$

No.	Indication of zero, I_0	Add. load, ΔL_0	E_0	Indication of load, I_L	Add. load, ΔL	E_L	$E_L - E_0$	Corrected value*
1								
2								
3								
4								
5								

* When applicable, necessary corrections resulting from variations of temperature, pressure, etc. See remarks.

If five loadings and readings have been performed: Average error = average ($E_L - E_0$)

Remarks:

Measurement no. 4

Application no.: _____
 Type designation: _____
 Observer: _____

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$$E_0 = I_0 + \frac{1}{2} d - \Delta L_0 - L_0, \quad E_L = I_L + \frac{1}{2} d - \Delta L - L$$

No.	Indication of zero, I_0	Add. load, ΔL_0	E_0	Indication of load, I_L	Add. load, ΔL	E_L	$E_L - E_0$	Corrected value*
1								
2								
3								
4								
5								

* When applicable, necessary corrections resulting from variations of temperature, pressure, etc. See remarks.

If five loadings and readings have been performed: Average error = average ($E_L - E_0$)

Remarks:

Measurement no. 5

Application no.: _____
 Type designation: _____
 Observer: _____

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$$E_0 = I_0 + \frac{1}{2} d - \Delta L_0 - L_0, \quad E_L = I_L + \frac{1}{2} d - \Delta L - L$$

No.	Indication of zero, I_0	Add. load, ΔL_0	E_0	Indication of load, I_L	Add. load, ΔL	E_L	$E_L - E_0$	Corrected value
1								
2								
3								
4								
5								

* When applicable, necessary corrections resulting from variations of temperature, pressure, etc. See remarks.

If five loadings and readings have been performed: Average error = average ($E_L - E_0$)

Remarks:

Measurement no. 6

Application no.: _____
 Type designation: _____
 Observer: _____

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$$E_0 = I_0 + \frac{1}{2} d - \Delta L_0 - L_0, \quad E_L = I_L + \frac{1}{2} d - \Delta L - L$$

No.	Indication of zero, I_0	Add. load, ΔL_0	E_0	Indication of load, I_L	Add. load, ΔL	E_L	$E_L - E_0$	Corrected value
1								
2								
3								
4								
5								

* When applicable, necessary corrections resulting from variations of temperature, pressure, etc. See remarks.

If five loadings and readings have been performed: Average error = average ($E_L - E_0$)

Remarks:

Measurement no. 7

Application no.: _____
 Type designation: _____
 Observer: _____

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$$E_0 = I_0 + \frac{1}{2} d - \Delta L_0 - L_0, \quad E_L = I_L + \frac{1}{2} d - \Delta L - L$$

No.	Indication of zero, I_0	Add. load, ΔL_0	E_0	Indication of load, I_L	Add. load, ΔL	E_L	$E_L - E_0$	Corrected value
1								
2								
3								
4								
5								

* When applicable, necessary corrections resulting from variations of temperature, pressure, etc. See remarks.

If five loadings and readings have been performed: Average error = average ($E_L - E_0$)

Remarks:

Measurement no. 8

Application no.: _____
 Type designation: _____
 Observer: _____

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$$E_0 = I_0 + \frac{1}{2} d - \Delta L_0 - L_0, \quad E_L = I_L + \frac{1}{2} d - \Delta L - L$$

No.	Indication of zero, I_0	Add. load, ΔL_0	E_0	Indication of load, I_L	Add. load, ΔL	E_L	$E_L - E_0$	Corrected value
1								
2								
3								
4								
5								

* When applicable, necessary corrections resulting from variations of temperature, pressure, etc. See remarks.

If five loadings and readings have been performed: Average error = average ($E_L - E_0$)


Remarks:

5 SPAN STABILITY (A.8)

Application no.:

Type designation:

Plot on the diagram the indication of temperature test, T, damp heat test, D and disconnections from the mains power supply, P



Maximum allowable variation:

Passed Failed

7 Material tests (6.1, A.5.1)

7.1 Material testing (separate verification method) (6.2.1, A.5.1.1, A.9.2.3)

Test 1

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval, d : _____ Totalization scale interval, d_t : _____ Material: _____ Condition of material: _____ Nominal load: _____	Temp.: Rel. h.: Date: Time: Bar. pres.:	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%; text-align: center;">At start</td> <td style="width: 50%; text-align: center;">At end</td> </tr> <tr> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> </tr> <tr> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> </tr> <tr> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> </tr> <tr> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> </tr> </table>	At start	At end									°C % yyyy-mm-dd hh:mm:ss hPa
At start	At end												

Parameter	Results
Number of loads	
Indicated total at start, T_S	
Indicated total at end, T_F	
$I = T_F - T_S$	
Control instrument indication for total load, L	
$Error = (I - L) / L \times 100 \%$	

Remarks:

Test 2

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval, d : _____ Totalization scale interval, d_t : _____ Material: _____ Condition of material: _____ Nominal load: _____	Temp.: Rel. h.: Date: Time: Bar. pres.:	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%; text-align: center;">At start</td> <td style="width: 50%; text-align: center;">At end</td> </tr> <tr> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> </tr> <tr> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> </tr> <tr> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> </tr> <tr> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> </tr> </table>	At start	At end									°C % yyyy-mm-dd hh:mm:ss hPa
At start	At end												

Parameter	Results
Number of loads	
Indicated total at start, T_S	
Indicated total at end, T_F	
$I = T_F - T_S$	
Control instrument indication for total load, L	
$Error = (I - L) / L \times 100 \%$	

Remarks:

Test 3

Application no.:	_____	Temp.:	At start	At end	°C
Type designation:	_____	Rel. h.:			%
Observer:	_____	Date:			yyyy-mm-dd
Control scale interval, d :	_____	Time:			hh:mm:ss
Totalization scale interval, d_t :	_____	Bar. pres.:			hPa
Material:	_____				
Condition of material:	_____				
Nominal load:	_____				

Parameter	Results
Number of loads	
Indicated total at start, T_S	
Indicated total at end, T_F	
$I = T_F - T_S$	
Control instrument indication for total load, L	
Error = $(I - L) / L \times 100 \%$	

Remarks:

Additional test

Application no.:	_____	Temp.:	At start	At end	°C
Type designation:	_____	Rel. h.:			%
Observer:	_____	Date:			yyyy-mm-dd
Control scale interval, d :	_____	Time:			hh:mm:ss
Totalization scale interval, d_t :	_____	Bar. pres.:			hPa
Material:	_____				
Condition of material:	_____				
Nominal load:	_____				

Parameter	Results
Number of loads	
Indicated total at start, T_S	
Indicated total at end, T_F	
$I = T_F - T_S$	
Control instrument indication for total load, L	
Error = $(I - L) / L \times 100 \%$	

Remarks:

Note: Reproduce this page for additional tests as necessary.

8 Examination of the construction of the instrument

Use this page to indicate any description or information pertaining to the instrument, additional to that already contained in this report and in the accompanying OIML certificate. This may include a picture of the complete instrument, a description of its main components, and any remark which could be useful for authorities responsible for the initial or subsequent verifications of individual instruments built according to the type. It may also include references to the manufacturer's description.

Description:

Remarks:

9 Checklist

This checklist is intended to serve as a summary of the results of examinations to be performed and not as a procedure. The items on this checklist are provided to recall the requirements specified in R 107-1:2007 and shall not be considered as a substitution for these requirements.

For non-mandatory devices, the checklist provides space to indicate whether or not the device exists and, if appropriate, its type. A cross in the box for “present” indicates that the device exists and that it complies with the definition given in the terminology; when indicating that a device is “not present”, also check the boxes to indicate that the tests are not applicable (see page 6).

If appropriate, the results stated in this checklist may be supplemented by remarks given on additional pages.

Application no.: _____ Type designation: _____

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks
Metrological requirements					
2.2.1	A.5.1	Maximum permissible errors			
		Maximum permissible errors for automatic weighing for each class for loads not less than Σ_{min} : <ul style="list-style-type: none"> ▪ do not exceed values in Table 1 rounded to the nearest d_t 			
2.2.2	A.7	Maximum permissible errors for influence factor tests:			
		<ul style="list-style-type: none"> ▪ do not exceed values in Table 2, ▪ accuracy of rounding errors at least $0.2 d_t$ 			
2.3	Observe	Form of the scale interval: $1 \times 10^k, 2 \times 10^k$ or 5×10^k	Note		
2.4	Observe	Totalization scale interval: $0.01 \% \leq d_t \leq 0.1 \%$ of Max	Note		
2.5	Observe	Minimum totalized load: $\Sigma_{min} \geq Min$ $\Sigma_{min} \geq 1000 d_t$ for class 0.2, or $400 d_t$ for class 0.5, or $200 d_t$ for class 1, or $100 d_t$ for class 2			
2.6	A.6.2	Agreement between multiple indicating devices			
		For a given load, the difference between the weighing results from any two devices having same scale interval is:			
	Observe	<ul style="list-style-type: none"> ▪ not greater than the absolute value of the maximum permissible errors for automatic weighing for analog devices. ▪ zero for digital displaying and printing devices. 			
2.7	A.7.3	Influence factors			
2.7.1.1	A.7.3.1	Static temperatures			
2.7.1.2		Temperature effect on no-load indication			
2.7.2		Mains power:			
	A.7.3.4	AC mains voltage variations			
	A.7.3.5	DC mains voltage variations			
	A.7.3.6	Battery voltage variations (DC)			
	A.7.3.7	12 V or 24 V road vehicle battery voltage variations			

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks
2.8	Observe	Units of measurement: gram (g), kilogram (kg), tonne (t)			
3		Technical requirements			
3.1	Observe	Suitability for use: design to suit intended materials and usage, and robust construction to maintain its metrological characteristics			
3.2	Observe	Security of operation			
3.2.1		No characteristics likely to facilitate fraudulent use			
3.2.2		Effect of accidental breakdown or maladjustment is evident			
3.2.3		Operation unaffected by incomplete discharge			
3.2.4		Effects of variation in the quantity of the load \geq Lim is evident			
3.2.5		Inhibition of usage at loads: > Max; < Min;			
3.2.6	Observe	Use as a non-automatic weighing instrument:			
		Complies with the requirements of OIML R 76-1:2006 <i>Non-automatic weighing instruments</i>			
3.2.7	A.6.3	Operational adjustments			
		Adjustment prevented in automatic mode, except during tests in accordance with 3.2.5 and 6.3 of R 107-1			
3.2.8	Observe	Controls			
		Controls come to rest in intended positions and unambiguously marked keys			
3.2.9	Observe	Dust extraction			
		Shall not affect measurement			
3.2.10	A.6.1	Stable equilibrium			
		Under continuous or temporary disturbance of stable equilibrium:			
		▪ printed or stored weighing values show no more than two adjacent; with one of them being the final weight value;			
		▪ for zero operations, correct operation according to 3.8.1 of R 107-1 is achievable			
3.2.11	Observe	Interlocks			
		Prevent or indicate operation outside specified working conditions for:			
		▪ minimum operating voltage (2.7.2)			
		▪ maximum safe load (3.2.4)			
		▪ zero-setting (3.8.3)			
		▪ automatic operation (3.2.5)			
3.3	A.6.4	Securing of components and pre-set controls			
3.3.1	Observe	Instrument, modules, devices and controls:			
		Fitted with a securing means, or			
		Enclosed;			

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks	
3.3.2	Observe	If enclosed, the enclosure is sealed				
		Seals are easily accessible				
		Legally relevant parameters protected by hardware or software means				
		Securing provided on all parts of the measuring system which cannot be materially protected in any other way against operations liable to affect the measurement accuracy				
		National regulations may specify the securing that is needed				
		Means of security:				
		Hardware and/or software means of security to restrict access to authorised persons only				
		Records of interventions including the date and a means of identifying the authorised person making the intervention (see a) above): <ul style="list-style-type: none"> ▪ can be memorised, accessed and displayed; ▪ traceability of the interventions is assured for at least the period of time in between periodical verifications depending on national regulations 				
		Records may not be overwritten, and if the storage capacities for records is exhausted, no further intervention shall be possible without breaking a physical seal				
		Software functions secured against intentional, unintentional and accidental changes in accordance with 3.6 of R 107-1				
		3.4	A.6.5 Observe	Transmission of legally relevant data via interfaces secured against intentional, unintentional and accidental changes according to 4.2.6.2 of R 107-1		
Securing possibilities available in an instrument shall be such that separate securing of the settings may be possible						
Stored measurement data is secured against intentional, unintentional and accidental changes in accordance with 3.5 of R 107-1						
Indication and recording of weighing results						
Devices included with the instruments						
Principal totalization indicating device	Present []			Not present []		
Supplementary totalization indicating device	Present []			Not present []		
Partial totalization indicating device	Present []			Not present []		
Data storage device	Present []			Not present []		
Printer	Present []			Not present []		
3.4.1	Observe			Quality of indication		
		Reliable, easy and unambiguous under normal conditions				
		Overall inaccuracy of an analogue device $< 0.2 d_t$				

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks
3.4.2	A.6.5	The scales, numbering and printing shall permit the figures which form the results to be read by simple juxtaposition			
3.4.2.1	Observe	Form of the indication			
		Units of mass			
		Results contain names and symbols of the units of mass			
		for any one indication, only one unit of mass			
		Units of mass written in small letters (lower case) in accordance with 2.8 of R 107-1.			
3.4.2.2	Observe	Digital indication			
		Digital zero indication includes the display of a zero for all places that are displayed to the right of a decimal point and at least one place to the left			
		When no decimal values are displayed, a zero shall be displayed for each place of the displayed division			
		Decimal fraction is separated from its integer by a decimal sign (comma or dot) with the indication showing at least one figure to the left of the sign and all figures to the right			
		Decimal sign on one line with the bottom of the figures (e.g. 0.305 kg) to separate integer and decimal fraction			
3.4.2.3	Observe	Scale interval			
		All devices (except supplementary devices) shall have the same scale interval.			
		Form of the scale interval is in accordance with requirements in 2.3 of R 107-1			
		Decimal sign maintains its position in the display where the scale interval is changed automatically			
3.4.3	Observe	Totalization indicating devices			
		Allow reliable, clear and unambiguous reading of the results by simple juxtaposition and bear the symbol of the appropriate unit of mass.			
		Printing is clear and permanent for the intended use. Printed figures are at least 2 mm high			
		It is not possible to reset the principle totalization device to zero an automatic operation.			
		On interruption of automatic operation, it is not possible to reset the partial totalization indicating device to zero unless the last total indicated before resetting to zero is automatically recorded			
		Control indicating device is to a higher resolution than that of the principal totalization indicating device.			
		During static weighing in non-automatic operations, printing is inhibited if the stability criteria in 3.2.10 of R 107-1 are not fulfilled			
3.4.4	Observe	Combined indicating devices			
		Combined indication on demand clearly identified			
3.4.5		Instruments that tare weigh			
		For instruments used to receive (weigh in), the no-load reference value shall be determined and recorded only at the beginning of each weighing cycle			

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks
3.5	Observe	For instruments used to deliver (weigh out), the no-load reference value shall be determined and recorded only after the gross load reference value for each weighing cycle has been indicated and recorded			
		Data storage device			
		Memory of the instrument (hard drive)	Present []		Not present []
		Removable external storage	Present []		Not present []
		Stored data is adequately protected against intentional and unintentional changes during storage process and contains all relevant information necessary to reconstruct an earlier measurement			
		Data storage security			
		Stored data is secured in accordance with the appropriate requirements in 3.5 of R 107-1			
		If software realizing the data storage can be transmitted to or downloaded into the instrument these processes shall be secured in accordance with requirements in 3.6 of R 107-1			
		External storage devices identification and security attributes are automatically verified to ensure integrity and authenticity			
		Exchangeable storage media for storing measurement data need not be sealed provided that the stored data is secured by a specific checksum or key code			
3.6	A.1.1 Observe	Replacement of old data with new data is only possible when the owner of the old data has given authority to overwrite the old data			
		Software			
3.6.1	A.1.1	Legally relevant software (T.2.7.7.1) of the instrument is identified by the manufacturer			
		Software information submitted with software controlled instruments			
		Description of the legally relevant software			
		Description of the accuracy of the measuring algorithms (e.g. programming modes)			
		Description of the user interface, menus and dialogues			
		The unambiguous software identification			
		Description of the embedded software			
		Overview of the system hardware, e.g. block diagram, type of computer(s), software source code, etc, if not described in the operating manual			
		Means of securing software			
		Operating manual			
3.6.2		Security of legally relevant software			
		Appropriate requirements for securing given in 3.3 and 3.6 of R 107-1			
		Assignment of appropriate software identification to legally relevant software, which is adapted in the case of every software change that may affect the functions and accuracy of the instrument			

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks	
3.7	A.5.4	Functions performed or initiated via connected interfaces, i.e., transmission of legally relevant software, shall comply with the securing requirements for interfaces in 4.2.6 in R 107-1				
		National regulation may specify the requirements for security of software controlled instruments				
		Instruments with control indicating devices				
		Load receptor shall have the facility to support a quantity of standard weights in accordance with Table 3 of R 107-1				
		Zero-setting devices				
		The types and modes of zero-setting required on an instrument are specified in accordance with national regulations	enter in remarks			
		Observe	Zero-setting modes:			
			Automatic zero-setting	Present []	Not present []	
			Semi-automatic zero-setting	Present []	Not present []	
			Non-automatic zero-setting	Present []	Not present []	
3.8.1	A.5.4.3	Accuracy of zero-setting: $\leq 0.25 d_t$				
3.8.2	Observe	Maximum effect				
		Effect of zero-setting device does not alter the maximum weighing capacity				
		Overall effect of:				
		Zero-setting range < 4 % =	%			
		Initial zero-setting < 20 % =	%			
3.8.3	A.6.8.1	Control of the zero-setting device				
	Observe	Operation of the zero-setting device shall be possible only when the instrument is in stable equilibrium (3.2.10), and				
		Rate of correction of zero-tracking shall not be more than 0.5 d per second				
		Interlock prevents automatic operation:				
		▪ if the zero indication varies by or more than:				
		– 1 d _t on instruments with an automatic zero-setting device, or				
		– 0.5 d _t on instruments with a semi-automatic or non-automatic zero-setting device				
		▪ if the instrument is not zeroed automatically following an automatic weighing cycle				
		A description of the operation of the automatic zero-setting device (e.g. the maximum programmable time interval) is specified by the manufacturer				
		The programmable interval specified by the manufacturer is sufficient to maintain zero within 0.5 d _t				
		Non-automatic or semi-automatic zero-setting device inoperable during automatic operation				

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks
3.8.4	Observe	Digital indicating device:			
		▪ provides an indication of when the deviation from zero is not more than $0.25 d_t$, or			
		▪ automatically maintains a “center of zero” condition to $\pm 1/4 d_t$ or less			
3.9	A.1.4	Descriptive markings, variable according to national regulation:			
3.9.1	Observe	Markings shown in full:			
		Identification mark or name of the manufacturer			
		Identification mark or name of the importer (if applicable)			
		Serial number of the instrument			
		Product description			
		Control scale interval (if applicable) (g, kg or t)			
		Electrical supply voltage (V)			
		Electrical supply frequency, (if applicable) (Hz)			
		Pneumatic/hydraulic pressure (if applicable) (kPa or bar)			
		Software identification (if applicable)			
		3.9.2	Observe	Markings shown in code:	
Type approval sign					
Indication of the class of accuracy: 0.2, 0.5, 1 or 2					
Maximum capacity, Max (g, kg or t)					
Minimum capacity, Min (g, kg or t)					
Minimum totalized load, Σ_{min} (g, kg or t)					
Totalization scale interval, d_t (g, kg or t)					
3.9.3	Observe	Supplementary markings:			
		Any additional markings	enter in remarks		
3.9.4	Observe	Presentation of descriptive markings:			
		Indelible and of size, shape and clarity that allows easy reading			
		Shown in accordance with national language or in form of adequate, internationally agreed and published pictograms or signs			
		Grouped together in a clearly visible place either on a descriptive plate or sticker fixed permanently near the indicating device, or on a non removable part of the instrument itself			
		In case of a plate or sticker which is not destroyed when removed, a means of securing shall be provided			
		Shown on a programmable display, and:			
		At least Max, Min and d_t shall be displayed as long as the instrument is switched on			
		The other marking may be shown on manual command			
		Described in the type approval certificate			

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks
3.9.4	Observe	Markings (device-specific parameters) comply with the securing requirements in 3.3 and 3.6			
		Markings on a data plate for software controlled display include:			
		Max, Min and d_t shown near the display			
		Type and designation of the instrument			
		Type approval number or sign			
		Name or identification mark of the manufacturer			
		Electrical supply voltage (V)			
		Electrical supply frequency (Hz)			
		Pneumatic/hydraulic pressure, (if applicable) (kPa or bar)			
3.10	A.1.4	Verification marks			
3.10.1	Observe	Position of verification marks:			
		Cannot be removed without damaging the marks			
		Allows easy application of marks			
3.10.2	Observe	Visible without the instrument having to be removed			
		Mounting			
		Verification mark support ensures conservation of the marks			
4		The type and method of sealing shall be determined by national prescription.			
		General requirements			
4.1.1		Rated operating conditions: errors do not exceed mpe			
4.1.2		Disturbances			
		Electronic instruments designed and manufactured so that:			
		Significant faults do not occur, or			
		Significant faults are detected and acted upon			
4.2	A.1.5	Functional requirements			
4.2.1	Observe	Acting upon significant faults: Note below			
		Instrument is made inoperative automatically, or			
		Visual or audible indication is provided automatically and continuous until the user takes action or the fault disappears			
		Totalized load information is retained when a significant fault occurs			
4.2.2	Observe	Indicator display test: Upon switch-on of displays on which failures become evident, all relevant signs of indicating device are active and non-active for sufficient time to be checked by operator			
4.2.5	A.5.3 Observe	Warm-up time:			
		No indication or transmission of weighing results			
		Automatic operation is inhibited			

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks
4.2.6	A.7.2.2	Interfaces			
4.2.6.1	Observe	When fitted: Instrument shall continue to function correctly and its metrological functions shall not be influenced			
	A.7.2.3	Interface information submitted with instrument:			
		▪ list of all commands (e.g. menu items)			
		▪ description of the software interface			
		▪ list of all commands together			
		▪ brief description of their meaning and their effect on the functions and data of the instrument			
		▪ other interface description			
4.2.6.2	Observe	Interface security:			
		▪ legally relevant software, measurement data and functions of the instrument are not adversely affected or influenced by other interconnected instruments, or by disturbances acting on the interface			
		▪ protective interface protects data against accidental or deliberate interference during the transfer			
		▪ hardware and software functions comply with the appropriate securing requirements in 3.3 and 3.6 respectively			
		▪ it shall be easily possible to verify the authenticity and integrity of data transmitted to and from the instrument			
		Other instruments required by national regulation to be connected to the interfaces of an instrument shall be secured to automatically inhibit the operation of the instrument for reasons of the non-presence or improper functioning of the required device			
4.2.7	A.6.6	AC mains voltage supply failure:			
	Observe	Metrological information retained for at least 24 hours			
		Switch-over to emergency power supply shall not cause significant fault			
4.2.8	A.6.7	External or plug-in (AC or DC) battery voltage supply:			
		When battery voltage is below the specified voltage value, the instrument:			
		Continues to function correctly, or			
		Is automatically put out of service			
5		Type approval			
5.1.1	A.1.1	Documentation submitted for type approval includes:			
		Metrological characteristics of the instrument			
		Standard set of specifications for the instrument			
		Functional description of the components and devices			
		Drawings, diagrams and general software information explaining the construction and operation			
		Details of fractions p_i (modules tested separately)			

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks	
5.1.1	A.1.1	Indicating devices (3.4.3)				
		Data storage device (3.5)				
		Zero-setting device (3.8)				
		Documentation submitted for type approval includes:				
		Interfaces (types, intended use, immunity to external influences instructions (4.2.6)				
		For software controlled instruments detailed software information (3.6)				
		Description of the stable equilibrium function of the instrument (3.2.11)				
		Drawing or photo of the instrument showing the principle and the location of control marks, securing marks, descriptive and verification marks (3.9, 3.10)				
		Operating instructions, operating manual				
		Any document or other evidence that the design and construction of the instrument complies with the requirements of the Recommendation				
5.1.2.1		General requirements				
		Instruments available for tests as follows:				
		<ul style="list-style-type: none"> ▪ fully operational at a typical site 	Confirm			
5.1.2.2		<ul style="list-style-type: none"> ▪ for laboratory simulation testing 	Confirm			
		Type evaluation tests				
5.1.2.3	A.5.1	Documents examined and tests carried out to verify that instrument complies with:				
		<ul style="list-style-type: none"> ▪ metrological requirements in Clause 2 				
		<ul style="list-style-type: none"> ▪ technical requirements in Clause 3 				
		<ul style="list-style-type: none"> ▪ requirements in Clause 4 for electronic instruments 				
		Acceptance of test report from another metrological authority	Note			
		Instruments used in static weighing shall comply with the requirements of 3.2.6	Note			
		Material tests				
		Instruments subjected to in-site material tests in accordance with:				
		<ul style="list-style-type: none"> ▪ Separate verification method as in A.5.1.1 				
		<ul style="list-style-type: none"> ▪ Integral verification method as in A.5.1.2 				
5.1.2.4		Simulation tests				
		Influence quantities shall be applied during simulation tests in a manner that will reveal an alteration in accordance with:				
		<ul style="list-style-type: none"> ▪ R 107-1, 2.7 for all instruments; and 				
		<ul style="list-style-type: none"> ▪ R 107-1, 4, for electronic instruments 				
5.1.4		Modules				
		Examination and separate test of modules of an instrument or system according to:				
		Modules to be examined separately defined and submitted by the manufacturer				

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks
5.2		The error limits applicable to a module which is examined separately apportioned in accordance with requirements in 5.1.4.1 of R 107-1			
		Initial verification			
5.2.1		Instruments shall comply with R 107-1, 2 (except 2.7) and 3 for any product(s) for which they are intended and when operated under normal weighing conditions	Confirm		
		General requirements			
5.2.2		Tests shall be carried out, in-situ, with the instrument fully assembled and fixed in the position in which it is intended to be used. Instrument installed such that the weighing operation will be the same whether for the purposes of testing or for normal weighing operation	Confirm		
		Operational tests			
5.2.3		Instruments subjected to in-site material tests in accordance with:			
		Separate verification method as in A.5.1.1			
		Integral verification method as in A.5.1.2			
		Instruments used in static weighing in accordance with the integral verification method in A.5.1.2 shall comply with the requirements of 3.2.6			
		Conformity			
		Conformity to the approved type and/or this Recommendation shall cover:			
		compliance with the appropriate maximum permissible errors in 2.2.1	Confirm		
		correct functioning of all devices, e.g. interlocks, indicating and recording devices	Confirm		
		construction material and design, as far as they are of metrological relevance	Confirm		
		if appropriate a list of the tests performed	Confirm		
6 6.1		Test methods			
		General test procedure			
		In-situ material tests shall be carried out as follows:			
		In accordance with the descriptive markings	Confirm		
		Under the rated operating conditions for the instrument	Confirm		
		Not less than three material tests shall be conducted, one at maximum capacity, Max, one at minimum capacity, Min, and one close to the minimum totalized load, Σ_{min} , marked on the instrument	Confirm		
		With test load(s) that is representative of the range and type of products for which the instrument is likely to be used or product(s) for which the instrument is intended	Confirm		
		Each test shall be conducted at the maximum rate of weighing cycles per hour	Confirm		
		Minimum of five weighing cycles per material test shall be conducted	Note		

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks
6.2	A.5.1.1	Equipment near the instrument, including conveyors, dust collection systems, etc. that are in use when the instrument is in normal operation, shall be in use during the tests	Note		
6.2.1		If the instrument can divert weighed material through alternative discharge facilities the test program shall be performed for each alternative unless weigh hopper is not affected, for example, by different air flow	Note		
6.2.2	A.5.1.2	Control instruments and test standards			
6.2.2		Separate control instrument	Error and uncertainty of a separate control instrument verified at any time other than immediately prior to the weighing tests shall be less than one-fifth of the maximum permissible error for automatic weighing in 2.2.1		
6.2.4	A.5.1.2.3	Integral control instrument			
		Combined error and uncertainty of the integral control instrument shall be less than one-third of the maximum permissible error in 2.2.1	Note mpe		
		Integral control instrument provided with an appropriate scale interval, and complies with the requirements of 3.2.6 and A.5.1.2	Confirm		
		When load receptor cannot be loaded with sufficient standard weights, instrument shall be subjected to material tests by the separate verification method. In which case an appropriate control instrument shall be available	Note method		
6.3	A.5.1.2.3	Standard weights			
		Reference standard weights or masses used for type examination or verification comply with the metrological requirements of OIML R 111:2004 Error of the additional weights used to determine the rounding error of the control instrument shall not exceed one-fifth of the maximum permissible errors of the instrument to be verified for the load, as specified in R 107-1, 2.2.2 for initial verification	Confirm		
		Interruption of the automatic operation			
	Integral control instrument uses a test-stop program as part of the automatic weighing program to automatically interrupt automatic weighing operation twice as specified in R 107-1, A.5.1.2.3 during each weighing cycle in order to weigh and discharge a subdivision of the test load If the integral control instrument is installed as an air-enclosed system interruption of the automatic operation during consecutive weighing cycles may not be possible and tests shall be conducted as specified in R 107-1, A.5.1.2.7	Confirm			

Use this space to detail remarks from the checklist