



Smart meter requirements and tests in harmonized standards

George Teunisse
Verispect (NL)

*OIML Seminar on Smart Meters
Brijuni, Croatia – 2-5 June 2009*





Contents

- Introduction
- Critical functions in smart metering
- Collected information from recommendations and some standards
- Some observations on lacking requirements
- Impact on future OIML recommendation development



My background

Expert on EM Fields and EMC since 1985

Involved in development of OIML D11

At present (since January 2009):

OIML secretary TC 8/SC 7 (gas metering)


OIML secretary TC 5/SC 1 (D11)

OIML contactperson in NL

Smart metering implies:

⇒ extra communication connections

⇒ unchanged measuring devices



Consequences implementation smart metering

In general:

- Basic measurement part does not change:
 - local metrological functionalities will be maintained
- Requirements and tests on these are well prescribed
 - this including sensitivity to environmental conditions

Why add requirements ?

INTERNATIONAL
RECOMMENDATION

OIML R 49-1
Edition 2006 (E)

Water meters intended for the metering
of cold potable water and hot water

Part 1: Metrological and technical requirements

Compteurs d'eau destinés au mesurage de l'eau potable froide
et de l'eau chaude

Partie 1: Exigences métrologiques et techniques



Critical functions in smart metering

Need for transparency in:

- calculation and presentation of the measurand
- calculation of the transaction parameter
(= a value based on the measurand)

Risks:

- Influence or disturbance of
 - the measurand
 - the transaction parameter



Critical functions

Risk of influence or disturbance:

- Hardware type interventions
 - electronics
 - interventions on transmission lines
- Software type interventions

How ?

Intended


- hardware: user influence
- software: e.g. hacking

Unintended (accidental)

- hardware: EM interference
- software : bugs

Standardisation of:

- specific hardware and software
- communication protocols



Eliminating of EM or other interference:

e.g. opto-coupling and optical transmission lines

How to deal with this in recommendations:

- Description of devices/functions required
- Prescription of specific tests

Is this yet dealt with in utility metering ?



Survey of documents

(recommendations and standards)



Survey of documents

I reviewed on integrity and communication aspects the Recommendations:

OIML R 137-1
(gas meters)

OIML R 46
(active electrical
energy meters)

OIML R 49
(water meters)

OIML R 75
(heath meters)

Netherlands Technical Agreement

NTA 8130 (e)

Minimum set of functions for metering of electricity, gas and thermal energy for domestic customers

Basisfuncties voor de meetinrichting voor elektriciteit, gas en thermische energie voor kleinverbruikers



Survey of documents

A survey on **integrity** aspects and **data transmission** requirements on Standards

EN 1359
gas meters
(diaphragm meter)

EN 1434
heath meters

EN 12261
gas meters
(turbine)

ISO 4064
water meters

EN 14154
water meters



R 137-1 (gas meters)

The subject is tackled mostly in **general** terms and in **different** ways:

e.g. draft **R137-1** 4.6.15

Metrological requirements for software:

“ Gas meters provided with software shall be designed such that all the functions of the software do not affect the metrological behaviour”.



R 46 (electrical energy)

In R46 (3.6.2) protection of hardware and firmware it is mentioned:

“f) The meter shall be capable of recording all interventions which could potential result in alteration of any metrological parameters, including the contents of any register(s) which store(s) energy measurements.”



Draft R49-1 (water meters)

For R 49-1 (draft revision) the following technical requirement has been suggested:

“The water meter shall have no feature likely to facilitate fraudulent use, whereas possibilities for unintentional misuse shall be minimal”

“The water meter shall be designed to reduce as far as possible the effect of a defect that would lead to an inaccurate measurement result, unless the presence of such a defect is obvious.”



R 75 (heat meters)

In R 75 no specific requirements for integrity or data transmission were found



Some Standards

Coverage in standard		integrity/ security	data comm.	remark
Gas meter				
EN 1359	Diaphragm	-	--	reference to MID
EN 12261	Turbine	--	--	not really touched
ISO 9951	Turbine	--	--	
EN 12405	Volume Conversion	?		
EN 12480	Rotary Displacement	?		
EN 14236	Ultrasonic	?		
Water meter				
EN 14154-1; -2; -3	General	+	+	at checking facilities
ISO 4064-1; -2; -3	General	+	+	
Heath meter				
EN 1434-1; -2; -3	General	--	--	not touched
Electrical energy meter				
EN 50470-1; -2;	Dynamic meter	+	-	at protection against corruption
EN 50470-3	Static meter	++	++	

Netherlands Technical Agreement

NTA 8130 (e)

Minimum set of functions for metering of electricity, gas and thermal energy for domestic customers

Basisfuncties voor de meetinrichting voor elektriciteit, gas en thermische energie voor kleinverbruikers



NTA 8130

Produced August 2007 by NEN; commissioned by Min. of Economic Affairs in NL

Interesting document describing possible functions

“**smart metering system**”

describes minimum requirements:

Rather strict in:

- Configuration smart grid
- Transmission requirements:
parameters, sequence, logging, availability of data




NTA 8130

Describes possible applications:

- Improvement administrative processes
- Awareness customer
- Safe remote activation/deactivation
- Change in threshold
- Different tariffs
- Prepayment
- Monitoring the distribution network

Communication ports





Communication ports:

P1: local, one way communication from metering system to service modules

P2: communication between metering instruments and metering system (read/write)

P3: port to Central Access Server (CAS) (read/write)

P4: from CAS to Supplier, service provider, grid operator (read/write)



Communication (data) contents and availability (chapt. 5.2)

- Which port
- Which parameters

Those parameters include e.g. :

Actual delivery and additional

- status information of metering installation;
- number of dips/peaks;
- errors;
- **fraud detection and registration !**



**Can NTA 8130 be useful for
OIML as document ?**



NTA 8130 contents

Comparison NTA 8130 with OIML recommendation template

Contents	scope	terminology	description	units of measurement	metrological requirements	technical requirements	inscriptions	instruction manual	sealing and stamping	suiteability for testing	sealing and stamping	performance tests
Applicability	A.	A.	A.	A.	P.	A.	P.	A.	P.	A.	A.	A.
Covered by NTA 8130 (chapt.)	1	3	pref. + 5	5	N.C.	P.	N.C.	N.C.	N.C.	N.C.	N.C.	N.C.

Not Applicable	Applicable	Partly	Not covered
N.A.	A.	P.	N.C.



NTA 8130 contents (cont.)

Metrological requirements

metrological requirements	<i>accuracy classes</i>	<i>measuring range</i>	<i>MPE</i>	<i>scale interval</i>	<i>significant fault</i>	<i>apportioning of errors</i>	<i>repeatability</i>	<i>multiple indic. devices</i>	<i>discrimination</i>	<i>rated operating conditions</i>	<i>significant fault</i>	<i>disturbances</i>	<i>durability</i>	<i>presumption of compliance</i>
Applicability	N.A.	N.A.	N.A.	A.	N.A.	N.A.	N.A.	A.	N.A.	A.	A.	A.	A.	A.
Covered by NTA 8130				N.C.				P.		N.C.	N.C.	N.C.	N.C.	N.C.

<i>Not Applicable</i>	<i>Applicable</i>	<i>Partly</i>	<i>Not covered</i>
N.A.	A.	P.	N.C.



NTA 8130 contents (cont.)

Technical requirements

Technical requirements	<i>construction</i>	<i>presentation of measurement value</i>	<i>adjustment facilities</i>	<i>protection against fraude</i>	<i>checking facilities</i>	<i>Durability protection</i>	<i>Battery powered</i>	<i>software</i>	<i>durable recording</i>	<i>data transmission</i>
Applicability	A.	A.	P.	A.	P.	N.A.	N.A.	A.	A.	A.
Covered by NTA 8130 (chapt.)			N.C.	5.2.8.6	N.C.			N.C.	5.2	N.C.

<i>Not Applicable</i>	<i>Applicable</i>	<i>Partly</i>	<i>Not covered</i>
N.A.	A.	P.	N.C.



NTA 8130

Referred to (in EU) as basic material for producing standard for smart meters

NTA 8130 useful but is **not sufficient** because:

- Focus primarily on functionality
- Focus only on existing functionalities, based on practice in The Netherlands
- Sometimes goes into deep detail
- Rather strict (e.g. 4 ports) and static document
- Does not deal with metrological requirements or (metrological) integrity nor privacy aspects



Example of possible Unintentional interference

- Use of different ways of data communication: GPRS; PLC; Ethernet; etc.

- In case of PLC

- Roll-out of many smart meters

- ⇒ Interference reported on touch dimmer lamps; (Cenelec SC 205A/Sec0228/RM)

Open structure of PLC could introduce unexpected interference


Could work out both directions





Lacking interference test

Present EMC requirements and tests OIML do not cover these PLC signals



Immunity below 150 kHz is not covered
(Emission covered by EN 50065-1)



Impact on future OIML recommendation development



Impact on OIML Recommendations ?

Choices to be made:

- Should requirements and tests for new functionalities be added to each recommendation ?
- Should specific tests be developed ?
- Should a Dxx on smart metering be produced ?
- Should TC / SC 's (utility) work be combined ?

Opinion:

A specific document (similar to D11 or D31) on requirements and tests for **remote** measurement (registration) could be of great help to TC's and SC's



Some references

Lot of information can be found in the study:

Security analysis of Dutch smart metering systems
by Sander Keeming & Bart Roos (University of Amsterdam)

<http://staff.science.uva.nl/~delaat/sne-2007-2008/p33/report.pdf>

also in the presentation:

Security, Privacy and AMR Systems: Small Issues or Sources of Future Problems ?

by Engelbert Hubbers & Marco van Eekelen
(Radboud University Nijmegen)



Inventory performed by CLC TC 13

Additional information:

Cenelec TC 13 has also performed an inventory on standardization needed.

This was presented in Brussels on 25 May 2009 in Brussels by the chairman Bernd Schultz



Thank you for your attention
Questions

OIML Seminar on Smart Meters
Brijuni, Croatia – 2-5 June 2009